

---

## Central Coast Regional Water Quality Control Board

June 10, 2013

Mr. Robert Bellew  
[bobbellew@earthlink.net](mailto:bobbellew@earthlink.net)  
Uni-Kool Partners, Inc.  
P.O. Box 3140  
Salinas, CA 93912

Sent via Electronic Mail only

Dear Mr. Bellew:

**ADOPTION OF WASTE DISCHARGE REQUIREMENTS ORDER NO. R3-2013-0002,  
(NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM [NPDES] PERMIT NO.  
CA0005720), UNI-KOOL PARTNERS SALINAS PACKING FACILITY WASTEWATER  
TREATMENT PLANT, MONTEREY COUNTY**

At its public meeting on May 30, 2013, the Central Coast Regional Water Quality Control Board adopted Order No. R3-2013-0002 Waste Discharge Requirements for the Uni-Kool facility on John Street. Please review the requirements carefully and note that some modifications to previous monitoring requirements are specified. The Order will also be posted online at: [http://www.waterboards.ca.gov/centralcoast/board\\_decisions/adopted\\_orders/index.shtml](http://www.waterboards.ca.gov/centralcoast/board_decisions/adopted_orders/index.shtml)

Thank you for your time in assisting with the process of adopting waste discharge requirements. If you have questions regarding the proposed Order, please contact **Katie DiSimone at (805) 542-4638 or [katie.disimone@waterboards.ca.gov](mailto:katie.disimone@waterboards.ca.gov)** or Sheila Soderberg at (805) 549-3592 or [ssoderberg@waterboards.ca.gov](mailto:ssoderberg@waterboards.ca.gov).

Sincerely,

Kenneth A. Harris Jr.  
Interim Executive Officer

Attachment: R3-2013-0002

Cc w/attachment:

Jamie Marincola, USEPA Region IX, [Marincola.JamesPaul@epa.gov](mailto:Marincola.JamesPaul@epa.gov)  
John Ramirez, Monterey County, [Ramirezj1@co.monterey.ca.us](mailto:Ramirezj1@co.monterey.ca.us)  
Brian Garneu, Carmel Lahaina, [carmellahaina@aol.com](mailto:carmellahaina@aol.com)  
Deirdre Whalen, Monterey Bay National Marine Sanctuary, [deirdre.whelen@noaa.gov](mailto:deirdre.whelen@noaa.gov).  
Dan Connally, PG Environmental, LLC, [Dan.Connally@pgenv.com](mailto:Dan.Connally@pgenv.com)  
David Smith, USEPA Region IX, [Smith.davidw@epa.gov](mailto:Smith.davidw@epa.gov)  
Steve Shimek, Otter Project, [exec@otterproject.org](mailto:exec@otterproject.org)  
Katie DiSimone, Central Coast Water Board, [kdisimone@waterboards.ca.gov](mailto:kdisimone@waterboards.ca.gov)

Todd Stanly, Central Coast Water Board, [tstanley@waterboards.ca.gov](mailto:tstanley@waterboards.ca.gov)

ECM 268996

Filename and Path: S:\NPDES\NPDES Facilities\Monterey Co\Uni-kool John Street, Salinas\R3-2013-0002\Cover letter adopted order.docx

**Central Coast Regional Water Quality Control Board**

**ORDER NO. R3-2013-0002  
NPDES NO. CA0005720**

**WASTE DISCHARGE REQUIREMENTS FOR  
THE UNI-KOOL PARTNERS  
UNI-KOOL PARTNERS VEGETABLE PACKING FACILITY, SALINAS**

The following Discharger is subject to waste discharge requirements as set forth in this Order.

**Table 1. Discharger Information**

<b>Discharger</b>	The Uni-Kool Partners
<b>Name of Facility</b>	The Uni-Kool Partners Vegetable Packing Facility
<b>Facility Address</b>	320 John Street
	Salinas, CA 93901
	Monterey County
The U.S. Environmental Protection Agency (USEPA) and the Central Coast Regional Water Quality Control Board have classified this discharge as a <b>minor</b> discharge.	

Discharges by The Uni-Kool Partners from the discharge point identified below are subject to waste discharge requirements as set forth in this Order:

**Table 2. Discharge Location**

Discharge Point	Effluent Description	Discharge Point Latitude	Discharge Point Longitude	Receiving Water
001	Treated Wastewater and Stormwater	36° 40' 16" N	121° 38' 23" W	Salinas Reclamation Canal

**Table 3. Administrative Information**

This Order was adopted by the Regional Water Quality Control Board on:	May 30, 2013
This Order shall become effective on:	July 1, 2013
This Order shall expire on:	July 1, 2018
The Discharger shall file a Report of Waste Discharge in accordance with title 23, California Code of Regulations, as application for issuance of new waste discharge requirements no later than:	<u>220 days prior to the Order expiration date</u>

THEREFORE, IT IS HEREBY ORDERED, that this Order supersedes Order No. R3-2005-0046 except for enforcement purposes, and, in order to meet the provisions contained in division 7 of the Water Code (commencing with section 13000) and regulations adopted thereunder, and the provisions of the federal CWA and regulations and guidelines adopted thereunder, the Discharger shall comply with the requirements in this Order.

I, Kenneth A. Harris Jr., Interim Executive Officer, do hereby certify that this Order, with all attachments, is a full, true, and correct copy of an order adopted by the California Regional Water Quality Control Board, Central Coastal Region on May 30, 2013.

---

Kenneth A. Harris Jr., Interim Executive Officer

## Table of Contents

I.	Facility Information .....	4
II.	Findings .....	4
III.	Discharge Prohibitions .....	8
IV.	Effluent Limitations and Discharge Specifications .....	8
	A. Effluent Limitations – Discharge Point 001 .....	8
	B. Land Discharge Specifications .....	9
	C. Reclamation Specifications .....	9
V.	Receiving Water Limitations .....	9
	A. Surface Water Limitations .....	9
	B. Groundwater Limitations .....	11
VI.	Provisions .....	12
	A. Standard Provisions .....	12
	B. Monitoring and Reporting Program (MRP) Requirements .....	12
	C. Special Provisions .....	12
	1. Reopener Provisions .....	12
	2. Special Studies, Technical Reports and Additional Monitoring Requirements .....	12
	3. Best Management Practices and Pollution Prevention .....	13
	4. Construction, Operation and Maintenance Specifications .....	13
	5. Special Provisions for Municipal Facilities (POTWs Only) .....	13
	6. Other Special Provisions .....	13
	7. Compliance Schedules .....	14

## List of Tables

Table 1.	Discharger Information .....	1
Table 2.	Discharge Location .....	1
Table 3.	Administrative Information .....	1
Table 4.	Facility Information .....	4
Table 5.	Basin Plan Beneficial Uses .....	6
Table 6.	Effluent Limitations for Conventional and Non-Conventional Pollutants .....	9
Table 7.	Effluent Limitations for Conventional and Non-Conventional Pollutants .....	9
Table 8.	Toxicity Reduction Evaluation—Schedule .....	13

## List of Attachments

Attachment A – Definitions .....	A-1
Attachment B – Map .....	B-1
Attachment C – Flow Schematic .....	C-1
Attachment D – Standard Provisions .....	D-1
Attachment E – Monitoring and Reporting Program .....	E-1
Attachment F – Fact Sheet .....	F-1
Attachment G – Priority Organic Pollutants and Pesticides .....	G-1

**I. FACILITY INFORMATION**

The following Discharger is subject to waste discharge requirements as set forth in this Order:

**Table 4. Facility Information**

<b>Discharger</b>	The Uni-Kool Partners
<b>Name of Facility</b>	Uni-Kool Partners Vegetable Packing Facility
<b>Facility Address</b>	320 John Street
	Salinas, CA 93901
	Monterey County
<b>Facility Contact, Title, and Phone</b>	Robert Bellew, Manager, (831) 424-4811
<b>Mailing Address</b>	PO Box 3140, Salinas, CA 93912
<b>Type of Facility</b>	Vegetable Processing (SIC Code 0273, NAICS Code 115114)
<b>Facility Design Flow</b>	0.10 million gallons per day (MGD)

**II. FINDINGS**

The California Regional Water Quality Control Board, Central Coast Region (hereinafter the Central Coast Water Board) finds:

**A. Background.** The Uni-Kool Partners (hereinafter the Discharger) is currently discharging pursuant to Order No. R3-2005-0046 and National Pollutant Discharge Elimination System (NPDES) Permit No. CA0005720. The Discharger submitted a Report of Waste Discharge, dated March 9, 2010, and applied to renew its NPDES permit to discharge up to 0.10 MGD (actual maximum daily flow) of treated wastewater and stormwater from the Uni-Kool Partners Vegetable Packing Facility. The Central Coast Water Board deemed the application complete on May 20, 2010.

For the purposes of this Order, references to the “discharger,” “facility,” or “permittee” in applicable federal and State laws, regulations, plans, or policies are held to be equivalent to references to the Discharger herein.

**B. Facility Description.** The Discharger owns and operates the Uni-Kool Partners Vegetable Packing Facility (hereinafter the Facility), a vegetable packing, processing and cold storage facility. The Facility generates process wastewater (cold storage melted ice, spent fresh vegetable wash water, equipment wash water, evaporative cooler blowdown) as well as on-site stormwater. Wastewater and stormwater generated at the Facility is pumped to an on-site treatment system, which consists of straining (coarse particulate removal), addition of anti-foaming agents, screening (Sweco-brand 80-mesh screens for fine particulate removal), settling, and aeration. The Facility has two aeration and settling ponds in series with a combined volume of 350,000 gallons. The ponds are connected via a weir between the two ponds.

Treated wastewater and stormwater is discharged from Discharge Point No. 001 to a storm drain tributary to the Salinas Reclamation Canal, a water of the United States within the Salinas Hydrologic Unit.

Attachment B provides a map of the area around the Facility. Attachment C provides a flow schematic of the Facility.

**C. Legal Authorities.** This Order is issued pursuant to CWA §402 and implementing regulations adopted by the USEPA and Chapter 5.5, Division 7 of the California Water Code (CWC),

commencing with §13370. It shall serve as an NPDES permit for point source discharges from the Facility to surface waters. This Order also serves as waste discharge requirements (WDRs) pursuant to article 4, chapter 4, division 7 of the CWC, commencing with §13260.

- D. Background and Rationale for Requirements.** The Central Coast Water Board developed the requirements in this Order based on information submitted in of the application, in monitoring and reporting programs, and other available information, including a site visit on May 9, 2012. The Fact Sheet (Attachment F), which contains background information and rationale for this Order's requirements, is hereby incorporated into this Order and constitutes part of its Findings. Attachments A through E are also incorporated into this Order.
- E. California Environmental Quality Act (CEQA).** Pursuant to CWC §13389, this action to adopt an NPDES permit is exempt from the provisions of the CEQA, Public Resources Code §21100 through §21177.
- F. Technology-Based Effluent Limitations.** CWA §301(b) and USEPA's NPDES regulations at 40 CFR 122.44 require that permits include, at a minimum, conditions meeting applicable technology-based requirements and any more stringent effluent limitations necessary to meet applicable water quality standards. Discharges authorized by this Order must meet minimum federal technology-based requirements based on Best Professional Judgment (BPJ) in accordance with 40 CFR 125.3. Discussion regarding development of technology-based effluent limitations is included in the Fact Sheet (Attachment F).
- G. Water Quality-Based Effluent Limitations.** CWA §301(b) and NPDES regulations at 40 CFR 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards.

NPDES regulations at 40 CFR 122.44(d)(1)(i) mandate that permits include effluent limitations for all pollutants that are or may be discharged at levels that have the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential is established for a pollutant, but there is no numeric criterion or objective for the pollutant, water quality-based effluent limitations (WQBELs) must be established using: (1) USEPA criteria guidance under CWA §304(a), supplemented where necessary by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion, such as a proposed State criterion or policy interpreting the State's narrative criterion, supplemented with other relevant information, as provided at 40 CFR 122.44(d)(1)(vi).

- H. Water Quality Control Plans.** The Central Coast Water Board has adopted the *Water Quality Control Plan for the Central Coastal Basin* (the Basin Plan), which designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for receiving waters within the Region. In addition, the Basin Plan implements State Water Resources Control Board (State Water Board) Resolution No. 88-63, which establishes State policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply. Beneficial uses established by the Basin Plan for the Salinas Reclamation Canal are presented in Table 5, below.

**Table 5. Basin Plan Beneficial Uses**

Discharge Point	Receiving Water Name	Beneficial Use(s)
001	Salinas Reclamation Canal	<ul style="list-style-type: none"> <li>• Contact Water Recreation (REC-1)</li> <li>• Non-contact Water Recreation (REC-2)</li> <li>• Wildlife Habitat (WILD)</li> <li>• Warm Freshwater Habitat (WARM)</li> <li>• Commercial and Sport Fishing (COMM)</li> </ul>
001	Groundwater	<ul style="list-style-type: none"> <li>• Municipal and Domestic Supply (MUN)</li> <li>• Agricultural Supply (AGR)</li> <li>• Industrial Supply (IND)</li> </ul>

Requirements of this Order implement the Basin Plan.

- I. National Toxics Rule (NTR) and California Toxics Rule (CTR).** USEPA adopted the NTR on December 22, 1992, and later amended it on May 4, 1995, and November 9, 1999. About forty criteria in the NTR applied in California. On May 18, 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the State. The CTR was amended on February 13, 2001. These rules contain water quality criteria for priority pollutants that are applicable to discharges from the Facility.
- J. State Implementation Policy.** On March 2, 2000, the State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP became effective on April 28, 2000, with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Central Coast Water Board in the Basin Plan. The SIP became effective on May 18, 2000, with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005, that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.
- K. Compliance Schedules and Interim Requirements.** Section 2.1 of the SIP provides that, based on a Discharger’s request and demonstration that it is infeasible for an existing Discharger to achieve immediate compliance with an effluent limitation derived from a CTR criterion, compliance schedules may be allowed in an NPDES permit. Unless an exception has been granted under section 5.3 of the SIP, a compliance schedule may not exceed 5 years from the date that the permit is issued or reissued, nor may it extend beyond 10 years from the effective date of the SIP (or May 18, 2010) to establish and comply with CTR criterion-based effluent limitations. Where a compliance schedule for a final effluent limitation exceeds 1 year, the Order must include interim numeric limitations for that constituent or parameter. Where allowed by the Basin Plan, compliance schedules and interim effluent limitations or discharge specifications may also be granted to allow time to implement a new or revised water quality objective. This Order does not include compliance schedules or interim effluent limitations.
- L. Alaska Rule.** On March 30, 2000, USEPA revised its regulation that specifies when new and revised State and tribal water quality standards (WQS) become effective for CWA purposes [65 Fed. Reg. 24641 (April 27, 2000) (codified at 40 CFR 131.21)]. Under the revised regulation (also known as the Alaska Rule), new and revised standards submitted to USEPA after May 30, 2000 must be approved by USEPA before being used for CWA purposes. The final rule also provides



that standards already in effect and submitted to USEPA by May 30, 2000 may be used for CWA purposes, whether or not approved by USEPA.

**M. Stringency of Requirements for Individual Pollutants.** This Order contains both technology-based and water quality-based effluent limitations for individual pollutants. The technology-based effluent limitations consist of restrictions for biochemical oxygen demand (BOD<sub>5</sub>), total suspended solids (TSS) and settleable solids, and are discussed in section IV.B of the Fact Sheet. This Order's technology-based pollutant restrictions implement the minimum applicable federal technology-based requirements.

WQBELs have been scientifically derived to implement water quality objectives that protect beneficial uses. Both the beneficial uses and the water quality objectives have been approved pursuant to federal law and are the applicable federal water quality standards. To the extent that toxic pollutant WQBELs were derived from the CTR, the CTR is the applicable standard pursuant to NPDES regulations at 40 CFR 131.38. The scientific procedures for calculating the individual WQBELs for priority pollutants are based on the CTR and the SIP, which was approved by USEPA on May 18, 2000. All beneficial uses and water quality objectives contained in the Basin Plan were approved under State law and submitted to and approved by USEPA prior to May 30, 2000. Any water quality objectives and beneficial uses submitted to USEPA prior to May 30, 2000, but not approved by USEPA before that date, are nonetheless "applicable water quality standards for purposes of the CWA" pursuant to NPDES regulations at 40 CFR 131.21(c)(1). Collectively, this Order's restrictions on individual pollutants are no more stringent than required to implement the requirements of the CWA.

**N. Antidegradation Policy.** NPDES regulations at 40 CFR 131.12 require that State water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution No. 68-16, which incorporates the federal antidegradation policy where the federal policy applies under federal law. Resolution No. 68-16 requires that the existing quality of waters be maintained unless degradation is justified based on specific findings. The Basin Plan implements and incorporates by reference both the State and federal antidegradation policies. As discussed in Section III.C.5 of the Fact Sheet, the permitted discharge is consistent with the antidegradation provisions of 40 CFR 131.12 and State Water Board Resolution No. 68-16.

**O. Anti-Backsliding Requirements.** CWA §402(o)(2) and §303(d)(4) and NPDES regulations at 40 CFR 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require effluent limitations in a reissued permit to be as stringent as those in the previous permit, with some exceptions where limitations may be relaxed. All effluent limitations in this Order are at least as stringent as the effluent limitations in the previous Order.

**P. Endangered Species Act.** This Order does not authorize any act that results in the taking of a threatened or endangered species or any act that is now prohibited, or becomes prohibited in the future, under either the California Endangered Species Act (Fish and Game Code §2050 to §2097) or the federal Endangered Species Act (16 U.S.C.A. §1531 to §1544). This Order requires compliance with effluent limits, receiving water limits, and other requirements to protect the beneficial uses of waters of the State. The Discharger is responsible for meeting all requirements of State and federal law regarding threatened and endangered species.

**Q. Monitoring and Reporting.** NPDES regulations at 40 CFR 122.48 require that all NPDES permits specify requirements for recording and reporting monitoring results. CWC §13267 and §13383 also authorize the Central Coast Water Board to require technical and monitoring reports. The

Monitoring and Reporting Program, provided as Attachment E to the Order, establishes monitoring and reporting requirements to implement federal and State requirements.

- R. Standard and Special Provisions.** Standard Provisions, which apply to all NPDES permits in accordance with 40 CFR 122.41, and additional conditions applicable to specified categories of permits in accordance with 40 CFR 122.42, are provided in Attachment D. The Discharger must comply with all standard provisions and with those additional conditions that are applicable pursuant to 40 CFR 122.42. The Central Coast Water Board has also included in this Order special provisions applicable to the Discharger. A rationale for the special provisions contained in this Order is provided in the attached Fact Sheet.
- S. Provisions and Requirements Implementing State Law.** The provisions and requirements in subsections IV.B, IV.C, and V.B of this Order are included to implement State law only. These provisions and requirements are not required or authorized under the federal CWA; consequently, violations of these provisions and requirements are not subject to the enforcement remedies that are available for NPDES violations.
- T. Notification of Interested Parties.** The Central Coast Water Board has notified the Discharger and interested agencies and persons of its intent to prescribe WDRs for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Details of notification are provided in the Fact Sheet of this Order.
- U. Consideration of Public Comment.** The Central Coast Water Board, in a public meeting, heard and considered all comments pertaining to the discharge. Details of the public hearing are provided in the Fact Sheet of this Order.

### III. DISCHARGE PROHIBITIONS

- A.** Discharge of treated wastewater at a location or in a manner other than as described by this Order at Discharge Point 001 is prohibited.
- B.** The discharge of any waste not specifically regulated by this Order is prohibited.
- C.** Creation of a condition of pollution, contamination, or nuisance, as defined by CWC §13050, is prohibited.
- D.** The overflow or bypass of wastewater from the Discharger's collection, treatment, or disposal facilities and the subsequent discharge of untreated or partially treated wastewater, except as provided for in Attachment D, Standard Provision I. G (Bypass), is prohibited.
- E.** Daily dry weather flow, averaged monthly (the average daily flow in the three driest months of each year) shall not exceed a dry weather monthly average of 0.10 MGD.
- F.** The discharge of radioactive substances is prohibited.

### IV. EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

#### A. Effluent Limitations – Discharge Point 001

##### 1. Final Effluent Limitations

- a. Conventional and Non-Conventional Pollutants.** The Discharger shall maintain compliance with the following effluent limitations at Discharge Point 001 (discharge to

the Salinas Reclamation Canal) with compliance measured at Monitoring Location EFF-001, as described in the attached Monitoring and Reporting Program (MRP).

**Table 6. Effluent Limitations for Conventional and Non-Conventional Pollutants**

Constituent	Units	Effluent Limits	
		Average Monthly	Maximum Daily
BOD <sub>5</sub>	mg/L	60	90
TSS	mg/L	60	90
Settleable Solids	mL/L	---	0.3
Total Dissolved Solids (TDS)	mg/L	1300	1500
Chloride	mg/L	---	250
Sulfate	mg/L	---	600
Boron	mg/L	---	0.5
Sodium	mg/L	---	250
Nitrate (as N)	mg/L	---	10
pH	standard units	7.0 – 8.3 at all times	
Acute Toxicity	Pass/Fail	There shall be no acute toxicity as determined by the survival of test organisms at 100 percent effluent compared to a control using a statistical t-test.	

**b. Dissolved Oxygen.** Dissolved oxygen in treated wastewater discharged at Discharge Point 001 shall not be below 5.0 mg/L.

**c. Toxic Pollutants.** The Discharger shall maintain compliance with the following effluent limitations for toxic pollutants at Discharge Point 001, with compliance measured at Monitoring Location EFF-001, as described in the attached MRP.

**Table 7. Effluent Limitations for Conventional and Non-Conventional Pollutants**

Constituent	Units	Effluent Limits	
		Average Monthly	Maximum Daily
Selenium	µg/L	4.1	8.2
Bis(2-ethylhexyl)phthalate	µg/L	1.8	3.6

**B. Land Discharge Specifications**

This section of the standardized permit template is not applicable.

**C. Reclamation Specifications**

This section of the standardized permit template is not applicable.

**V. RECEIVING WATER LIMITATIONS**

**A. Surface Water Limitations**

Receiving water limitations are based on water quality objectives contained in the Basin Plan and are a required part of this Order. Discharges from the Facility shall not cause the following conditions in the Salinas Reclamation Canal.

1. Waters shall be free of coloration that causes nuisance or adversely affects beneficial uses. Coloration attributable to materials of waste origin shall not be greater than 15 units or 10 percent above natural background color, whichever is greater.
2. Waters shall not contain taste or odor-producing substances in concentrations that impart undesirable tastes or odors to fish flesh or other edible products of aquatic origin, that cause nuisance, or that adversely affect beneficial uses.
3. Waters shall not contain floating material, including solids, liquids, foams, and scum, in concentrations that cause nuisance or adversely affect beneficial uses.
4. Waters shall not contain suspended material in concentrations that causes nuisance or adversely affects beneficial uses.
5. Waters shall not contain settleable material in concentrations that result in deposition of material that causes nuisance or adversely affects beneficial uses.
6. Waters shall not contain oils, greases, waxes, or other similar materials in concentrations that result in a visible film or coating on the surface of the water or on objects in the water, that cause nuisance, or that otherwise adversely affect beneficial uses.
7. Waters shall not contain biostimulatory substances in concentrations that promote aquatic growths to the extent that such growths cause nuisance or adversely affect beneficial uses.
8. The suspended sediment load and suspended sediment discharge rate to surface waters shall not be altered in such a manner as to cause nuisance or adversely affect beneficial uses.
9. Waters shall be free of changes in turbidity that cause nuisance or adversely affect beneficial uses. Increase in turbidity attributable to controllable water quality factors shall not exceed the following limits.
  - a. Where natural turbidity is between 0 and 50 Jackson Turbidity Units (JTU), increases shall not exceed 20 percent.
  - b. Where natural turbidity is between 50 and 100 JTU, increases shall not exceed 10 JTU.
  - c. Where natural turbidity is greater than 100 JTU, increases shall not exceed 10 percent.
10. The pH value shall not be depressed below 7.0 nor raised above 8.3. The change in normal ambient pH levels shall not exceed 0.5 in fresh water.
11. Dissolved oxygen concentrations in receiving waters shall not be reduced below 5.0 mg/L at any time. Median values should not fall below 85 percent saturation as a result of controllable water quality conditions.
12. At no time or place shall the temperature of any water be increased by more than 5°F above the natural receiving water temperature.
13. All waters shall be maintained free of toxic substances in concentrations which are toxic to, or which produce detrimental physiological responses in, human, plant, animal, or aquatic life. Survival of aquatic life in surface waters subjected to a waste discharge or other

controllable water quality conditions shall not be less than that for the same water body in areas unaffected by the waste discharge.

14. The discharge of wastes shall not cause concentrations of un-ionized ammonia (NH<sub>3</sub>) to exceed 0.025 mg/L (as N) in the Salinas Reclamation Canal.
15. No individual pesticide or combination of pesticides shall reach concentrations that adversely affect the beneficial uses of the receiving water. There shall be no increase in pesticide concentrations found in bottom sediments or aquatic life. For waters where existing concentrations are presently nondetectable or where beneficial uses would be impaired by concentrations in excess of nondetectable levels, total identifiable chlorinated hydrocarbon pesticides shall not be present at concentrations detectable within the accuracy of analytical methods as prescribed in *Standard Methods for the Examination of Water and Wastewater*, latest edition, or other equivalent methods approved by the Executive Officer.
16. Waters shall not contain organic substances in concentrations greater than the following.

Methylene Blue Activated Substances	0.2 mg/L
Phenols	0.2 mg/L
PCBs	0.3 µg/L
Phthalate Esters	0.002 µg/L
17. Radionuclides shall not be present in concentrations that are deleterious to human, plant, animal, or aquatic life; or result in the accumulation of radionuclides in the food web to an extent which presents a hazard to human, plant, animal, or aquatic life.

## B. Groundwater Limitations

Activities at and discharges from the Facility shall not cause exceedances or deviation from the following water quality objectives for groundwater established by the Basin Plan.

1. Groundwater shall not contain taste- or odor-producing substances in concentrations that adversely affect beneficial uses.
2. Radionuclides shall not be present in concentrations that are deleterious to human, plant, animal, or aquatic life; or result in the accumulation of radionuclides in the food web to an extent that presents a hazard to human, plant, animal, or aquatic life. For protection of the municipal and domestic supply beneficial use, in no circumstance shall groundwaters contain concentrations of radionuclides in excess of the maximum contaminant levels (MCLs) for radioactivity presented in Table 4 of Title 22 CCR, Division 4, Chapter 15, Article 5.
3. For protection of the municipal and domestic supply beneficial use, the median concentration of coliform organisms in groundwater, over any seven-day period, shall be less than 2.2 organisms per 100 milliliters.
4. For protection of the municipal and domestic supply beneficial use, groundwater shall not contain concentrations of chemical constituents in excess of the primary maximum contaminant levels (MCLs) specified for drinking water in Table 64431-A (Primary MCLs for Inorganic Chemicals) and Table 64444-A (Primary MCLs for Organic Chemicals) of Title 22 CCR, Division 4, Chapter 15. Note that the MCL for nitrate is 10 mg/L expressed as N.

## VI. PROVISIONS

### A. Standard Provisions

The Discharger shall comply with all Standard Provisions included as Attachment D of this Order.

### B. Monitoring and Reporting Program (MRP) Requirements

The Discharger shall comply with the Monitoring and Reporting Program, and future revisions thereto, in Attachment E of this Order. All monitoring shall be conducted according to 40 CFR Part 136, *Guidelines Establishing Test Procedures for Analysis of Pollutants*.

### C. Special Provisions

#### 1. Reopener Provisions

- a. This permit may be reopened and modified in accordance with NPDES regulations at 40 CFR 122 and 124, as necessary, to include additional conditions or limitations based on newly available information or to implement any USEPA approved, new, State water quality objective.

#### 2. Special Studies, Technical Reports and Additional Monitoring Requirements

##### a. Toxicity Reduction Requirements

As indicated in Section V.C of the MRP, accelerated monitoring for toxicity is required upon the detection of acute toxicity. The Discharger shall conduct a Toxicity Reduction Evaluation (TRE) in accordance with the Discharger's TRE Workplan upon consistent detection of toxicity in the effluent during accelerated testing.

A TRE is a study conducted in a step-wise process designed to identify the causative agents of effluent or ambient toxicity, isolate the sources of toxicity, evaluate the effectiveness of toxicity control options, and then confirm the reduction in toxicity. The first steps of the TRE consist of the collection of data relevant to the toxicity, including additional toxicity testing, and an evaluation of Facility operations and maintenance practices, and best management practices. A Toxicity Identification Evaluation (TIE) may be required as part of the TRE, if appropriate. A TIE is a set of procedures to identify the specific chemical(s) responsible for toxicity. These procedures are performed in three phases - characterization, identification, and confirmation using aquatic organism toxicity tests. The TRE shall include all reasonable steps to identify the source of toxicity. The Discharger shall take all reasonable steps to reduce toxicity to the required level once the source of toxicity is identified.

The Discharger shall maintain a Toxicity Reduction Evaluation (TRE) Workplan, which describes steps that the Discharger intends to follow in the event that a toxicity effluent limitation established by this Order is exceeded in the discharge. The workplan shall be prepared in accordance with current technical guidance and reference material, including EPA/600/2-88-070 (for industrial discharges) or EPA/600/2-88/062 (for municipal discharges), and shall include, at a minimum:

- i. Actions that will be taken to investigate/identify the causes/sources of toxicity,

- ii. Actions that will be evaluated to mitigate the impact of the discharge, to correct the non-compliance, and/or to prevent the recurrence of acute toxicity (this list of action steps may be expanded, if a TRE is undertaken), and
- iii. A schedule under which these actions will be implemented.

When monitoring measures toxicity in the effluent above a limitation established by this Order, the Discharger shall resample immediately, if the discharge is continuing, and retest for whole effluent toxicity. Results of an initial failed test and results of subsequent monitoring shall be reported to the Executive Officer (EO) as soon as possible following receipt of monitoring results. The EO will determine whether to initiate enforcement action, whether to require the Discharger to implement a Toxicity Reduction Evaluation, or to implement other measures. The Discharger shall conduct a TRE giving due consideration to guidance provided by the U.S. EPA’s Toxicity Reduction Evaluation Procedures, Phases 1, 2, and 3 (EPA document nos. EPA 600/3-88/034, 600/3-88/035, and 600/3-88/036, respectively). A TRE, if necessary, shall be conducted in accordance with the following schedule.

**Table 8. Toxicity Reduction Evaluation—Schedule**

Action Step	When Required
Take all reasonable measures necessary to immediately reduce toxicity, where the source is known.	Within 24 hours of identification of noncompliance.
Initiate the TRE in accordance to the Workplan.	Within 7 days of notification by the EO
Conduct the TRE following the procedures in the Workplan.	Within the period specified in the Workplan (not to exceed one year, without an approved Workplan)
Submit the results of the TRE, including summary of findings, required corrective action, and all results and data.	Within 60 days of completion of the TRE
Implement corrective actions to meet Permit limits and conditions.	To be determined by the EO

**3. Best Management Practices and Pollution Prevention**

This section of the standardized permit template is not applicable.

**4. Construction, Operation and Maintenance Specifications**

This section of the standardized permit template is not applicable.

**5. Special Provisions for Municipal Facilities (POTWs Only)**

This section of the standardized permit template is not applicable.

**6. Other Special Provisions**

- a. **Discharges of Stormwater.** For the control of stormwater discharged from the site of the vegetable packing, processing and cold storage facility, if applicable, the Discharger shall seek authorization to discharge under and meet the requirements of the State Water Board’s Water Quality Order 97-03-DWQ, NPDES General Permit No.

*CAS000001, Waste Discharge Requirements for Discharges of Storm Water Associated with Industrial Activities Excluding Construction Activities.*

## **7. Compliance Schedules**

This section of the standardized permit template is not applicable.

## **VII. COMPLIANCE DETERMINATION**

Compliance with the effluent limitations contained in section IV of this Order will be determined as specified below.

### **A. General**

Compliance with effluent limitations for priority pollutants shall be determined using sample reporting protocols defined in the MRP and Attachment A of this Order. For purposes of reporting and administrative enforcement by the Central Coast and State Water Boards, the Discharger shall be deemed out of compliance with effluent limitations if the concentration of the priority pollutant in the monitoring sample is greater than the effluent limitation and greater than or equal to the reporting level (RL).

### **B. Multiple Sample Data**

When determining compliance with an AMEL, AWEL, or MDEL for priority pollutants and more than one sample result is available, the Discharger shall compute the arithmetic mean unless the data set contains one or more reported determinations of "Detected, but Not Quantified" (DNQ) or "Not Detected" (ND). In those cases, the Discharger shall compute the median in place of the arithmetic mean in accordance with the following procedure:

1. The data set shall be ranked from low to high, ranking the reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
2. The median value of the data set shall be determined. If the data set has an odd number of data points, then the median is the middle value. If the data set has an even number of data points, then the median is the average of the two values around the middle unless one or both of the points are ND or DNQ, in which case the median value shall be the lower of the two data points where DNQ is lower than a value and ND is lower than DNQ.



## **ATTACHMENT A – DEFINITIONS**

### **Arithmetic Mean ( $\mu$ )**

Also called the average, is the sum of measured values divided by the number of samples. For ambient water concentrations, the arithmetic mean is calculated as follows:

$$\text{Arithmetic mean} = \mu = \Sigma x / n \quad \text{where: } \Sigma x \text{ is the sum of the measured ambient water concentrations, and } n \text{ is the number of samples.}$$

### **Average Monthly Effluent Limitation (AMEL)**

The highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

### **Average Weekly Effluent Limitation (AWEL)**

The highest allowable average of daily discharges over a calendar week (Sunday through Saturday), calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

### **Bioaccumulative**

Those substances taken up by an organism from its surrounding medium through gill membranes, epithelial tissue, or from food and subsequently concentrated and retained in the body of the organism.

### **Carcinogenic**

Pollutants are substances that are known to cause cancer in living organisms.

### **Coefficient of Variation (CV)**

CV is a measure of the data variability and is calculated as the estimated standard deviation divided by the arithmetic mean of the observed values.

### **Daily Discharge**

Daily Discharge is defined as either: (1) the total mass of the constituent discharged over the calendar day (12:00 am through 11:59 pm) or any 24-hour period that reasonably represents a calendar day for purposes of sampling (as specified in the permit), for a constituent with limitations expressed in units of mass or; (2) the unweighted arithmetic mean measurement of the constituent over the day for a constituent with limitations expressed in other units of measurement (e.g., concentration).

The daily discharge may be determined by the analytical results of a composite sample taken over the course of one day (a calendar day or other 24-hour period defined as a day) or by the arithmetic mean of analytical results from one or more grab samples taken over the course of the day.

For composite sampling, if 1 day is defined as a 24-hour period other than a calendar day, the analytical result for the 24-hour period will be considered as the result for the calendar day in which the 24-hour period ends.

### **Detected, but Not Quantified (DNQ)**

DNQ are those sample results less than the RL, but greater than or equal to the laboratory's MDL.

### **Dilution Credit**

Dilution Credit is the amount of dilution granted to a discharge in the calculation of a water quality-based effluent limitation, based on the allowance of a specified mixing zone. It is calculated from the

dilution ratio or determined through conducting a mixing zone study or modeling of the discharge and receiving water.

### **Effluent Concentration Allowance (ECA)**

ECA is a value derived from the water quality criterion/objective, dilution credit, and ambient background concentration that is used, in conjunction with the coefficient of variation for the effluent monitoring data, to calculate a long-term average (LTA) discharge concentration. The ECA has the same meaning as waste load allocation (WLA) as used in USEPA guidance (Technical Support Document For Water Quality-based Toxics Control, March 1991, second printing, EPA/505/2-90-001).

### **Enclosed Bays**

Enclosed Bays means indentations along the coast that enclose an area of oceanic water within distinct headlands or harbor works. Enclosed bays include all bays where the narrowest distance between the headlands or outermost harbor works is less than 75 percent of the greatest dimension of the enclosed portion of the bay. Enclosed bays include, but are not limited to, Humboldt Bay, Bodega Harbor, Tomales Bay, Drake's Estero, San Francisco Bay, Morro Bay, Los Angeles-Long Beach Harbor, Upper and Lower Newport Bay, Mission Bay, and San Diego Bay. Enclosed bays do not include inland surface waters or ocean waters.

### **Estimated Chemical Concentration**

The estimated chemical concentration that results from the confirmed detection of the substance by the analytical method below the ML value.

### **Estuaries**

Estuaries means waters, including coastal lagoons, located at the mouths of streams that serve as areas of mixing for fresh and ocean waters. Coastal lagoons and mouths of streams that are temporarily separated from the ocean by sandbars shall be considered estuaries. Estuarine waters shall be considered to extend from a bay or the open ocean to a point upstream where there is no significant mixing of fresh water and seawater. Estuarine waters included, but are not limited to, the Sacramento-San Joaquin Delta, as defined in Water Code section 12220, Suisun Bay, Carquinez Strait downstream to the Carquinez Bridge, and appropriate areas of the Smith, Mad, Eel, Noyo, Russian, Klamath, San Diego, and Otay rivers. Estuaries do not include inland surface waters or ocean waters.

### **Inland Surface Waters**

All surface waters of the State that do not include the ocean, enclosed bays, or estuaries.

### **Instantaneous Maximum Effluent Limitation**

The highest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous maximum limitation).

### **Instantaneous Minimum Effluent Limitation**

The lowest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous minimum limitation).

### **Maximum Daily Effluent Limitation (MDEL)**

The highest allowable daily discharge of a pollutant, over a calendar day (or 24-hour period). For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the arithmetic mean measurement of the pollutant over the day.

### **Median**

The middle measurement in a set of data. The median of a set of data is found by first arranging the measurements in order of magnitude (either increasing or decreasing order). If the number of measurements ( $n$ ) is odd, then the median =  $X_{(n+1)/2}$ . If  $n$  is even, then the median =  $(X_{n/2} + X_{(n/2)+1})/2$  (i.e., the midpoint between the  $n/2$  and  $n/2+1$ ).

### **Method Detection Limit (MDL)**

MDL is the minimum concentration of a substance that can be measured and reported with 99 percent confidence that the analyte concentration is greater than zero, as defined in title 40 of the Code of Federal Regulations, Part 136, Attachment B, revised as of July 3, 1999.

### **Minimum Level (ML)**

ML is the concentration at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed.

### **Mixing Zone**

Mixing Zone is a limited volume of receiving water that is allocated for mixing with a wastewater discharge where water quality criteria can be exceeded without causing adverse effects to the overall water body.

### **Not Detected (ND)**

Sample results which are less than the laboratory's MDL.

### **Ocean Waters**

The territorial marine waters of the State as defined by California law to the extent these waters are outside of enclosed bays, estuaries, and coastal lagoons. Discharges to ocean waters are regulated in accordance with the State Water Board's California Ocean Plan.

### **Persistent Pollutants**

Persistent pollutants are substances for which degradation or decomposition in the environment is nonexistent or very slow.

### **Pollutant Minimization Program (PMP)**

PMP means waste minimization and pollution prevention actions that include, but are not limited to, product substitution, waste stream recycling, alternative waste management methods, and education of the public and businesses. The goal of the PMP shall be to reduce all potential sources of a priority pollutant(s) through pollutant minimization (control) strategies, including pollution prevention measures as appropriate, to maintain the effluent concentration at or below the water quality-based effluent limitation. Pollution prevention measures may be particularly appropriate for persistent bioaccumulative priority pollutants where there is evidence that beneficial uses are being impacted. The Central Coast Water Board may consider cost effectiveness when establishing the requirements of a PMP. The completion and implementation of a Pollution Prevention Plan, if required pursuant to CWC §13263.3(d), shall be considered to fulfill the PMP requirements.

### **Pollution Prevention**

Pollution Prevention means any action that causes a net reduction in the use or generation of a hazardous substance or other pollutant that is discharged into water and includes, but is not limited to, input change, operational improvement, production process change, and product reformulation (as defined in CWC §13263.3). Pollution prevention does not include actions that merely shift a pollutant in wastewater from one environmental medium to another environmental medium, unless clear

environmental benefits of such an approach are identified to the satisfaction of the State or Central Coast Water Board.

### **Reporting Level (RL)**

RL is the ML (and its associated analytical method) chosen by the Discharger for reporting and compliance determination from the MLs included in this Order. The MLs included in this Order correspond to approved analytical methods for reporting a sample result that are selected by the Central Coast Water Board either from Appendix 4 of the SIP in accordance with section 2.4.2 of the SIP or established in accordance with section 2.4.3 of the SIP. The ML is based on the proper application of method-based analytical procedures for sample preparation and the absence of any matrix interferences. Other factors may be applied to the ML depending on the specific sample preparation steps employed. For example, the treatment typically applied in cases where there are matrix-effects is to dilute the sample or sample aliquot by a factor of ten. In such cases, this additional factor must be applied to the ML in the computation of the RL.

### **Source of Drinking Water**

Any water designated as municipal or domestic supply (MUN) in a Central Coast Water Board Basin Plan.

### **Standard Deviation ( $\sigma$ )**

Standard Deviation is a measure of variability that is calculated as follows:

$$\sigma = (\sum[(x - \mu)^2]/(n - 1))^{0.5}$$

where:

x is the observed value;


$\mu$  is the arithmetic mean of the observed values; and

n is the number of samples.


### **Toxicity Reduction Evaluation (TRE)**

TRE is a study conducted in a step-wise process designed to identify the causative agents of effluent or ambient toxicity, isolate the sources of toxicity, evaluate the effectiveness of toxicity control options, and then confirm the reduction in toxicity. The first steps of the TRE consist of the collection of data relevant to the toxicity, including additional toxicity testing, and an evaluation of Facility operations and maintenance practices, and best management practices. A Toxicity Identification Evaluation (TIE) may be required as part of the TRE, if appropriate. (A TIE is a set of procedures to identify the specific chemical(s) responsible for toxicity. These procedures are performed in three phases (characterization, identification, and confirmation) using aquatic organism toxicity tests.)

**ATTACHMENT B – MAP**



**ATTACHMENT C – FLOW SCHEMATIC**



## **ATTACHMENT D – STANDARD PROVISIONS**

### **I. FEDERAL STANDARD PROVISIONS – PERMIT COMPLIANCE**

#### **A. Duty to Comply**

1. The Discharger must comply with all of the conditions of this Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code (CWC) and is grounds for enforcement action, for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. (40 CFR §122.41(a).)
2. The Discharger shall comply with effluent standards or prohibitions established under CWA §307(a) for toxic pollutants and with standards for sewage sludge use or disposal established under CWA §405(d) within the time provided in the regulations that establish these standards or prohibitions, even if this Order has not yet been modified to incorporate the requirement. (40 CFR §122.41(a)(1).)

#### **B. Need to Halt or Reduce Activity Not a Defense**

It shall not be a defense for a Discharger in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Order. (40 CFR §122.41(c).)

#### **C. Duty to Mitigate**

The Discharger shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this Order that has a reasonable likelihood of adversely affecting human health or the environment. (40 CFR §122.41(d).)

#### **D. Proper Operation and Maintenance**

The Discharger shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Discharger to achieve compliance with the conditions of this Order. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems that are installed by a Discharger only when necessary to achieve compliance with the conditions of this Order. (40 CFR §122.41(e).)

#### **E. Property Rights**

1. This Order does not convey any property rights of any sort or any exclusive privileges. (40 CFR §122.41(g).)
2. The issuance of this Order does not authorize any injury to persons or property or invasion of other private rights, or any infringement of State or local law or regulations. (40 CFR §122.5(c).)

#### **F. Inspection and Entry**

The Discharger shall allow the Central Coast Water Board, State Water Board, USEPA, and/or their authorized representatives (including an authorized contractor acting as their

representative), upon the presentation of credentials and other documents, as may be required by law, to (40 CFR § 122.41(i); CWC §13383):

1. Enter upon the Discharger's premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this Order (40 CFR §122.41(i)(1));
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Order (40 CFR §122.41(i)(2));
3. Inspect and photograph, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order (40 CFR §122.41(i)(3)); and
4. Sample or monitor, at reasonable times, for the purposes of assuring Order compliance or as otherwise authorized by the CWA or the CWC, any substances or parameters at any location. (40 CFR §122.41(i)(4).)

## **G. Bypass**

### **1. Definitions**

- a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility. (40 CFR §122.41(m)(1)(i).)
- b. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities, which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production. (40CFR § 122.41(m)(1)(ii).)

2. Bypass not exceeding limitations. The Discharger may allow any bypass to occur which does not cause exceedances of effluent limitations, but only if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions listed in Standard Provisions – Permit Compliance I.G.3, I.G.4, and I.G.5 below. (40 CFR §122.41(m)(2).)

3. Prohibition of bypass. Bypass is prohibited, and the Central Coast Water Board may take enforcement action against a Discharger for bypass, unless (40 CFR §122.41(m)(4)(i)):

- a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage (40 CFR §122.41(m)(4)(i)(A));
- b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance (40 CFR §122.41(m)(4)(i)(B)); and
- c. The Discharger submitted notice to the Central Coast Water Board as required under Standard Provisions – Permit Compliance I.G.5 below. (40 CFR §122.41(m)(4)(i)(C).)



4. The Central Coast Water Board may approve an anticipated bypass, after considering its adverse effects, if the Central Coast Water Board determines that it will meet the three conditions listed in Standard Provisions – Permit Compliance I.G.3 above. (40 CFR §122.41(m)(4)(ii).)
5. Notice
  - a. Anticipated bypass. If the Discharger knows in advance of the need for a bypass, it shall submit a notice, if possible at least 10 days before the date of the bypass. (40 CFR §122.41(m)(3)(i).)
  - b. Unanticipated bypass. The Discharger shall submit notice of an unanticipated bypass as required in Standard Provisions - Reporting V.E below (24-hour notice). (40 CFR §122.41(m)(3)(ii).)

#### H. Upset

Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the Discharger. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation. (40 CFR §122.41(n)(1).)

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of Standard Provisions – Permit Compliance I.H.2 below are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review. (40 CFR §122.41(n)(2).)
2. Conditions necessary for a demonstration of upset. A Discharger who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that (40 CFR §122.41(n)(3)):
  - a. An upset occurred and that the Discharger can identify the cause(s) of the upset (40 CFR §122.41(n)(3)(i));
  - b. The permitted facility was, at the time, being properly operated (40 CFR §122.41(n)(3)(ii));
  - c. The Discharger submitted notice of the upset as required in Standard Provisions – Reporting V.E.2.b below (24-hour notice) (40 CFR §122.41(n)(3)(iii)); and
  - d. The Discharger complied with any remedial measures required under Standard Provisions – Permit Compliance I.C above. (40 CFR §122.41(n)(3)(iv).)
3. Burden of proof. In any enforcement proceeding, the Discharger seeking to establish the occurrence of an upset has the burden of proof. (40 CFR §122.41(n)(4).)

## **II. FEDERAL STANDARD PROVISIONS – PERMIT ACTION**

### **A. General**

This Order may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Discharger for modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any Order condition. (40 CFR §122.41(f).)

### **B. Duty to Reapply**

If the Discharger wishes to continue an activity regulated by this Order after the expiration date of this Order, the Discharger must apply for and obtain a new permit. (40 CFR §122.41(b).)

### **C. Transfers**

This Order is not transferable to any person except after notice to the Central Coast Water Board. The Central Coast Water Board may require modification or revocation and reissuance of the Order to change the name of the Discharger and incorporate such other requirements as may be necessary under the CWA and the CWC. (40 CFR § 122.41(l)(3); §122.61.)

## **III. FEDERAL STANDARD PROVISIONS – MONITORING**

**A.** Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. (40 CFR §122.41(j)(1).)

**B.** Monitoring results must be conducted according to test procedures under Part 136 or, in the case of sludge use or disposal, approved under Part 136 unless otherwise specified in Part 503 unless other test procedures have been specified in this Order. (40 CFR §122.41(j)(4); §122.44(i)(1)(iv).)

## **IV. FEDERAL STANDARD PROVISIONS – RECORDS**

**A.** Except for records of monitoring information required by this Order related to the Discharger's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by Part 503), the Discharger shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this Order, and records of all data used to complete the application for this Order, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Central Coast Water Board Executive Officer at any time. (40 CFR 122.41(j)(2).)

### **B. Records of monitoring information shall include:**

1. The date, exact place, and time of sampling or measurements (40 CFR §122.41(j)(3)(i));
2. The individual(s) who performed the sampling or measurements (40 CFR §122.41(j)(3)(ii));
3. The date(s) analyses were performed (40 CFR §122.41(j)(3)(iii));
4. The individual(s) who performed the analyses (40 CFR §122.41(j)(3)(iv));

5. The analytical techniques or methods used (40 CFR §122.41(j)(3)(v)); and
6. The results of such analyses. (40 CFR §122.41(j)(3)(vi).)

**C. Claims of confidentiality for the following information will be denied (40 CFR § 122.7(b)):**

1. The name and address of any permit applicant or Discharger (40 CFR §122.7(b)(1)); and
2. Permit applications and attachments, permits and effluent data. (40 CFR §122.7(b)(2).)

**V. FEDERAL STANDARD PROVISIONS – REPORTING**

**A. Duty to Provide Information**

The Discharger shall furnish to the Central Coast Water Board, State Water Board, or USEPA within a reasonable time, any information which the Central Coast Water Board, State Water Board, or USEPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this Order or to determine compliance with this Order. Upon request, the Discharger shall also furnish to the Central Coast Water Board, State Water Board, or USEPA copies of records required to be kept by this Order. (40 CFR § 122.41(h); CWC §13267.)

**B. Signatory and Certification Requirements**

1. All applications, reports, or information submitted to the Central Coast Water Board, State Water Board, and/or USEPA shall be signed and certified in accordance with Standard Provisions – Reporting V.B.2, V.B.3, V.B.4, and V.B.5 below. (40 CFR §122.41(k).)
2. All permit applications shall be signed by either a principal executive officer or ranking elected official. For purposes of this provision, a principal executive officer of a federal agency includes: (i) the chief executive officer of the agency, or (ii) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of USEPA). (40 CFR §122.22(a)(3).)
3. All reports required by this Order and other information requested by the Central Coast Water Board, State Water Board, or USEPA shall be signed by a person described in Standard Provisions – Reporting V.B.2 above, or by a duly authorized representative of that person. A person is a duly authorized representative only if:
  - a. The authorization is made in writing by a person described in Standard Provisions – Reporting V.B.2 above (40 CFR §122.22(b)(1));
  - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.) (40 CFR §122.22(b)(2)); and
  - c. The written authorization is submitted to the Central Coast Water Board and State Water Board. (40 CFR §122.22(b)(3).)

4. If an authorization under Standard Provisions – Reporting V.B.3 above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Standard Provisions – Reporting V.B.3 above must be submitted to the Central Coast Water Board and State Water Board prior to or together with any reports, information, or applications, to be signed by an authorized representative. (40 CFR §122.22(c).)
5. Any person signing a document under Standard Provisions – Reporting V.B.2 or V.B.3 above shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.” (40 CFR §122.22(d).)

### **C. Monitoring Reports**

1. Monitoring results shall be reported at the intervals specified in the Monitoring and Reporting Program (Attachment E) in this Order. (40 CFR §122.22(l)(4).)
2. Monitoring results must be reported on a Discharge Monitoring Report (DMR) form or forms provided or specified by the Central Coast Water Board or State Water Board for reporting results of monitoring of sludge use or disposal practices. (40 CFR §122.41(l)(4)(i).)
3. If the Discharger monitors any pollutant more frequently than required by this Order using test procedures approved under Part 136 or, in the case of sludge use or disposal, approved under Part 136 unless otherwise specified in Part 503, or as specified in this Order, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Central Coast Water Board. (40 CFR §122.41(l)(4)(ii).)
4. Calculations for all limitations, which require averaging of measurements, shall utilize an arithmetic mean unless otherwise specified in this Order. (40 CFR §122.41(l)(4)(iii).)

### **D. Compliance Schedules**

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this Order, shall be submitted no later than 14 days following each schedule date. (40 CFR §122.41(l)(5).)

### **E. Twenty-Four Hour Reporting**

1. The Discharger shall report any noncompliance that may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Discharger becomes aware of the circumstances. A written submission shall also be provided within five (5) days of the time the Discharger becomes aware of the circumstances. The written submission shall contain a description of the noncompliance

and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance. (40 CFR §122.41(l)(6)(i).)

2. The following shall be included as information that must be reported within 24 hours under this paragraph (40 CFR §122.41(l)(6)(ii)):
  - a. Any unanticipated bypass that exceeds any effluent limitation in this Order. (40 CFR §122.41(l)(6)(ii)(A).)
  - b. Any upset that exceeds any effluent limitation in this Order. (40 CFR §122.41(l)(6)(ii)(B).)
3. The Central Coast Water Board may waive the above-required written report under this provision on a case-by-case basis if an oral report has been received within 24 hours. (40 CFR §122.41(l)(6)(iii).)

#### **F. Planned Changes**

The Discharger shall give notice to the Central Coast Water Board as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required under this provision only when (40 CFR §122.41(l)(1)):

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in section 122.29(b) (40 CFR §122.41(l)(1)(i)); or
2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are subject neither to effluent limitations in this Order nor to notification requirements under section 122.42(a)(1) (see Additional Provisions—Notification Levels VII.A.1). (40 CFR §122.41(l)(1)(ii).)
3. The alteration or addition results in a significant change in the Discharger's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan. (40 CFR §122.41(l)(1)(iii).)

#### **G. Anticipated Noncompliance**

The Discharger shall give advance notice to the Central Coast Water Board or State Water Board of any planned changes in the permitted facility or activity that may result in noncompliance with General Order requirements. (40 CFR §122.41(l)(2).)

#### **H. Other Noncompliance**

The Discharger shall report all instances of noncompliance not reported under Standard Provisions – Reporting V.C, V.D, and V.E above at the time monitoring reports are submitted. The reports shall contain the information listed in Standard Provision – Reporting V.E above. (40 CFR §122.41(l)(7).)

## **I. Other Information**

When the Discharger becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Central Coast Water Board, State Water Board, or USEPA, the Discharger shall promptly submit such facts or information. (40 CFR §122.41(l)(8).)

## **VI. FEDERAL STANDARD PROVISIONS – ENFORCEMENT**

- A.** The Central Coast Water Board is authorized to enforce the terms of this permit under several provisions of the CWC, including, but not limited to, §13385, §13386, and §13387

## **VII. FEDERAL ADDITIONAL PROVISIONS – NOTIFICATION LEVELS**

### **A. Publicly Owned Treatment Works (POTWs)**

All POTWs shall provide adequate notice to the Central Coast Water Board of the following (40 CFR §122.42(b)):

- 1.** Any new introduction of pollutants into the POTW from an indirect discharger that would be subject to sections 301 or 306 of the CWA if it were directly discharging those pollutants (40 CFR §122.42(b)(1)); and
- 2.** Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of adoption of the Order. (40 CFR §122.42(b)(2).)
- 3.** Adequate notice shall include information on the quality and quantity of effluent introduced into the POTW as well as any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW. (40 CFR §122.42(b)(3).)

## **ATTACHMENT D-1 - CENTRAL COAST WATER BOARD STANDARD PROVISIONS (DECEMBER 2012)**

### **I. Central Coast General Permit Conditions**

#### **A. Central Coast Standard Provisions – Prohibitions**

1. Introduction of "incompatible wastes" to the treatment system is prohibited.
2. Discharge of high-level radiological waste and of radiological, chemical, and biological warfare agents is prohibited.
3. Discharge of "toxic pollutants" in violation of effluent standards and prohibitions established under §307(a) of the Clean Water Act (CWA) is prohibited.
4. Discharge of sludge, sludge digester or thickener supernatant, and sludge drying bed leachate to drainageways, surface waters, or the ocean is prohibited.
5. Introduction of pollutants into the collection, treatment, or disposal system by an "indirect discharger" that:
  - a. Inhibit or disrupt the treatment process, system operation, or the eventual use or disposal of sludge; or,
  - b. Flow through the system to the receiving water untreated; and,
  - c. Cause or "significantly contribute" to a violation of any requirement of this Order, is prohibited.
6. Introduction of "pollutant free" wastewater to the collection, treatment, and disposal system in amounts that threaten compliance with this order is prohibited.

#### **B. Central Coast Standard Provisions – Provisions**

1. Collection, treatment, and discharge of waste shall not create a nuisance or pollution, as defined by California Water Code (CWC) §13050.
2. All facilities used for transport or treatment of wastes shall be adequately protected from inundation and washout as the result of a 100-year frequency flood.
3. Operation of collection, treatment, and disposal systems shall be in a manner that precludes public contact with wastewater.
4. Collected screenings, sludges, and other solids removed from liquid wastes shall be disposed in a manner approved by the Executive Officer.
5. Wastewater treatment plants shall be supervised and operated by persons possessing certificates of appropriate grade pursuant to Title 23 of the California Code of Regulations.
6. After notice and opportunity for a hearing, this order may be terminated for cause, including, but not limited to:
  - a. violation of any term or condition contained in this order;

- b. obtaining this order by misrepresentation, or by failure to disclose fully all relevant facts;
  - c. a change in any condition or endangerment to human health or environment that requires a temporary or permanent reduction or elimination of the authorized discharge; and,
  - d. a substantial change in character, location, or volume of the discharge.
7. Provisions of this permit are severable. If any provision of the permit is found invalid, the remainder of the permit shall not be affected.
8. After notice and opportunity for hearing, this order may be modified or revoked and reissued for cause, including:
  - a. Promulgation of a new or revised effluent standard or limitation;
  - b. A material change in character, location, or volume of the discharge;
  - c. Access to new information that affects the terms of the permit, including applicable schedules;
  - d. Correction of technical mistakes or mistaken interpretations of law; and,
  - e. Other causes set forth under Sub-part D of 40 CFR Part 122.
9. Safeguards shall be provided to ensure maximal compliance with all terms and conditions of this permit. Safeguards shall include preventative and contingency plans and may also include alternative power sources, stand-by generators, retention capacity, operating procedures, or other precautions. Preventative and contingency plans for controlling and minimizing the affect of accidental discharges shall:
  - a. identify possible situations that could cause "upset", "overflow" or "bypass", or other noncompliance. (Loading and storage areas, power outage, waste treatment unit outage, and failure of process equipment, tanks and pipes should be considered.)
  - b. evaluate the effectiveness of present facilities and procedures and describe procedures and steps to minimize or correct any adverse environmental impact resulting from noncompliance with the permit.
10. Physical Facilities shall be designed and constructed according to accepted engineering practice and shall be capable of full compliance with this order when properly operated and maintained. Proper operation and maintenance shall be described in an Operation and Maintenance Manual. Facilities shall be accessible during the wet-weather season.
11. The discharger shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) that are installed or used by the discharger to achieve compliance with the conditions of this order. Electrical and mechanical equipment shall be maintained in accordance with appropriate practices and standards, such as NFPA 70B, *Recommended Practice for Electrical Equipment Maintenance*; NFPA 70E, *Standard for Electrical Safety in the Workplace*; ANSI/NETA MTS *Standard for Maintenance: Testing Specifications for Electrical Power Equipment and Systems*, or procedures established by insurance companies or other industry resources.



12. If the discharger's facilities are equipped with SCADA or other systems that implement wireless, remote operation, the discharger should implement appropriate safeguards against unauthorized access to the wireless systems. Standards such as NIST SP 800-53, *Recommended Security Controls for Federal Information Systems*, can provide guidance.
13. Production and use of recycled water is subject to the approval of the Central Coast Board. Production and use of recycled water shall be in conformance with reclamation criteria established in Chapter 3, Title 22, of the California Code of Regulations and Chapter 7, Division 7, of the CWC. An engineering report pursuant to section 60323, Title 22, of the California Code of Regulations is required and a waiver or water reclamation requirements from the Central Coast Board is required before recycled water is supplied for any use, or to any user, not specifically identified and approved either in this Order or another order issued by this Board.

### **C. Central Coast Standard Provisions – General Monitoring Requirements**

1. If results of monitoring a pollutant appear to violate effluent limitations based on a weekly, monthly, 30-day, or six-month period, but compliance or non-compliance cannot be validated because sampling is too infrequent, the frequency of sampling shall be increased to validate the test within the next monitoring period. The increased frequency shall be maintained until the Executive Officer agrees the original monitoring frequency may be resumed.

For example, if copper is monitored annually and results exceed the six-month median numerical effluent limitation in the permit, monitoring of copper must be increased to a frequency of at least once every two months (Central Coast Standard Provisions – Definitions I.G.13.). If suspended solids are monitored weekly and results exceed the weekly average numerical limit in the permit, monitoring of suspended solids must be increased to at least four (4) samples every week (Central Coast Standard Provisions – Definitions I.G.14.).

2. Water quality analyses performed in order to monitor compliance with this permit shall be by a laboratory certified by the State Department of Public Health (DPH) for the constituent(s) being analyzed. Bioassay(s) performed in order to monitor compliance with this permit shall be in accord with guidelines approved by the State Water Resources Control Board (State Water Board) and the State Department of Fish and Game.
3. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. Samples shall be taken during periods of peak loading conditions. Influent samples shall be samples collected from the combined flows of all incoming wastes, excluding recycled wastes. Effluent samples shall be samples collected downstream of the last treatment unit and tributary flow and upstream of any mixing with receiving waters.
4. All monitoring instruments and devices used by the discharger to fulfill the prescribed monitoring program shall be properly maintained and calibrated as necessary to ensure their continued accuracy.

### **E. Central Coast Standard Provisions – General Reporting Requirements**

1. Reports of marine monitoring surveys conducted to meet receiving water monitoring requirements of the Monitoring and Reporting Program shall include at least the following information:

- a. A description of climatic and receiving water characteristics at the time of sampling (weather observations, floating debris, discoloration, wind speed and direction, swell or wave action, time of sampling, tide height, etc.).
  - b. A description of sampling stations, including differences unique to each station (e.g., station location, grain size, rocks, shell litter, calcareous worm tubes, evident life, etc.).
  - c. A description of the sampling procedures and preservation sequence used in the survey.
  - d. A description of the exact method used for laboratory analysis. In general, analysis shall be conducted according to Central Coast Standard Provisions – C.1 above, and Federal Standard Provision – Monitoring III.B. However, variations in procedure are acceptable to accommodate the special requirements of sediment analysis. All such variations must be reported with the test results.
  - e. A brief discussion of the results of the survey. The discussion shall compare data from the control station with data from the outfall stations. All tabulations and computations shall be explained.
2. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule shall be submitted within 14 days following each scheduled date unless otherwise specified within the permit. If reporting noncompliance, the report shall include a description of the reason, a description and schedule of tasks necessary to achieve compliance, and an estimated date for achieving full compliance. A second report shall be submitted within 14 days of full compliance.
  3. The “Discharger” shall file a report of waste discharge at least 220 days before making any material change or proposed change in the character, location, or plume of the discharge.
  4. Within 120 days after the discharger discovers, or is notified by the Central Coast Water Board, that monthly average daily flow will or may reach design capacity of waste treatment and/or disposal facilities within four (4) years, the discharger shall file a written report with the Central Coast Water Board. The report shall include:
    - a. the best estimate of when the monthly average daily dry weather flow rate will equal or exceed design capacity; and,
    - b. a schedule for studies, design, and other steps needed to provide additional capacity for waste treatment and/or disposal facilities before the waste flow rate equals the capacity of present units.

In addition to complying with Federal Standard Provision – Reporting V.B., the required technical report shall be prepared with public participation and reviewed, approved and jointly submitted by all planning and building departments having jurisdiction in the area served by the waste collection, treatment, or disposal facilities.

5. All “Dischargers” shall submit reports electronically to the:

California Regional Water Quality Control Board  
Central Coast Region  
[centralcoast@waterboards.ca.gov](mailto:centralcoast@waterboards.ca.gov)  
895 Aerovista Place, Suite 101  
San Luis Obispo, CA 93401-7906

In addition, "Dischargers" with designated major discharges shall submit a copy of each document to:

Regional Administrator  
USEPA, Region 9  
Attention: CWA Standards and Permits Office (WTR-5)  
75 Hawthorne Street  
San Francisco, California 94105

6. Transfer of control or ownership of a waste discharge facility must be preceded by a notice to the Central Coast Water Board at least 30 days in advance of the proposed transfer date. The notice must include a written agreement between the existing "Discharger" and proposed "Discharger" containing specific date for transfer of responsibility, coverage, and liability between them. Whether a permit may be transferred without modification or revocation and reissuance is at the discretion of the Board. If permit modification or revocation and reissuance is necessary, transfer may be delayed 180 days after the Central Coast Water Board's receipt of a complete permit application. Please also see Federal Standard Provision – Permit Action II.C.
7. Except for data determined to be confidential under CWA §308 (excludes effluent data and permit applications), all reports prepared in accordance with this permit shall be available for public inspection at the office of the Central Coast Water Board or Regional Administrator of USEPA. Please also see Federal Standard Provision – Records IV.C.
8. By January 30 of each year, the discharger shall submit an annual report to the Central Coast Water Board. The report shall contain the following:
  - a) Both tabular and graphical summaries of the monitoring data obtained during the previous year.
  - b) A discussion of the previous year's compliance record and corrective actions taken, or which may be needed, to bring the discharger into full compliance.
  - c) An evaluation of wastewater flows with projected flow rate increases over time and the estimated date when flows will reach facility capacity.
  - d) A discussion of operator certification and a list of current operating personnel and their grades of certification.
  - e) The date of the facility's Operation and Maintenance Manual (including contingency plans as described in Provision B.9), the date the manual was last reviewed, and whether the manual is complete and valid for the current facility.
  - f) A discussion of the laboratories used by the discharger to monitor compliance with effluent limits and a summary of performance relative to Section C, General Monitoring Requirements.
  - g) If the facility treats industrial or domestic wastewater and there is no provision for periodic sludge monitoring in the Monitoring and Reporting Program, the report shall include a summary of sludge quantities, analyses of its chemical and moisture content, and its ultimate destination.
  - h) If appropriate, the report shall also evaluate the effectiveness of the local source control or pretreatment program using the State Water Resources Control Board's "Guidelines for Determining the Effectiveness of Local Pretreatment Program."
  - i)

## **F. Central Coast Standard Provisions – General Pretreatment Provisions**

1. Discharge of pollutants by "indirect dischargers" in specific industrial sub-categories (appendix C, 40 CFR Part 403), where categorical pretreatment standards have been established, or are to be established, (according to 40 CFR Chapter 1, Subchapter N), shall comply with the appropriate pretreatment standards by the date specified therein or; if a new indirect discharger, upon commencement of discharge.

## **G. Central Coast Standard Provisions – Enforcement**

1. Any person failing to file a report of waste discharge or other report as required by this permit shall be subject to a civil penalty not to exceed \$5,000 per day.
2. Upon reduction, loss, or failure of the treatment facility, the "Discharger" shall, to the extent necessary to maintain compliance with this permit, control production or all discharges, or both, until the facility is restored or an alternative method of treatment is provided.

## **H. Central Coast Standard Provisions – Definitions**

### **(Not otherwise included in Attachment A to this Order)**

1. A "composite sample" is a combination of no fewer than eight (8) individual samples obtained at equal time intervals (usually hourly) over the specified sampling (composite) period. The volume of each individual sample is proportional to the flow rate at the time of sampling. The period shall be specified in the Monitoring and Reporting Program ordered by the Executive Officer.
2. "Daily Maximum" limit means the maximum acceptable concentration or mass emission rate of a pollutant measured during a calendar day or during any 24-hour period reasonably representative of the calendar day for purposes of sampling. It is normally compared with results based on "composite samples" except for ammonia, total chlorine, phenolic compounds, and toxicity concentration. For all exceptions, comparisons will be made with results from a "grab sample".
3. "Discharger", as used herein, means, as appropriate: (1) the Discharger, (2) the local sewerage entity (when the collection system is not owned and operated by the Discharger), or (3) "indirect discharger" (where "Discharger" appears in the same paragraph as "indirect discharger", it refers to the discharger.)
4. "Duly Authorized Representative" is one where:
  - a. the authorization is made in writing by a person described in the signatory paragraph of Federal Standard Provision V.B.;
  - b. the authorization specifies either an individual or the occupant of a position having either responsibility for the overall operation of the regulated facility, such as the plant manager, or overall responsibility for environmental matters of the company; and,
  - c. the written authorization was submitted to the Central Coast Water Board.
5. A "grab sample" is defined as any individual sample collected in less than 15 minutes. "Grab samples" shall be collected during peak loading conditions, which may or may not be during hydraulic peaks. It is used primarily in determining compliance with the daily maximum limits

identified in Central Coast Standard Provision – Provision G.2. and instantaneous maximum limits.

6. "Hazardous substance" means any substance designated under 40 CFR Part 116 pursuant to Section 311 of the Clean Water Act.
7. "Incompatible wastes" are:
  - a. Wastes which create a fire or explosion hazard in the treatment works;
  - b. Wastes which will cause corrosive structural damage to treatment works or wastes with a pH lower than 5.0 unless the works is specifically designed to accommodate such wastes;
  - c. Solid or viscous wastes in amounts which cause obstruction to flow in sewers, or which cause other interference with proper operation of treatment works;
  - d. Any waste, including oxygen demanding pollutants (BOD, etc), released in such volume or strength as to cause inhibition or disruption in the treatment works and subsequent treatment process upset and loss of treatment efficiency; and,
  - e. Heat in amounts that inhibit or disrupt biological activity in the treatment works or that raise influent temperatures above 40°C (104°F) unless the treatment works is designed to accommodate such heat.
8. "Indirect Discharger" means a non-domestic discharger introducing pollutants into a publicly owned treatment and disposal system.
9. "Log Mean" is the geometric mean. Used for determining compliance of fecal or total coliform populations, it is calculated with the following equation:

$$\text{Log Mean} = (C_1 \times C_2 \times \dots \times C_n)^{1/n},$$

in which "n" is the number of days samples were analyzed during the period and any "C" is the concentration of bacteria (MPN/100 ml) found on each day of sampling. "n" should be five or more.

10. "Mass emission rate" is a daily rate defined by the following equations:

$$\text{mass emission rate (lbs/day)} = 8.34 \times Q \times C; \text{ and,}$$

$$\text{mass emission rate (kg/day)} = 3.79 \times Q \times C,$$

where "C" (in mg/L) is the measured daily constituent concentration or the average of measured daily constituent concentrations and "Q" (in MGD) is the measured daily flowrate or the average of measured daily flowrates over the period of interest.

11. The "Maximum Allowable Mass Emission Rate," whether for a month, week, day, or six-month period, is a daily rate determined with the formulas in paragraph G.10, above, using the effluent concentration limit specified in the permit for the period and the average of measured daily flows (up to the allowable flow) over the period.
12. "Maximum Allowable Six-Month Median Mass Emission Rate" is a daily rate determined with the formulas in Central Coast Standard Provision – Provision G.10, above, using the "six-

month Median" effluent limit specified in the permit, and the average of measured daily flows (up to the allowable flow) over a 180-day period.

13. "Median" is the value below which half the samples (ranked progressively by increasing value) fall. It may be considered the middle value, or the average of two middle values.
14. "Monthly Average" (or "Weekly Average", as the case may be) is the arithmetic mean of daily concentrations or of daily mass emission rates over the specified 30-day (or 7-day) period.

$$\text{Average} = (X1 + X2 + \dots + Xn) / n$$

in which "n" is the number of days samples were analyzed during the period and "X" is either the constituent concentration (mg/l) or mass emission rate (kg/day or lbs/day) for each sampled day. "n" should be four or greater.

15. "Municipality" means a city, town, borough, county, district, association, or other public body created by or under State law and having jurisdiction over disposal of sewage, industrial waste, or other waste.
16. "Overflow" means the intentional or unintentional diversion of flow from the collection and transport systems, including pumping facilities.
17. "Pollutant-free wastewater" means inflow and infiltration, stormwaters, and cooling waters and condensates which are essentially free of pollutants.
18. "Primary Industry Category" means any industry category listed in 40 CFR Part 122, Appendix A.
19. "Removal Efficiency" is the ratio of pollutants removed by the treatment unit to pollutants entering the treatment unit. Removal efficiencies of a treatment plant shall be determined using "Monthly averages" of pollutant concentrations (C, in mg/l) of influent and effluent samples collected about the same time and the following equation (or its equivalent):

$$C_{\text{Effluent}} \text{ Removal Efficiency (\%)} = 100 \times (1 - C_{\text{effluent}} / C_{\text{influent}})$$

20. "Severe property damage" means substantial physical damage to property, damage to treatment facilities which causes them to become inoperable, or substantial and permanent loss to natural resources which can reasonably be expected to occur in the absence of a "bypass". It does not mean economic loss caused by delays in production.
21. "Sludge" means the solids, residues, and precipitates separated from, or created in, wastewater by the unit processes of a treatment system.
22. To "significantly contribute" to a permit violation means an "indirect discharger" must:
  - a. Discharge a daily pollutant loading in excess of that allowed by contract with the "Discharger" or by Federal, State, or Local law;
  - b. Discharge wastewater which substantially differs in nature or constituents from its average discharge;

- c. Discharge pollutants, either alone or in conjunction with discharges from other sources, which results in a permit violation or prevents sewage sludge use or disposal; or
  - d. Discharge pollutants, either alone or in conjunction with pollutants from other sources that increase the magnitude or duration of permit violations.
23. "Toxic Pollutant" means any pollutant listed as toxic under Section 307 (a) (1) of the Clean Water Act or under 40 CFR Part 122, Appendix D. Violation of maximum daily discharge limitations are subject to 24-hour reporting (Federal Standard Provisions V.E.).
24. "Zone of Initial Dilution" means the region surrounding or adjacent to the end of an outfall pipe or diffuser ports whose boundaries are defined through calculation of a plume model verified by the State Water Board.

## ATTACHMENT E – MONITORING AND REPORTING PROGRAM

### Table of Contents

I.	General Monitoring Provisions .....	E-2
II.	Monitoring Locations .....	E-3
III.	Influent Monitoring Requirements.....	E-3
IV.	Effluent Monitoring Requirements .....	E-3
	A. Monitoring Location EFF-001 .....	E-3
V.	Whole Effluent Toxicity Testing Requirements .....	E-4
	A. Whole Effluent Acute Toxicity .....	E-4
	B. Quality Assurance.....	E-5
	C. Accelerated Monitoring Requirements .....	E-5
	D. Conducting Toxicity Identification Evaluations and Toxicity Reduction Evaluations.....	E-6
VI.	Land Discharge Monitoring Requirements .....	E-6
VII.	Reclamation Monitoring Requirements.....	E-6
VIII.	Receiving Water Monitoring Requirements – Surface Water and Groundwater.....	E-7
	A. Salinas Reclamation Canal Monitoring Locations RSW-001 and RSW-002.....	E-7
IX.	Other Monitoring Requirements .....	E-7
X.	Reporting Requirements .....	E-8
	A. General Monitoring and Reporting Requirements .....	E-8
	B. Self-Monitoring Reports (SMRs) .....	E-8
	C. Discharge Monitoring Reports (DMRs).....	E-10
	D. Other Reports .....	E-11

### List of Tables

Table E-1.	Monitoring Station Locations .....	E-3
Table E-2.	Effluent Monitoring – EFF-001 .....	E-3
Table E-3.	Receiving Water Monitoring Requirements – RSW-001 and RSW-002 .....	E-7
Table E-4.	Monitoring Periods and Reporting Schedule.....	E-8



## **ATTACHMENT E – MONITORING AND REPORTING PROGRAM (MRP)**

The Code of Federal Regulations at 40 CFR 122.48 requires that all NPDES permits specify monitoring and reporting requirements. California Water Code (CWC) §13267 and §13383 also authorize the Central Coast Water Board to require technical and monitoring reports. This MRP establishes monitoring and reporting requirements, which implement the federal and California regulations.

### **I. GENERAL MONITORING PROVISIONS**

- A.** Laboratories analyzing monitoring samples shall be certified by the Department of Health Services, in accordance with CWC §13176, and must include quality assurance/quality control data with their reports.
- B.** Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge. All samples shall be taken at the monitoring locations specified below and, unless otherwise specified, before the monitored flow joins or is diluted by any other waste stream, body of water, or substance. Monitoring locations shall not be changed without notification to and approval of the Central Coast Water Board.
- C.** Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to ensure the accuracy and reliability of measurements of the volume of monitored discharges. The devices shall be installed, calibrated, and maintained to ensure that the accuracy of the measurements is consistent with the accepted capability of that type of device. Devices selected shall be capable of measuring flows with a maximum deviation of less than  $\pm 10$  percent from true discharge rates throughout the range of expected discharge volumes. Guidance in selection, installation, calibration, and operation of acceptable flow measurement devices can be obtained from the following references.
  - 1.** A Guide to Methods and Standards for the Measurement of Water Flow, U.S. Department of Commerce, National Bureau of Standards, NBS Special Publication 421, May 1975, 96 pp. (Available from the U.S. Government Printing Office, Washington, D.C. 20402. Order by SD Catalog No. C13.10:421.)
  - 2.** Water Measurement Manual, U.S. Department of Interior, Bureau of Reclamation, Second Edition, Revised Reprint, 1974, 327 pp. (Available from the U.S. Government Printing Office, Washington D.C. 20402. Order by Catalog No. 172.19/2:W29/2, Stock No. S/N 24003-0027.)
  - 3.** Flow Measurement in Open Channels and Closed Conduits, U.S. Department of Commerce, National Bureau of Standards, NBS Special Publication 484, October 1977, 982 pp. (Available in paper copy or microfiche from National Technical Information Services (NTIS) Springfield, VA 22151. Order by NTIS No. PB-273 535/5ST.)
  - 4.** NPDES Compliance Sampling Manual, U.S. Environmental Protection Agency, Office of Water Enforcement, Publication MCD-51, 1977, 140 pp. (Available from the General Services Administration (8FFS), Centralized Mailing Lists Services, Building 41, Denver Federal Center, CO 80225.)
- D.** All monitoring instruments and devices used by the Discharger to fulfill the prescribed monitoring program shall be properly maintained and calibrated as necessary to ensure their continued accuracy. All flow measurement devices shall be calibrated at least once per year to ensure continued accuracy of the devices.

- E. Monitoring results, including noncompliance, shall be reported at intervals and in a manner specified in this MRP.
- F. Unless otherwise specified by this MRP, all monitoring shall be conducted according to test procedures established at 40 CFR 136, *Guidelines Establishing Test Procedures for Analysis of Pollutants*. All analyses shall be conducted using the lowest practical quantitation limit achievable using the specified methodology. Where effluent limitations are set below the lowest achievable quantitation limits, pollutants not detected at the lowest practical quantitation limits will be considered in compliance with effluent limitations. Analysis for toxics listed by the California Toxics Rule shall also adhere to guidance and requirements contained in the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (2005).

## II. MONITORING LOCATIONS

The Discharger shall establish the following monitoring locations to demonstrate compliance with the effluent limitations, discharge specifications, and other requirements in this Order.

**Table E-1. Monitoring Station Locations**

Discharge Point Name	Monitoring Location Name	Monitoring Location Description
001	EFF-001	Treated wastewater located at a point located following all treatment and prior to discharge to the Salinas Reclamation Canal
---	RSW-001	Salinas Reclamation Canal 50 feet upstream of outfall (previously R-001U)
---	RSW-002	Salinas Reclamation Canal 100 feet downstream from outfall (previously R-001D)

## III. INFLUENT MONITORING REQUIREMENTS

This section of the standardized MRP is not applicable to the Discharger.

## IV. EFFLUENT MONITORING REQUIREMENTS

### A. Monitoring Location EFF-001

1. The Discharger shall monitor effluent at monitoring location EFF-001, as follows. If more than one analytical test method is listed for a given parameter, the Discharger must select from the listed methods and corresponding Minimum Level. Discrete discharge periods shall be defined by lapses in discharge flow of 24 hours or more. When discrete discharges occur at Discharge Point 001, monitoring shall occur at least once during the first discrete discharge period of the sampling period. Monitoring for CTR pollutants shall occur once during the permit term, during discharge to the Salinas Reclamation Canal, in the 12-month period before application is made to renew WDRs for the Facility.

**Table E-2. Effluent Monitoring – EFF-001**

Parameter	Units	Sample Type	Minimum Sampling Frequency
Mean Daily Flow	MGD	Estimated	Monthly
Settleable Solids	mL/L	Grab	Monthly
BOD <sub>5</sub>	mg/L	Grab	Monthly <sup>[1]</sup>

Parameter	Units	Sample Type	Minimum Sampling Frequency
TSS	mg/L	Grab	Monthly <sup>[1]</sup>
pH	standard units	Grab	Monthly <sup>[1]</sup>
Temperature	° F	Grab	Monthly <sup>[1]</sup>
Dissolved Oxygen	mg/L	Grab	Monthly <sup>[1]</sup>
Total Dissolved Solids (TDS)	mg/L	Grab	Semiannually <sup>[2]</sup>
Boron	mg/L	Grab	Semiannually <sup>[2]</sup>
Chloride	mg/L	Grab	Semiannually <sup>[2]</sup>
Sodium	mg/L	Grab	Semiannually <sup>[2]</sup>
Sulfate	mg/L	Grab	Semiannually <sup>[2]</sup>
Total Nitrogen (as N)	mg/L	Grab	Semiannually <sup>[2]</sup>
Nitrate Nitrogen (as N)	mg/L	Grab	Semiannually <sup>[2]</sup>
Selenium	µg/L	Grab	Semiannually <sup>[2]</sup>
Bis(2-Ethylhexyl)Phthalate	µg/L	Grab	Semiannually <sup>[2]</sup>
Total Ammonia (as N)	mg/L	Grab	Annually
Un-ionized Ammonia <sup>[3]</sup>	mg/L	Calculated	Annually
<i>E. coli</i> Bacteria	MPN/100mL	Grab	Annually
Fecal Coliform Bacteria	MPN/100mL	Grab	Annually
Turbidity	NTU	Grab	Annually
Copper	µg/L	Grab	Annually
Chlorpyrifos	µg/L	Grab	Annually
Diazinon	µg/L	Grab	Annually
Priority Organics <sup>[4]</sup>	µg/L	Grab	Annually
Pesticides <sup>[4]</sup>	µg/L	Grab	Annually
Acute Toxicity <sup>[5]</sup>	TU <sub>a</sub>	Grab	Annually
Remaining CTR Pollutants <sup>[6][7]</sup>	µg/L	Grab	Once per permit term

[1] BOD<sub>5</sub>, TSS, pH, temperature, and dissolved oxygen shall be monitored once per month from May through October.

[2] Monitoring shall be performed two times per year, during operating periods in June and in September.

[3] Temperature and pH are to be measured concurrently with the total ammonia sample, and the results shall be used to calculate and report un-ionized ammonia concentrations.

[4] See Attachment G for pollutant listing.

[5] Whole effluent acute toxicity monitoring shall be conducted according to the requirements established in Section V.A of this Monitoring and Reporting Plan. Effluent flow shall be recorded at the time of sampling.

[6] Analyses, compliance determination, and reporting for these pollutants shall adhere to applicable provisions of the Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California (SIP). The Discharger shall instruct its analytical laboratory to establish calibration standards so that the Minimum Levels (MLs) presented in Appendix 4 of the SIP are the lowest calibration standards. The Discharger and its analytical laboratory shall select MLs, which are below applicable water quality criteria of the CTR; and when applicable water quality criteria are below all MLs, the Discharger and its analytical laboratory shall select the lowest ML.

[7] Those remaining 126 pollutants with applicable water quality objectives established by the CTR at 40 CFR 131.38.

## V. WHOLE EFFLUENT TOXICITY TESTING REQUIREMENTS

### A. Whole Effluent Acute Toxicity

#### 1. Acute Toxicity Monitoring Requirements - EFF-001

- a. Compliance with acute toxicity limitation shall be determined using a U.S. Environmental Protection Agency (USEPA) approved method protocol as provided in 40 CFR 136 (*Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms*, Fifth Edition, USEPA Office of Water, EPA-821- R-02-012 (2002) or the latest edition).
- b. Bioassays shall be performed to evaluate the toxicity of the discharge in accordance with the following procedures unless otherwise specified by the Central Coast Water Board's Executive Officer or designee:
- c. The Discharger shall use the fathead minnow to measure acute toxicity.
- d. The presence of acute toxicity shall be determined as significantly reduced survival of test organisms at 100 percent effluent compared to a control using a statistical t-test. The Discharger shall include with the SMR the percent survival of the organisms for both the effluent and control, and the results of the t-test ("statistically different" or "not statistically different").

## **B. Quality Assurance**

1. For the acute toxicity testing using a t-test, two dilutions shall be used, i.e., 100 percent effluent and a control.
2. If organisms are not cultured in-house, concurrent testing with a referenced toxicant shall be conducted. Where organisms are cultured in-house, monthly reference toxicant testing is sufficient. Reference toxicant tests also shall be conducted using the same test conditions as the effluent toxicity tests (e.g., same test duration, etc.).
3. If either the reference toxicant test or effluent test does not meet all test acceptability criteria (TAC) as specified in the toxicity test references, then the Discharger must re-sample and retest within 14 working days or as soon as possible. The retesting period begins when the Discharger collects the first sample required to complete the retest.
4. The reference toxicant and effluent tests must meet the upper and lower bounds on test sensitivity as determined by calculating the percent minimum significant difference (PMSD) for each test result. The test sensitivity bound is specified for each test method in the respective methods manuals.

## **C. Accelerated Monitoring Requirements**

1. When acute toxicity is detected in the effluent, and the testing meets all test acceptability criteria, the Discharger shall initiate accelerated monitoring to confirm the effluent toxicity.
2. The Discharger shall implement an accelerated monitoring frequency consisting of performing three toxicity tests in a six-week period following the first test result that shows an exceedance of the effluent limitation.
3. If implementation of the generic Toxicity Reduction Evaluation (TRE) work plan indicates the source of the exceedance of the toxicity limitation (for instance, a temporary plant upset), then only one additional test is necessary. If exceedance of the toxicity limitation is detected in this test, the Discharger will continue with accelerated monitoring requirements or implement the Toxicity Identification and Toxicity Reduction Evaluations.

4. If none of the three tests indicated exceedance of the applicable toxicity limitation, then the Discharger may return to the normal toxicity testing frequency.

#### **D. Conducting Toxicity Identification Evaluations and Toxicity Reduction Evaluations**

1. A Toxicity Identification Evaluation (TIE) shall be triggered if testing from the accelerated monitoring frequency indicates any of the following:
  - a. Two of the three accelerated toxicity tests are reported as failed tests meeting any of the conditions specified in Attachment E, Section V.C.
  - b. The TIE shall be initiated within 15 days following failure of the second accelerated monitoring test.
  - c. If a TIE is triggered prior to the completion of the accelerated testing, the accelerated testing schedule may be terminated, or used as necessary in performing the TIE.
2. The TIE shall be conducted to identify and evaluate toxicity in accordance with procedures recommended by the USEPA which include the following:
  - a. Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I, (USEPA, 1992a);
  - b. Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures, Second Edition (USEPA, 1991a);
  - c. Methods for Aquatic Toxicity Identification Evaluations: Phase II Toxicity Identification Procedures for Sampling Exhibiting Acute and Chronic Toxicity (USEPA, 1993a); and
  - d. Methods for Aquatic Toxicity Identification Evaluations: Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity (USEPA, 1993b).
3. As part of the TIE investigation, the Discharger shall be required to implement its TRE work plan. The Discharger shall take all reasonable steps to control toxicity once the source of the toxicity is identified. A failure to conduct required toxicity tests or a TRE within a designated period shall result in appropriate enforcement action. Recommended guidance in conducting a TRE include the following:
  - a. Clarifications Regarding Toxicity Reduction and Identification Evaluations in the National Pollutant Discharge Elimination System Program dated March 27, 2001, USEPA Office of Wastewater Management, Office of Regulatory Enforcement.

#### **VI. LAND DISCHARGE MONITORING REQUIREMENTS**

This section of the standardized MRP is not applicable to the Discharger.

#### **VII. RECLAMATION MONITORING REQUIREMENTS**

This section of the standardized MRP is not applicable to the Discharger.

**VIII. RECEIVING WATER MONITORING REQUIREMENTS – SURFACE WATER AND GROUNDWATER**

**A. Salinas Reclamation Canal Monitoring Locations RSW-001 and RSW-002.**

1. The Discharger shall monitor the receiving water at Monitoring Locations RSW-001 and RSW-002, as follows.

**Table E-3. Receiving Water Monitoring Requirements – RSW-001 and RSW-002**

Parameter	Units	Sample Type	Minimum Sampling Frequency
pH <sup>[1][2]</sup>	s.u.	Grab	Semiannually <sup>[3]</sup>
Temperature <sup>[1][2]</sup>	°F	Grab	Semiannually <sup>[3]</sup>
Dissolved Oxygen	mg/L	Metered	Semiannually <sup>[3]</sup>
Turbidity <sup>[4]</sup>	NTU	Grab	Semiannually <sup>[3]</sup>
Total Dissolved Solids	mg/L	Grab	Semiannually <sup>[3]</sup>
Nitrate Nitrogen (as N)	mg/L	Grab	Semiannually <sup>[3]</sup>
Total Nitrogen (as N)	mg/L	Grab	Semiannually <sup>[3]</sup>
Fecal Coliform Bacteria <sup>[5]</sup>	MPN/100mL	Grab	Annually
Total Coliform Bacteria <sup>[5]</sup>	MPN/100mL	Grab	Annually
Enterococcus Bacteria	MPN/100mL	Grab	Annually
Hardness (RSW-001 only) <sup>[6]</sup>	mg/L	Grab	Once per permit term
CTR Pollutants (RSW-001 only) <sup>[6][7][8]</sup>	µg/L	Grab	Once per permit term

- [1] To be sampled at the frequency specified if effluent un-ionized ammonia limitation is exceeded. Sampling shall continue until two (2) effluent samples at the specified frequency show compliance.
- [2] Temperature and pH are to be measured concurrently with the total ammonia sample, and the results shall be used to calculate and report un-ionized ammonia concentrations.
- [3] Monitoring shall be performed two times per year, during operating periods in June and in September.
- [4] To be sampled at the frequency specified if effluent turbidity limitations are exceeded.
- [5] To be sampled within 24 hours of effluent limitation exceedance of limitations for total or fecal coliform.
- [6] Grab samples shall be collected one time, during discharge, and within the twelve-month period before application is made to renew the Waste Discharge Requirements for the Facility.
- [7] Analyses, compliance determination, and reporting for these pollutants shall adhere to applicable provisions of the Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California (SIP). The Discharger shall instruct its analytical laboratory to establish calibration standards so that the Minimum Levels (MLs) presented in Appendix 4 of the SIP are the lowest calibration standards. The Discharger and its analytical laboratory shall select MLs, which are below applicable water quality criteria of the CTR; and when applicable water quality criteria are below all MLs, the Discharger and its analytical laboratory shall select the lowest ML.
- [8] Those 126 pollutants with applicable water quality objectives established by the California Toxics Rule (CTR) at 40 CFR 131.38.

2. At the time of receiving water sampling, the Discharger shall keep a log of receiving water conditions, and shall note the presence or absence of floating or suspended matter, discoloration, foaming, aquatic life, bottom deposits, oils sheen, and algal growth. The Discharger shall summarize receiving water conditions in notes entered into the monitoring report.

**IX. OTHER MONITORING REQUIREMENTS**

This section of the standardized MRP is not applicable to the Discharger.

**X. REPORTING REQUIREMENTS**

**A. General Monitoring and Reporting Requirements**

1. The Discharger shall comply with all Standard Provisions (Attachment D) related to monitoring, reporting, and recordkeeping.

**B. Self-Monitoring Reports (SMRs)**

1. The Discharger must electronically submit Self-Monitoring Reports (SMRs) using the State Water Board’s California Integrated Water Quality System (CIWQS) Program Web site (<http://www.waterboards.ca.gov/ciwqs/index.html>). The CIWQS web site will provide additional directions for SMR submittal in the event there will be service interruption for electronic submittal.
2. The Discharger shall report in the SMR the results for all monitoring specified in this MRP under sections III through IX. The Discharger shall submit monthly, quarterly, and annual SMRs including the results of all required monitoring using USEPA-approved test methods or other test methods specified in this Order. If the Discharger monitors any pollutant more frequently than required by this Order, the results of this monitoring shall be included in the calculations and reporting of the data submitted in the SMR.
3. Monitoring periods and reporting for all required monitoring shall be completed according to the following schedule.

**Table E-4. Monitoring Periods and Reporting Schedule**

Sampling Frequency	Monitoring Period Begins On...	Monitoring Period	SMR Due Date
Continuous	Permit effective date	All	First day of second calendar month following month of sampling
Daily	Permit effective date	(Midnight through 11:59 PM) or any 24-hour period that reasonably represents a calendar day for purposes of sampling.	
Weekly	Sunday following permit effective date or on permit effective date if on a Sunday	Sunday through Saturday	
Monthly	First day of calendar month following permit effective date or on permit effective date if that date is first day of the month	1 <sup>st</sup> day of calendar month through last day of calendar month	
Quarterly	Closest of January 1, April 1, July 1, or October 1 following (or on) permit effective date	January 1 through March 31 April 1 through June 30 July 1 through September 30 October 1 through December 31	May 1 August 1 November 1 February 1
Semiannually	Closest of January 1 or July 1 following (or on) permit effective date	January 1 through June 30 July 1 through December 31	August 1 February 1
Annually	January 1 following (or on) permit effective date	January 1 through December 31	February 15
1X/Permit term	January 1 following (or on) permit effective date	Permit term	180 days prior to permit expiration

4. **Reporting Protocols.** The Discharger shall report with each sample result the applicable reported Minimum Level (ML) and the current Method Detection Limit (MDL), as determined by the procedure in Part 136.

The Discharger shall report the results of analytical determinations for the presence of chemical constituents in a sample using the following reporting protocols:

- a. Sample results greater than or equal to the reported ML shall be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).
- b. Sample results less than the RL, but greater than or equal to the laboratory's MDL, shall be reported as "Detected, but Not Quantified," or DNQ. The estimated chemical concentration of the sample shall also be reported.

For the purposes of data collection, the laboratory shall write the estimated chemical concentration next to DNQ as well as the words "Estimated Concentration" (may be shortened to "Est. Conc."). The laboratory may, if such information is available, include numerical estimates of the data quality for the reported result. Numerical estimates of data quality may be percent accuracy (+ a percentage of the reported value), numerical ranges (low to high), or any other means considered appropriate by the laboratory.

- c. Sample results less than the laboratory's MDL shall be reported as "Not Detected," or ND.
  - d. Dischargers are to instruct laboratories to establish calibration standards so that the ML value (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Discharger to use analytical data derived from extrapolation beyond the lowest point of the calibration curve.
5. **Compliance Determination.** Compliance with effluent limitations for priority pollutants shall be determined using sample reporting protocols defined above and Attachment A of this Order. For purposes of reporting and administrative enforcement by the Central Coast Water Board and State Water Boards, the Discharger shall be deemed out of compliance with effluent limitations if the concentration of the priority pollutant in the monitoring sample is greater than the effluent limitation and greater than or equal to the reporting level (RL).
  6. **Multiple Sample Data.** When determining compliance with an AMEL, AWEL, or MDEL for priority pollutants and more than one sample result is available, the Discharger shall compute the arithmetic mean unless the data set contains one or more reported determinations of "Detected, but Not Quantified" (DNQ) or "Not Detected" (ND). In those cases, the Discharger shall compute the median in place of the arithmetic mean in accordance with the following procedure:
    - a. The data set shall be ranked from low to high, ranking the reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
    - b. The median value of the data set shall be determined. If the data set has an odd number of data points, then the median is the middle value. If the data set has an even number of data points, then the median is the average of the two values around the middle unless one or both of the points are ND or DNQ, in which case the median value



shall be the lower of the two data points where DNQ is lower than a value and ND is lower than DNQ.

7. The Discharger shall submit SMRs in accordance with the following requirements:
  - a. The Discharger shall arrange all reported data in a tabular format. The data shall be summarized to clearly illustrate whether the facility is operating in compliance with interim and/or final effluent limitations. The Discharger is not required to duplicate the submittal of data that is entered in a tabular format within CIWQS. The Discharger shall submit Self-Monitoring Reports (SMRs) electronically using the State Water Board's California Integrated Water Quality System (CIWQS) Program Web site (<http://www.waterboards.ca.gov/ciwqs/index.html>). The CIWQS web site will provide additional directions for SMR submittal in the event there will be service interruption for electronic submittal.
  - b. The Discharger shall attach a cover letter to the SMR. The information contained in the cover letter shall clearly identify violations of the WDRs; discuss corrective actions taken or planned; and the proposed time schedule for corrective actions. Identified violations must include a description of the requirement that was violated and a description of the violation.
  - c. SMRs must be submitted to the Central Coast Water Board via the California Integrated Water Quality system (CIWQS) internet database, signed and certified as required by the Standard Provisions (Attachment D). If an electronic submittal is not available, the electronic copy SMR must be submitted to the address listed below:

Central Coast Water Board  
[Centralcoast@waterboards.ca.gov](mailto:Centralcoast@waterboards.ca.gov)

**C. Discharge Monitoring Reports (DMRs)**

1. As described in Section X.B.1 above, the Discharger must electronically submit SMRs that will satisfy federal requirements for submittal of Discharge Monitoring Reports (DMRs). If the DMR website is inoperable, Discharger shall submit DMRs in accordance with the requirements described below.
2. DMRs must be signed and certified as required by the standard provisions (Attachment D). The Discharger shall submit the original DMR and one copy of the DMR to the address listed below:

STANDARD MAIL	FEDEX/UPS/ OTHER PRIVATE CARRIERS
State Water Resources Control Board Division of Water Quality c/o DMR Processing Center PO Box 100 Sacramento, CA 95812-1000	State Water Resources Control Board Division of Water Quality c/o DMR Processing Center 1001 I Street, 15 <sup>th</sup> Floor Sacramento, CA 95814

3. Unless DMRs are submitted electronically through CWIQS, discharge monitoring results must be reported on the official USEPA pre-printed DMR forms (EPA Form 3320-1). Forms that are self-generated will not be accepted unless they follow the exact same format of EPA Form 3320-1.

#### **D. Other Reports**

1. The Discharger shall report the results of any special monitoring, TREs, or other data or information that results from section VI.C (Special Provisions) of the Order. The Discharger shall submit such reports with the first monthly SMR scheduled to be submitted on or immediately following the report due date.

**ATTACHMENT F – FACT SHEET**

**Table of Contents**

I.	Permit Information.....	F-3
II.	FACILITY Description .....	F-4
	A. Description of Wastewater Treatment .....	F-4
	B. Discharge Points and Receiving Waters .....	F-4
	C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data .....	F-4
	D. Compliance Summary.....	F-5
	E. Planned Changes .....	F-5
III.	Applicable Plans, Policies, and Regulations .....	F-5
	A. Legal Authorities .....	F-5
	B. California Environmental Quality Act (CEQA).....	F-6
	C. State and Federal Regulations, Policies, and Plans .....	F-6
	D. Impaired Water Bodies on CWA 303(d) List.....	F-7
	E. Other Plans, Policies and Regulations – Not Applicable .....	F-8
IV.	Rationale For Effluent Limitations and Discharge Specifications .....	F-8
	A. Discharge Prohibitions .....	F-8
	B. Technology-Based Effluent Limitations .....	F-9
	1. Scope and Authority .....	F-9
	2. Applicable Technology-Based Effluent Limitations.....	F-9
	C. Water Quality-Based Effluent Limitations (WQBELs) .....	F-9
	1. Scope and Authority .....	F-9
	2. Applicable Beneficial Uses and Water Quality Criteria and Objectives.....	F-10
	3. Determining the Need for WQBELs .....	F-10
	4. WQBEL Calculations .....	F-11
	5. Whole Effluent Toxicity (WET) .....	F-13
	D. Final Effluent Limitations.....	F-14
	1. Satisfaction of Anti-Backsliding Requirements.....	F-14
	2. Satisfaction of Antidegradation Policy.....	F-14
	3. Stringency of Requirements for Individual Pollutants .....	F-15
	E. Interim Effluent Limitations.....	F-15
	F. Land Discharge Specifications.....	F-15
	G. Reclamation Specifications.....	F-15
V.	Rationale for Receiving Water Limitations .....	F-15
	A. Surface Water.....	F-15
	B. Groundwater .....	F-15
VI.	Rationale for Monitoring and Reporting Requirements .....	F-15
	A. Influent Monitoring .....	F-16
	B. Effluent Monitoring .....	F-16
	C. Whole Effluent Toxicity Testing Requirements .....	F-16
	D. Receiving Water Monitoring.....	F-16
	1. Surface Water .....	F-16
	2. Groundwater.....	F-17
	E. Other Monitoring Requirements .....	F-17
VII.	Rationale for Provisions .....	F-17
	A. Standard Provisions.....	F-17
	B. Monitoring and Reporting Program (MRP) Requirements .....	F-17
	C. Special Provisions.....	F-18
	1. Reopener Provisions .....	F-18

2. Special Studies and Additional Monitoring Requirements .....	F-18
3. Best Management Practices and Pollution Prevention .....	F-18
4. Construction, Operation, and Maintenance Specifications .....	F-18
5. Special Provisions for Municipal Facilities (POTWs Only) .....	F-18
6. Other Special Provisions .....	F-18
7. Compliance Schedules .....	F-18
VIII. Public Participation .....	F-18
A. Notification of Interested Parties .....	F-19
B. Written Comments .....	F-19
C. Public Hearing .....	F-19
D. Waste Discharge Requirements Petitions .....	F-19
E. Information and Copying .....	F-19
F. Register of Interested Persons .....	F-20
G. Additional Information .....	F-20

**List of Tables**

Table F-1. Facility Information .....	F-3
Table F-2. Historic Effluent Limitations and Monitoring Data .....	F-4
Table F-3. Basin Plan Beneficial Uses .....	F-6
Table F-4. Summary of Technology-Based Effluent Limitations – Discharge Point 001 .....	F-9
Table F-5. RPA Results .....	F-11
Table F-6. Calculation of Long-Term Averages .....	F-12
Table F-7. Calculation of Aquatic Life WQBELs .....	F-12
Table F-8. Calculation of Human Health WQBELs .....	F-12
Table F-9. Summary of WQBELs – Discharge Point 001 .....	F-14
Table F-11. Receiving Water Monitoring Data .....	F-17

## ATTACHMENT F – FACT SHEET

As described in section II of this Order, this Fact Sheet includes the legal requirements and technical rationale that serve as the basis for the requirements of this Order.

This Order has been prepared under a standardized format to accommodate a broad range of discharge requirements for Dischargers in California. Only those sections or subsections of this Order that are specifically identified as “not applicable” have been determined not to apply to this Discharger. Sections or subsections of this Order not specifically identified as “not applicable” are fully applicable to this Discharger.

### I. PERMIT INFORMATION

The following table summarizes administrative information related to the Facility.

**Table F-1. Facility Information**

<b>WDID</b>	3 272009001
<b>Discharger</b>	The Uni-Kool Partners
<b>Name of Facility</b>	Uni-Kool Partners Vegetable Packing Facility
<b>Facility Address</b>	320 John Street
	Salinas, CA 93901
	Monterey County
<b>Facility Contact, Title and Phone</b>	Robert Bellew, Manager, (831) 424-4811
<b>Authorized Person to Sign and Submit Reports</b>	Robert Bellew, Manager, (831) 424-4811
<b>Mailing Address</b>	PO Box 3140, Salinas, CA 93912
<b>Billing Address</b>	PO Box 3140, Salinas, CA 93912
<b>Type of Facility</b>	Vegetable Processing (SIC Code 0273, NAICS Code 115114)
<b>Major or Minor Facility</b>	Minor
<b>Threat to Water Quality</b>	3
<b>Complexity</b>	B
<b>Pretreatment Program</b>	N
<b>Reclamation Requirements</b>	N
<b>Facility Permitted Flow</b>	0.10 MGD
<b>Facility Design Flow</b>	0.10 MGD
<b>Watershed</b>	Salinas River Watershed
<b>Receiving Waters</b>	Salinas Reclamation Canal
<b>Receiving Water Type</b>	Drain

- A.** The Uni-Kool Partners is the owner and operator of the Uni-Kool Partners Vegetable Packing Facility, a vegetable packing, processing, and cold storage facility.
- B.** For the purposes of this Order, references to the “discharger” or “permittee” in applicable federal and State laws, regulations, plans, or policy are held to be equivalent to references to the Discharger herein.
- C.** This Order authorizes the discharge of cold storage melted ice, spent fresh vegetable wash water, equipment wash water, evaporative cooler blowdown, and stormwater to the Salinas

Reclamation Canal, a water of the United States. The terms and conditions of the current Order (Order No. R3-2005-0046) have been automatically continued past its expiration date of May 13, 2010, and remain in effect until new waste discharge requirements are adopted pursuant to this Order.

- D. The Discharger filed a Report of Waste Discharge and submitted an application for renewal of its Waste Discharge Requirements (WDRs) and National Pollutant Discharge Elimination System (NPDES) permit on March 9, 2010.

**II. FACILITY DESCRIPTION**

**A. Description of Wastewater Treatment**

The Discharger owns and operates a vegetable packing, processing and cold storage facility (hereinafter referred to as the Facility) located at the intersection of Abbott Street and John Street in the City of Salinas. The Facility receives, washes, chills, packs, stores, and ships vegetables from farm to market.

The Facility generates process wastewater (cold storage melted ice, spent fresh vegetable wash water, equipment wash water, evaporative cooler blowdown) as well as on-site stormwater. Coarse particulates, such as pebbles, vegetable roots, or other larger-sized vegetable wastes, are removed by way of strainers. Anti-foaming agents are then added to the waste stream to prevent foam build-up in subsequent treatment processes. Fine particulates, such as dirt and smaller-sized vegetable wastes, are removed through the use of Sweco-brand 80-mesh screens. Screened wastes are then routed through the Facility’s settling and aeration ponds prior to discharge to the Salinas Reclamation Canal. (Altogether, the Facility’s settling and aeration ponds hold up to 350,000 gallons of treated wastewater and stormwater.)

**B. Discharge Points and Receiving Waters**

Treated wastewater and stormwater is discharged at Discharge Point 001 (36° 40' 16" N, 121° 38' 23" W) to a storm drain tributary to the Salinas Reclamation Canal. The Facility’s current design capacity is 0.10 MGD, which serves as its dry weather design flow.

**C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data**

Effluent limitations contained in the previous Order for treated wastewater and stormwater and monitoring data collected during the permit term are summarized in the table below.

**Table F-2. Historic Effluent Limitations and Monitoring Data**

Parameter	Units	Effluent Limitation		Monitoring Data (May 2005 – May 2012)
		Monthly Average	Maximum Daily	Maximum Reported Value
Daily Discharge Flow	MGD	---	0.10	0.1
Biochemical Oxygen Demand (5-day @ 20°C) (BOD <sub>5</sub> )	mg/L	60	90	15
Total Suspended Solids (TSS)	mg/L	60	90	57
Settleable Solids	mL/L/hr	---	0.3	0.1
Total Dissolved Solids (TDS)	mg/L	1300	1500	1190
Boron	mg/L	---	0.5	0.56
Chloride	mg/L	---	250	172

Parameter	Units	Effluent Limitation		Monitoring Data (May 2005 – May 2012)
		Monthly Average	Maximum Daily	Maximum Reported Value
Sodium	mg/L	---	250	143
Sulfate	mg/L	---	600	317
Nitrate (as N)	mg/L	---	10	6
Dissolved Oxygen (D.O.)	mg/L	5.0 <sup>[1]</sup>	---	12.8
pH	s.u.	---	7.0 – 8.3 <sup>[2]</sup>	8.4
Acute Toxicity	%survival	---	100 <sup>[3]</sup>	100

Table Notes:

- [1] This effluent limitation is expressed as an instantaneous minimum.
- [2] This range represents the instantaneous minimum and maximum pH limitations, respectively.
- [3] Survival of test organisms exposed to 100 percent effluent shall not be significantly reduced when compared to the survival of control organisms using a t-test.

#### D. Compliance Summary

There were 19 permit violations that occurred during the term of the previous permit (R3-2005-0046), as determined through a review of the CIWQS violation report for the Facility. The majority of violations were from effluent limitation violations (boron, dissolved oxygen, nitrate, pH, and settleable solids). The Central Coast Water Board issued a notice of violation on May 16, 2008, for effluent limit violations and reporting violations occurring between April 2007 and November 2007.

Facility inspections were conducted on February 10, 2006, April 23, 2009, and April 13, 2012. No permit violations were identified during these inspections.

#### E. Planned Changes

The Discharger anticipates expanding production at the Facility and requested in a letter received on June 14, 2012, that the permitted discharge volume be increased from 0.10 MGD to 0.15 MGD. However, the Discharger did not submit a revised Report of Waste Discharge, which should have evaluated the adequacy of its treatment systems for the increase in flow. This Order therefore includes no changes to its requirements or specifications. Applicable Plans, Policies, and Regulations

The requirements contained in the proposed Order are based on the requirements and authorities described in this section.

### III. APPLICABLE PLANS, POLICIES, AND REGULATIONS

#### A. Legal Authorities

This Order is issued pursuant to the federal Clean Water Act (CWA) §402 and implementing regulations adopted by the USEPA and chapter 5.5, division 7 of the California Water Code (CWC), commencing with §402 of the 13370. It shall serve as a NPDES permit for point source discharges from this facility to surface waters. This Order also serves as Waste Discharge Requirements (WDRs) pursuant to article 4, chapter 4, division 7 of the CWC commencing with §402 of the 13260).

**B. California Environmental Quality Act (CEQA)**

Pursuant to CWC §13389, this action to adopt an NPDES permit is exempt from the provisions of CEQA, Public Resources Code §21100 through §21177.

**C. State and Federal Regulations, Policies, and Plans**

**1. Water Quality Control Plans.** The Central Coast Water Board has adopted the *Water Quality Control Plan for the Central Coastal Basin* (the Basin Plan), which designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for receiving waters within the region. In addition, the Basin Plan implements State Water Resources Control Board (State Water Board) Resolution No. 88-63, which establishes State policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply. Beneficial uses established by the Basin Plan for the Salinas Reclamation Canal and to groundwater in the vicinity of the discharge are presented below.

**Table F-3. Basin Plan Beneficial Uses**

Discharge Point	Receiving Water Name	Beneficial Use(s)
001	Salinas Reclamation Canal	<ul style="list-style-type: none"> <li>• Contact Water Recreation (REC-1)</li> <li>• Non-contact Water Recreation (REC-2)</li> <li>• Wildlife Habitat (WILD)</li> <li>• Warm Freshwater Habitat (WARM)</li> <li>• Commercial and Sport Fishing (COMM)</li> </ul>
001	Groundwater	<ul style="list-style-type: none"> <li>• Municipal and Domestic Supply (MUN)</li> <li>• Agricultural Supply (AGR)</li> <li>• Industrial Supply (IND)</li> </ul>

Requirements of this Order implement the Basin Plan.

**2. National Toxics Rule (NTR) and California Toxics Rule (CTR).** USEPA adopted the NTR on December 22, 1992, and later amended it on May 4, 1995, and November 9, 1999. About forty criteria in the NTR applied in California. On May 18, 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the State. The CTR was amended on February 13, 2001. These rules contain water quality criteria for priority pollutants that are applicable to the receiving waters for discharges from the Facility.

**3. State Implementation Policy.** On March 2, 2000, the State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP became effective on April 28, 2000 with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Central Coast Water Board in the Basin Plan. The SIP became effective on May 18, 2000 with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005 that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control that are applicable to discharges to the receiving waters for discharges from the Facility. Requirements of this Order implement the SIP.



4. **Alaska Rule.** On March 30, 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards become effective for CWA purposes [65 Fed. Reg. 24641 (April 27, 2000) (codified at 40 CFR 131.21,)]. Under the revised regulation (also known as the Alaska Rule), new and revised standards submitted to USEPA after May 30, 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA by May 30, 2000, may be used for CWA purposes, whether or not approved by USEPA.
5. **Antidegradation Policy.** NPDES regulations at 40 CFR 131.12 require that State water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution No. 68-16, which incorporates the federal antidegradation policy where the federal policy applies under federal law. Resolution No. 68-16 requires that the existing quality of waters be maintained unless degradation is justified based on specific findings. The Central Coast Water Board's Basin Plan implements and incorporates by reference both the State and federal antidegradation policies. As discussed in section IV.D.2 of this Fact Sheet, the permitted discharge is consistent with the antidegradation provisions of 40 CFR 131.12 and State Water Board Resolution No. 68-16.
6. **Anti-Backsliding Requirements.** CWA §402(o)(2) and §303(d)(4) and NPDES regulations at 40 CFR 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require effluent limitations in a reissued permit to be as stringent as those in the previous permit, with some exceptions where limitations may be relaxed. As discussed in section IV.D.1 of this Fact Sheet, effluent limitations and other requirements established by this Order satisfy applicable anti-backsliding provisions of the CWA and NPDES regulations.

#### D. Impaired Water Bodies on CWA 303(d) List

CWA §303(d) requires states to identify specific water bodies where water quality standards are not expected to be met after implementation of technology based limitations on point sources. For all §303(d) listed water bodies, the Central Coast Water Board must develop and implement TMDLs (total maximum daily loads) that specify waste load allocations for point sources and load allocations for non-point sources.

The USEPA partially approved the State's 2010 §303(d) list of impaired water bodies on November 12, 2010, and issued a final decision regarding the water bodies and pollutants that USEPA added to the State's 2010 §303(d) list on October 11, 2011. The 2010 §303(d) list identifies the Salinas Reclamation Canal as being impaired for ammonia (un-ionized), chlorpyrifos, copper, diazinon, *E. coli*, fecal coliform, low dissolved oxygen, nitrate, pesticides, pH, priority organics, sediment toxicity, turbidity, and unknown toxicity.

TMDLs establish waste load allocations for point source and load allocations for non-point sources and are intended to achieve the water quality standards for the impaired water bodies. According to the 2010 §303(d) list, these TMDLs are scheduled for completion between 2013 and 2018. Two TMDLs that affect the Salinas Reclamation Canal have been approved (Chlorpyrifos/Diazinon and Fecal Coliform TMDLs). A third TMDL that affects the Salinas Reclamation Canal is under development (Nutrients).

The Fecal Coliform TMDL affects the City of Salinas MS4, to which the Facility discharges its wastewaters.

## **E. Other Plans, Polices and Regulations – Not Applicable**

### **IV. RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS**

The CWA requires point source dischargers to control the amount of conventional, non-conventional, and toxic pollutants that are discharged into the waters of the United States. The control of pollutants discharged is established through effluent limitations and other requirements in NPDES permits. NPDES regulations establish two principal bases for effluent limitations. At 40 CFR 122.44(a) permits are required to include applicable technology-based limitations and standards; and at 40 CFR 122.44(d) permits are required to include water quality-based effluent limitations (WQBELs) to attain and maintain applicable numeric and narrative water quality criteria (WQC) to protect the beneficial uses of the receiving water. When numeric water quality objectives (WQOs) have not been established, but a discharge has the reasonable potential to cause or contribute to an excursion above a narrative criterion, WQBELs may be established using one or more of three methods described at 40 CFR 122.44(d) - 1) WQBELs may be established using a calculated water quality criterion derived from a proposed State criterion or an explicit State policy or regulation interpreting its narrative criterion; 2) WQBELs may be established on a case-by-case basis using USEPA criteria guidance published under CWA Section 304(a); or 3) WQBELs may be established using an indicator parameter for the pollutant of concern.

#### **A. Discharge Prohibitions**

- 1. Discharge Prohibition III. A** (No discharge at a location or in a manner except as described by the Order). The Order authorizes a single point of discharge of treated process wastewater (cold storage melted ice, spent fresh vegetable wash, equipment wash, and evaporative cooler blowdown water) and stormwater to the Salinas Reclamation Canal. This prohibition reflects CWA §402's prohibition against discharges of pollutants except in compliance with the Act's permit requirements, effluent limitations, and other enumerated provisions.
- 2. Discharge Prohibition III. B** (The discharge of any waste not specifically regulated by this permit is prohibited.) Because limitations and conditions of the Order have been prepared based on specific information provided by the Discharger and specific wastes described by the Discharger, the limitations and conditions of the Order do not adequately address waste streams not contemplated during drafting of the Order. To prevent the discharge of such waste streams that may be inadequately regulated, the Order establishes this prohibition against the discharge of any waste that was not described to the Central Coast Water Board during the process of permit reissuance.
- 3. Discharge Prohibition III. C** (Creation of a condition of pollution, contamination, or nuisance, as defined by CWC §13050, is prohibited). This prohibition is based on CWC §13050.
- 4. Discharge Prohibition III. D** (Overflows and bypasses prohibited). The discharge of untreated or partially treated wastewater from the Discharger's collection, treatment, or disposal facilities represents an unauthorized bypass pursuant to 40 CFR 122.41(m) or an unauthorized discharge, which poses a threat to human health and/or aquatic life, and therefore, is explicitly prohibited by the Order.
- 5. Discharge Prohibition III. E** (Daily dry weather flow, averaged monthly [the average daily flow in the three driest months of the year] shall not exceed a dry weather monthly average of 0.10 MGD). This prohibition is newly established in the Order. The purpose of the prohibition is to assure efficient treatment of wastewater by assuring that flows do not exceed the Facility's dry weather design capacity.

- 6. Discharge Prohibition III. F** (The discharge of radioactive substances is prohibited). This prohibition is retained from the previous permit.

**B. Technology-Based Effluent Limitations**

**1. Scope and Authority**

NPDES regulations at 40 CFR 122.44(a) require that permits include applicable technology-based limitations and standards. Where the USEPA has not yet developed technology based standards for a particular industry or a particular pollutant, CWA §402(a)(1) and USEPA regulations at 40 CFR 125.3 authorize the use of best professional judgment (BPJ) to derive technology-based effluent limitations on a case-by-case basis. When BPJ is used, the permit writer must consider specific factors outlined at 40 CFR 125.3.

This NPDES permit is for a fresh vegetable packing, processing and cold storage facility. Furthermore, the Facility does not operate the canning of fruits or vegetables, which are subject to technology-based effluent limitations and standards established in 40 CFR 407. Therefore, this Order includes technology-based effluent limitations based on BPJ in accordance with 40 CFR 125.3. Effluent limitations for BOD<sub>5</sub>, TSS, and settleable solids have been carried over from the previous Order No. R3-2005-0046.

**2. Applicable Technology-Based Effluent Limitations**

The following table summarizes technology-based effluent limitations established by the Order at Discharge Point 001.

**Table F-4. Summary of Technology-Based Effluent Limitations – Discharge Point 001**

Parameter	Units	Effluent Limitations	
		Average Monthly	Maximum Daily
BOD <sub>5</sub>	mg/L	60	90
TSS	mg/L	60	90
Settleable Solids	mL/L	---	0.3

**C. Water Quality-Based Effluent Limitations (WQBELs)**

**1. Scope and Authority**

NPDES regulations at 40 CFR 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards, including numeric and narrative objectives within a standard.

The process for determining “reasonable potential” and calculating WQBELs, when necessary, is intended to protect the designated uses of receiving waters as specified in the Basin Plan, and achieve applicable water quality objectives and criteria that are contained in the Basin Plan and in other applicable State and federal rules, plans, and policies, including applicable water quality criteria from the CTR and the NTR.

Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, WQBELs must be established in accordance with the requirements of 40 CFR 122.44(d)(1)(vi), using (1) USEPA criteria guidance under CWA §304 (a), supplemented where necessary by other relevant information; (2) an indicator

parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion, such as a proposed State criterion or policy interpreting the State's narrative criterion, supplemented with other relevant information.

## 2. Applicable Beneficial Uses and Water Quality Criteria and Objectives

Beneficial uses described by the Basin Plan for the Salinas Reclamation Canal are presented in section II.H of the Order. Water quality criteria applicable to this receiving water are established by the CTR, the NTR, and by the Basin Plan.

## 3. Determining the Need for WQBELs

NPDES regulations at 40 CFR 122.44 (d) require effluent limitations to control all pollutants that are or may be discharged at a level that will cause, have the reasonable potential to cause, or contribute to an excursion above any State water quality standard.

The SIP, statewide policy that became effective on May 22, 2000, establishes procedures to implement water quality criteria from the NTR and CTR and for priority, toxic pollutant objectives established in the Basin Plan. The implementation procedures of the SIP include methods to determine reasonable potential (for pollutants to cause or contribute to excursions above State water quality standards) and to establish numeric effluent limitations, if necessary, for those pollutants which show reasonable potential.

The SIP Section 1.3 requires the Central Coast Water Board to use all available valid, relevant, and representative receiving water and effluent data and information to conduct a reasonable potential analysis. The Central Coast Water Board analyzed the Discharger's data for priority pollutants and the nature of the discharge to determine if the discharge has Reasonable Potential. The RPA is based on effluent and background monitoring data collected by the Discharger on June 24, 2009, and analyzed for all CTR pollutants.

Some freshwater water quality criteria for metals are hardness dependent; i.e., as hardness decreases, the toxicity of certain metals increases and the applicable water quality criteria become correspondingly more stringent. The Discharger has not collected hardness data for the receiving water. Central Coast Water Board staff used a hardness value of 100 mg/L as a conservative estimate of the receiving water hardness to determine hardness-based criteria.

To conduct the reasonable potential analysis, the Central Coast Water Board identified the maximum observed effluent (MEC) from effluent data provided by the Discharger as well as background data (B) from the receiving water, and compared these data to the most stringent applicable water quality criterion (C) for each pollutant from the NTR, CTR, and the Basin Plan. Section 1.3 of the SIP establishes three triggers for a finding of reasonable potential.

**Trigger 1.** If the MEC is greater than C, there is reasonable potential, and an effluent limitation is required.

**Trigger 2.** If B is greater than C, and the pollutant is detected in effluent ( $MEC > ND$ ), there is reasonable potential, and an effluent limitation is required.

**Trigger 3.** After reviewing other available and relevant information, a permit writer may decide that a WQBEL is required. Such additional information may include, but is not limited to: the facility type, the discharge type, solids loading analyses, lack of dilution,

history of compliance problems, potential toxic impact of the discharge, fish tissue residue data, water quality and beneficial uses of the receiving water, CWA §303 (d) listing for the pollutant, and the presence of endangered or threatened species or their critical habitat.

Based on analysis of effluent data, the Central Coast Water Board, using methods presented in the SIP, finds that the discharge to the Salinas Reclamation Canal shows reasonable potential to cause or contribute to in-stream excursions above applicable water quality criteria for selenium and bis(2-ethylhexyl)phthalate.

The following table summarizes the RPA for each priority toxic pollutant that was detected in effluent collected on June 24, 2009. No other pollutants with applicable numeric water quality criteria from the NTR, CTR, and the Basin Plan were measured above detectable concentrations during that monitoring event.

**Table F-5. RPA Results**

Pollutant	Units	C (Basis)	MEC	B	RPA Result
Arsenic	µg/L	150 (CTR freshwater chronic aquatic life)	1.4	4.6	No
Cadmium	µg/L	2.5 (CTR freshwater chronic aquatic life)	0.12	ND	No
Chromium (III)	µg/L	207 (CTR freshwater chronic aquatic life)	3.2	2.0	No
Chromium (VI)	µg/L	11 (CTR freshwater chronic aquatic life)	2.7	1.3	No
Copper	µg/L	9.3 (CTR freshwater chronic aquatic life)	0.81	3.8	No
Lead	µg/L	3.2 (CTR freshwater chronic aquatic life)	0.23	0.37	No
Nickel	µg/L	52 (CTR freshwater chronic aquatic life)	1.2	2.1	No
Selenium	µg/L	5 (NTR criterion)	6.3	2.9	<b>Yes</b>
Zinc	µg/L	120 (CTR freshwater acute and chronic aquatic life)	23	18	No
Bis(2-Ethylhexyl)Phthalate	µg/L	1.8 (CTR Human Health for Consumption of Water & Organisms)	37	ND	<b>Yes</b>

**4. WQBEL Calculations**

If necessary, final WQBELs for selenium and bis(2-ethylhexyl)phthalate will be determined using the methods described in Section 1.4 of the SIP.

**Step 1:** For each water quality criterion/objective, an effluent concentration allowance (ECA) is calculated from the following equation to account for dilution and background levels of each pollutant.

$$ECA = C + D (C - B), \text{ where}$$

C = the applicable water quality criterion (adjusted for receiving water hardness and expressed as total recoverable metal, if necessary)

D = the dilution credit (here D = 0, as the Central Coast Water Board has no information with which to justify credit for dilution)

B = the background concentration

**Step 2:** To calculate the ECA based on an aquatic life criterion (i.e., selenium), the long-term average discharge condition (LTA) is determined by multiplying the ECA times a factor (multiplier), which adjusts the ECA to account for effluent variability. The multiplier varies depending on the coefficient of variation (CV) of the data set and whether it is an acute or chronic criterion/objective. Table 1 of the SIP provides pre-calculated values for the multipliers based on the value of the CV. When the data set contains less than 10 sample results, as is the case here, or 80 percent or more of the data are reported as non-detect (ND), the CV is set equal to 0.6. Derivation of the multipliers is presented in Section 1.4 of the SIP.

From Table 1 of the SIP, the ECA multipliers for calculating LTAs at the 99<sup>th</sup> percentile occurrence probability and the resulting LTAs are presented below.

**Table F-6. Calculation of Long-Term Averages**

Pollutant	ECA		ECA Multiplier		LTA (µg/L)	
	Acute	Chronic	Acute	Chronic	Acute	Chronic
Selenium	20	5.0	0.32	0.53	6.4	2.6

**Step 3:** WQBELs, including an average monthly effluent limitation (AMEL) and a maximum daily effluent limitation (MDEL) are calculated using the most limiting (the lowest) LTA. The LTA is multiplied times a factor that accounts for averaging periods and exceedance frequencies of the effluent limitations, and for the AMEL, the effluent monitoring frequency. Here, the sampling frequency is set equal to 4 (n = 4). The 99<sup>th</sup> percentile occurrence probability was used to determine the MDEL multiplier and a 95<sup>th</sup> percentile occurrence probability was used to determine the AMEL multiplier. Table 2 of the SIP presents the MDEL and AMEL multipliers as a function of the CV. When the data set contains less than 10 sample results, as is the case here, or when 80 percent or more of the data set is reported as non-detect (ND), the CV is set equal to 0.6. Final WQBELs for selenium are calculated as follows.

**Table F-7. Calculation of Aquatic Life WQBELs**

Pollutant	LTA	MDEL Multiplier	AMEL Multiplier	MDEL (µg/L)	AMEL (µg/L)
Selenium	2.6	3.11	1.55	8.2	4.1

**Step 4:** When the most stringent water quality criterion is a human health criterion (i.e., bis(2-ethylhexyl)phthalate), the AMEL is set equal to the ECA, and the MDEL is calculated by multiplying the ECA times the ratio of the MDEL multiplier to the AMEL multiplier. Final WQBELs for bis(2-ethylhexyl)phthalate are determined as follows.

**Table F-8. Calculation of Human Health WQBELs**

Pollutant	ECA	MDEL/AMEL Multiplier	MDEL (µg/L)	AMEL (µg/L)
Bis(2-Ethylhexyl)Phthalate	1.8	3.11/1.55 = 2.01	3.6	1.8

## 5. Whole Effluent Toxicity (WET)

Whole effluent toxicity (WET) limitations protect receiving water quality from the aggregate toxic effect of a mixture of pollutants in the effluent. WET tests measure the degree of response of exposed aquatic test organisms to an effluent. The WET approach allows for protection of the narrative “no toxics in toxic amounts” criterion while implementing numeric criteria for toxicity. There are two types of WET tests - acute and chronic. An acute toxicity test is conducted over a short time period and measures mortality. A chronic toxicity test is conducted over a longer period of time and may measure mortality, reproduction, and growth.

The Basin Plan specifies a narrative objective for toxicity, requiring that all waters be maintained free of toxic substances in concentrations that are toxic to, or which produce detrimental physiological responses in human, plant, animal, or aquatic life. Survival of aquatic organisms in surface waters subjected to a waste discharge or other controllable water quality conditions shall not be less than that for the same water body in areas unaffected by the waste discharge or for another control water.

The previous permit included effluent limitations for acute toxicity only. The effluent limitation for acute toxicity specified that the survival of test organisms exposed to 100 percent effluent shall not be significantly reduced when compared to the survival of control organisms using a t-test. The Discharger’s monitoring data for the previous permit term indicated that the results of the June 30, 2009, sampling event showed 100 percent test species survival. Chronic toxicity test results were not reported. The Order retains the effluent limitations for acute toxicity to protect the receiving water against aggregate toxic effects that may result from the discharge.

6. **pH.** The effluent limitation for pH is retained from the previous permit and is based on the Basin Plan objective for pH for all inland surface waters.
7. **Dissolved Oxygen.** The effluent limitation for dissolved oxygen is retained from the previous permit and is based on the Basin Plan objective for dissolved oxygen for all inland surface waters.
8. **Total Dissolved Solids.** The effluent limitations for total dissolved solids are retained from the previous permit. The average monthly effluent limitation (1,300 mg/L) is not based on Basin Plan objectives but is still retained in order to comply with anti-backsliding requirements established in the CWA. The maximum daily effluent limitation (1,500 mg/L) is based on the Basin Plan median groundwater objective for total dissolved solids for the Salinas River 180-foot Aquifer (Table 3-8 of the Basin Plan).
9. **Chloride.** The effluent limitation for chloride is retained from the previous permit and is based on the Basin Plan median groundwater objective for chloride for the Salinas River 180-foot Aquifer.
10. **Sulfate.** The effluent limitation for sulfate is retained from the previous permit and is based on the Basin Plan median groundwater objective for sulfate for the Salinas River 180-foot Aquifer.
11. **Boron.** The effluent limitation for boron is retained from the previous permit and is based on the Basin Plan median groundwater objective for boron for the Salinas River 180-foot Aquifer.

**12. Sodium.** The effluent limitation for sodium is retained from the previous permit and is based on the Basin Plan median groundwater objective for sodium for the Salinas River 180-foot Aquifer.

**13. Nitrate.** The effluent limitation for nitrate (as N) is retained from the previous permit.

A summary of all WQBELs applicable at Discharge Point 001 are presented in Table F-9 below.

**Table F-9. Summary of WQBELs – Discharge Point 001**

Constituent	Units	Effluent Limits	
		Average Monthly	Maximum Daily
Selenium	µg/L	4.1	8.2
Bis(2-Ethylhexyl)Phthalate	µg/L	1.8	3.6
Total Dissolved Solids (TDS)	mg/L	1300	1500
Chloride	mg/L	---	250
Sulfate	mg/L	---	600
Boron	mg/L	---	0.5
Sodium	mg/L	---	250
Nitrate (as N)	mg/L	---	10
Dissolved Oxygen	mg/L	[1]	
pH	standard units	7.0 – 8.3 at all times	
Acute Toxicity	Pass/Fail	There shall be no acute toxicity as determined by the survival of test organisms at 100 percent effluent compared to a control using a statistical t-test.	

[1] Dissolved oxygen in treated wastewater discharged at Discharge Point 001 shall not be below 5.0 mg/L.

**D. Final Effluent Limitations**

Final, technology-based and water quality-based effluent limitations established by the Order are discussed in the preceding sections of the Fact Sheet.

**1. Satisfaction of Anti-Backsliding Requirements**

The Order satisfies applicable anti-backsliding provisions of the CWA, as all limitations and requirements of the Order are at least as stringent as those of the previous permit.

CWA sections 402(o)(2) and 303(d)(4) and 40 CFR 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require that effluent limitations in a reissued permit must be as stringent as those in the previous permit, with some exceptions in which limitations may be relaxed.

**2. Satisfaction of Antidegradation Policy**

Provisions of the Order are consistent with applicable anti-degradation policy expressed by NPDES regulations at 40 CFR 131.12 and by State Water Board Resolution No. 68-16. Limitations and conditions of the Order assure maintenance of the existing quality of receiving waters and do not authorize increased rates of discharge or increased pollutant loadings to the receiving water above that authorized by the previous Order.



### **3. Stringency of Requirements for Individual Pollutants**

This Order contains both technology-based and water quality-based effluent limitations for individual pollutants. The technology-based effluent limitations consist of restrictions on BOD<sub>5</sub>, TSS, and settleable solids. Restrictions on these pollutants are discussed in Section IV.B of the Fact Sheet. This Order's technology-based pollutant restrictions implement the minimum, applicable federal technology-based requirements. In addition, this Order contains effluent limitations more stringent than the minimum federal technology-based requirements that are necessary to meet water quality standards. These limitations are not more stringent than required by the CWA.

Final, technology and water quality based effluent limitations are summarized in sections IV.B and C of this Fact Sheet.

#### **E. Interim Effluent Limitations**

The Order does not establish interim effluent limitations or schedules for compliance with final effluent limitations.

#### **F. Land Discharge Specifications**

The Order does not establish land discharge specifications.

#### **G. Reclamation Specifications**

This Order does not establish reclamation specifications.

### **V. RATIONALE FOR RECEIVING WATER LIMITATIONS**

#### **A. Surface Water**

Receiving water quality is a result of many factors, some unrelated to the discharge. This Order considers these factors and is designed to minimize the influence of the discharge on the receiving water. Specific water quality objectives established by the Basin Plan to meet this goal for all inland surface waters are included as Receiving Water Limitations in Section V.A of this Order.

#### **B. Groundwater**

Groundwater limitations established by the Order include general objectives for groundwater as well as objectives for the protection of municipal and domestic supply, in accordance with the Basin Plan.

### **VI. RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS**

NPDES regulations at 40 CFR 122.48 require that all NPDES permits specify requirements for recording and reporting monitoring results. Water Code sections 13267 and 13383 also authorize the Central Coast Water Board to require technical and monitoring reports. Rationale for the monitoring and reporting requirements contained in the Monitoring and Reporting Program (MRP), which is presented in Attachment E of this Order, is presented below.

## **A. Influent Monitoring**

The MRP does not establish influent monitoring requirements.

## **B. Effluent Monitoring**

At EFF-001, most effluent monitoring requirements remain unchanged and are retained from the previous Order. Changes in effluent monitoring are as summarized below:

- Routine effluent monitoring for selenium and bis(2-ethylhexyl)phthalate have been established to determine if reasonable potential exists for those parameters.
- Annual effluent monitoring for total ammonia, un-ionized ammonia, chlorpyrifos, copper, diazinon, *E. coli*, fecal coliform, priority organics, pesticides, and turbidity have been established to determine whether the effluent contributes to existing impairments of the receiving water, Salinas Reclamation Canal.
- Effluent monitoring for acute toxicity has been accelerated from once per permit term to annual monitoring. The receiving water is listed as impaired due to toxicity and the increase in monitoring frequency is necessary to ensure the discharge from the Facility is not contributing to the impairment.

## **C. Whole Effluent Toxicity Testing Requirements**

Whole effluent toxicity (WET) limitations protect receiving water quality from the aggregate toxic effect of a mixture of pollutants in the effluent. Acute toxicity testing measures mortality in 100 percent effluent over a short test period is conducted over a longer period of time and may measure mortality, reproduction, and or growth. As mentioned previously, this Order increases acute toxicity monitoring frequency from once per permit term to annually for Discharge Point 001.

## **D. Receiving Water Monitoring**

### **1. Surface Water**

Most receiving water and surface water monitoring requirements are unchanged and are retained from the previous Order. Changes in the receiving water monitoring are summarized below:

- The MRP establishes hardness monitoring in the receiving water for future RPA determinations.
- Routine monitoring for fecal coliform, total coliform, and enterococcus bacteria is established in the MRP.

Monitoring data collected in the Salinas Reclamation Canal at the upstream and downstream locations is described in Table F-10 below.

**Table F-10. Receiving Water Monitoring Data**

Parameter	Monitoring Data (2005-2012)		
	Units	R-001U	R-001D
		Maximum Reported	Maximum Reported
Dissolved Oxygen	mg/L	5.4	13
Temperature	°C	19	19
pH	standard units	8.2	8.6
Turbidity	NTU	70	70
Total Dissolved Solids	mg/L	1100	800
Nitrate (as N)	mg/L	27	90
Total Nitrogen (as N)	mg/L	99	28

Most maximum values were reported in 2006. The data indicate that water quality upstream and downstream of the discharge are generally consistent; however, nitrogen concentrations are increased downstream from the discharge.

**2. Groundwater**

The MRP does not establish groundwater monitoring requirements.

**E. Other Monitoring Requirements**

The MRP does not establish other monitoring requirements.

**VII. RATIONALE FOR PROVISIONS**

**A. Standard Provisions**

Standard Provisions, which apply to all NPDES permits in accordance with 40 CFR 122.41, and additional conditions applicable to specified categories of permits in accordance with 40 CFR 122.42, are provided in Attachment D to the Order.

NPDES regulations at 40 CFR 122.41(a)(1) and (b - n) establish conditions that apply to all state-issued NPDES permits. These conditions must be incorporated into the permits either expressly or by reference. If incorporated by reference, a specific citation to the regulations must be included in the Order. 40 CFR 123.25(a)(12) allows the State to omit or modify conditions to impose more stringent requirements. In accordance with 40 CFR 123.25, this Order omits federal conditions that address enforcement authority specified in 40 CFR 122.41(j)(5) and (k)(2), because the enforcement authority under the Water Code is more stringent. In lieu of these conditions, this Order incorporates by reference CWC §13387(e).

**B. Monitoring and Reporting Program (MRP) Requirements**

The Discharger shall comply with the MRP and future revisions thereto, in Attachment E of this Order.

## **C. Special Provisions**

### **1. Reopener Provisions**

The Order may be modified in accordance with the requirements set forth at 40 CFR 122 and 124, to include appropriate conditions or limits based on newly available information, or to implement any, new State water quality objectives that are approved by the USEPA. As effluent is further characterized through additional monitoring, and if a need for additional effluent limitations becomes apparent after additional effluent characterization, the Order will be reopened to incorporate such limitations.

### **2. Special Studies and Additional Monitoring Requirements**

The Order includes the requirement to conduct accelerated whole effluent toxicity monitoring upon the detection of acute toxicity in the effluent.

### **3. Best Management Practices and Pollution Prevention**

The Order does not establish requirements regarding best management practices and pollution prevention.

### **4. Construction, Operation, and Maintenance Specifications**

The Order does not establish construction, operation, or maintenance specifications.

### **5. Special Provisions for Municipal Facilities (POTWs Only)**

The Order does not establish special provisions for municipal facilities.

### **6. Other Special Provisions**

#### **a. Stormwater**

The Order does not address discharges of stormwater from the treatment and disposal site, except to require coverage by and compliance with applicable provisions of General Permit No. CAS000001 - *Waste Discharge Requirements for Discharges of Storm Water Associated with Industrial Activities Excluding Construction Activities*, if applicable.

The Facility is not required to seek coverage under Water Quality Order 97-03-DWQ, NPDES General Permit No. CAS000001 because the Facility design flow is less than 1.0 MGD.

### **7. Compliance Schedules**

The Order does not establish interim effluent limitations or schedules for compliance with final effluent limitations.

## **VIII. PUBLIC PARTICIPATION**

The Central Coast Water Board is considering the issuance of waste discharge requirements (WDRs) that will serve as a National Pollutant Discharge Elimination System (NPDES) permit for the Uni-Kool Partners Vegetable Packing Facility in Salinas. As a step in the WDR adoption

process, the Central Coast Water Board staff has developed draft WDRs. The Central Coast Water Board encourages public participation in the WDR adoption process.

#### **A. Notification of Interested Parties**

The Central Coast Water Board notified the Discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the discharge and provided them with an opportunity to submit their written comments and recommendations. Notification was provided through the following: Posting of the Public Notice at the Monterey County Courthouse in Salinas.

#### **B. Written Comments**

To be fully responded to by staff and considered by the Central Coast Water Board, written comments were to be received at the Central Coast Water Board offices by 5:00 p.m. on **March 29, 2013**. No written comments were submitted.

#### **C. Public Hearing**

The Central Coast Water Board will hold a public hearing on the draft WDRs during its regular Board meeting on the following date and time and at the following location:

Date: **May 30-31, 2013**  
Time: **8:30 a.m.**  
Location: **Central Coast Water Board  
895 Aerovista Place, Suite 101  
San Luis Obispo, CA 93401**

Interested persons are invited to attend. At the public hearing, the Central Coast Water Board will hear testimony, if any, pertinent to the discharge, WDRs, and permit. Oral testimony will be heard; however, for accuracy of the record, important testimony should be in writing.

Please be aware that dates and venues may change. Our Web address is <http://www.waterboards.ca.gov/centralcoast/> where you can access the current agenda for changes in dates and locations.

#### **D. Waste Discharge Requirements Petitions**

Any aggrieved person may petition the State Water Resources Control Board to review the decision of the Central Coast Water Board regarding the final WDRs. The petition must be submitted within 30 days of the Central Coast Water Board's action to the following address:

State Water Resources Control Board  
Office of Chief Counsel  
P.O. Box 100, 1001 I Street  
Sacramento, CA 95812-0100

#### **E. Information and Copying**

The Report of Waste Discharge (ROWD), related documents, tentative effluent limitations and special provisions, comments received, and other information are on file and may be inspected at the address above at any time between 8:00 a.m. and 5:00 p.m., Monday through Friday. Copying of documents may be arranged through the Central Coast Water Board by calling 805-549-3147.

## **F. Register of Interested Persons**

Any person interested in being placed on the mailing list for information regarding the WDRs and NPDES permit should contact the Central Coast Water Board, reference this facility, and provide a name, address, and phone number.

## **G. Additional Information**

Requests for additional information or questions regarding this order should be directed to **Katie DiSimone** at (805)542-4638 or [Katie.DiSimone@waterboards.ca.gov](mailto:Katie.DiSimone@waterboards.ca.gov) or Sheila Soderberg at (805) 549-3592 or [ssoderberg@waterboards.ca.gov](mailto:ssoderberg@waterboards.ca.gov).

S:\NPDES\NPDES Facilities\Monterey Co\Uni-kool John Street, Salinas\R3-2013-0002\FINAL R3-2013-0002.docx

**ATTACHMENT G - PRIORITY ORGANICS AND PESTICIDES**

CTR #	Constituent	CAS Number	Controlling Water Quality Criterion for Surface Waters		Criterion Quantitation Limit ug/L or noted	Suggested Test Methods
			Basis	Criterion Concentration ug/L or noted <sup>1</sup>		
<b>VOLATILE ORGANICS</b>						
28	1,1-Dichloroethane	75343	Primary MCL	5	0.5	EPA 8260B
30	1,1-Dichloroethene	75354	National Toxics Rule	0.057	0.5	EPA 8260B
41	1,1,1-Trichloroethane	71556	Primary MCL	200	0.5	EPA 8260B
42	1,1,2-Trichloroethane	79005	National Toxics Rule	0.6	0.5	EPA 8260B
37	1,1,2,2-Tetrachloroethane	79345	National Toxics Rule	0.17	0.5	EPA 8260B
75	1,2-Dichlorobenzene	95501	Taste & Odor	10	0.5	EPA 8260B
29	1,2-Dichloroethane	107062	National Toxics Rule	0.38	0.5	EPA 8260B
	cis-1,2-Dichloroethene	156592	Primary MCL	6	0.5	EPA 8260B
31	1,2-Dichloropropane	78875	Calif. Toxics Rule	0.52	0.5	EPA 8260B
101	1,2,4-Trichlorobenzene	120821	Public Health Goal	5	0.5	EPA 8260B
76	1,3-Dichlorobenzene	541731	Taste & Odor	10	0.5	EPA 8260B
32	1,3-Dichloropropene	542756	Primary MCL	0.5	0.5	EPA 8260B
77	1,4-Dichlorobenzene	106467	Primary MCL	5	0.5	EPA 8260B
17	Acrolein	107028	Aquatic Toxicity	21	2	EPA 8260B
18	Acrylonitrile	107131	National Toxics Rule	0.059	2	EPA 8260B
19	Benzene	71432	Primary MCL	1	0.5	EPA 8260B
20	Bromoform	75252	Calif. Toxics Rule	4.3	0.5	EPA 8260B
34	Bromomethane	74839	Calif. Toxics Rule	48	1	EPA 8260B
21	Carbon tetrachloride	56235	National Toxics Rule	0.25	0.5	EPA 8260B
22	Chlorobenzene (mono chlorobenzene)	108907	Taste & Odor	50	0.5	EPA 8260B
24	Chloroethane	75003	Taste & Odor	16	0.5	EPA 8260B
25	2-Chloroethyl vinyl ether	110758	Aquatic Toxicity	122 <sup>(2)</sup>	1	EPA 8260B
26	Chloroform	67663	OEHHA Cancer Risk	1.1	0.5	EPA 8260B
35	Chloromethane	74873	USEPA Health Advisory	3	0.5	EPA 8260B
23	Dibromochloromethane	124481	Calif. Toxics Rule	0.41	0.5	EPA 8260B
27	Dichlorobromomethane	75274	Calif. Toxics Rule	0.56	0.5	EPA 8260B
36	Dichloromethane	75092	Calif. Toxics Rule	4.7	0.5	EPA 8260B
33	Ethylbenzene	100414	Taste & Odor	29	0.5	EPA 8260B
88	Hexachlorobenzene	118741	Calif. Toxics Rule	0.00075	1	EPA 8260B
89	Hexachlorobutadiene	87683	National Toxics Rule	0.44	1	EPA 8260B
91	Hexachloroethane	67721	National Toxics Rule	1.9	1	EPA 8260B
94	Naphthalene	91203	USEPA IRIS	14	10	EPA 8260B
38	Tetrachloroethene	127184	National Toxics Rule	0.8	0.5	EPA 8260B

CTR #	Constituent	CAS Number	Controlling Water Quality Criterion for Surface Waters		Criterion Quantitation Limit ug/L or noted	Suggested Test Methods
			Basis	Criterion Concentration ug/L or noted <sup>1</sup>		
39	Toluene	108883	Taste & Odor	42	0.5	EPA 8260B
40	trans-1,2-Dichloroethylene	156605	Primary MCL	10	0.5	EPA 8260B
43	Trichloroethene	79016	National Toxics Rule	2.7	0.5	EPA 8260B
44	Vinyl chloride	75014	Primary MCL	0.5	0.5	EPA 8260B
	Methyl-tert-butyl ether (MTBE)	1634044	Secondary MCL	5	0.5	EPA 8260B
	Trichlorofluoromethane	75694	Primary MCL	150	5	EPA 8260B
	1,1,2-Trichloro-1,2,2-Trifluoroethane	76131	Primary MCL	1200	10	EPA 8260B
	Styrene	100425	Taste & Odor	11	0.5	EPA 8260B
	Xylenes	1330207	Taste & Odor	17	0.5	EPA 8260B
<b>SEMI-VOLATILE ORGANICS</b>						
60	1,2-Benzanthracene	56553	Calif. Toxics Rule	0.0044	5	EPA 8270C
85	1,2-Diphenylhydrazine	122667	National Toxics Rule	0.04	1	EPA 8270C
45	2-Chlorophenol	95578	Taste and Odor	0.1	2	EPA 8270C
46	2,4-Dichlorophenol	120832	Taste and Odor	0.3	1	EPA 8270C
47	2,4-Dimethylphenol	105679	Calif. Toxics Rule	540	2	EPA 8270C
49	2,4-Dinitrophenol	51285	National Toxics Rule	70	5	EPA 8270C
82	2,4-Dinitrotoluene	121142	National Toxics Rule	0.11	5	EPA 8270C
55	2,4,6-Trichlorophenol	88062	Taste and Odor	2	10	EPA 8270C
83	2,6-Dinitrotoluene	606202	USEPA IRIS	0.05	5	EPA 8270C
50	2-Nitrophenol	25154557	Aquatic Toxicity	150 <sup>(3)</sup>	10	EPA 8270C
71	2-Chloronaphthalene	91587	Aquatic Toxicity	1600 <sup>(4)</sup>	10	EPA 8270C
78	3,3'-Dichlorobenzidine	91941	National Toxics Rule	0.04	5	EPA 8270C
62	3,4-Benzofluoranthene	205992	Calif. Toxics Rule	0.0044	10	EPA 8270C
52	4-Chloro-3-methylphenol	59507	Aquatic Toxicity	30	5	EPA 8270C
48	4,6-Dinitro-2-methylphenol	534521	National Toxics Rule	13.4	10	EPA 8270C
51	4-Nitrophenol	100027	USEPA Health Advisory	60	5	EPA 8270C
69	4-Bromophenyl phenyl ether	101553	Aquatic Toxicity	122	10	EPA 8270C
72	4-Chlorophenyl phenyl ether	7005723	Aquatic Toxicity	122 <sup>(2)</sup>	5	EPA 8270C
56	Acenaphthene	83329	Taste and Odor	20	1	EPA 8270C
57	Acenaphthylene	208968	No Criteria Available		10	EPA 8270C
58	Anthracene	120127	Calif. Toxics Rule	9,600	10	EPA 8270C
59	Benzidine	92875	National Toxics Rule	0.00012	5	EPA 8270C
61	Benzo(a)pyrene (3,4-Benzopyrene)	50328	Calif. Toxics Rule	0.0044	0.1	EPA 8270C
63	Benzo(g,h,i)perylene	191242	No Criteria Available		5	EPA 8270C
64	Benzo(k)fluoranthene	207089	Calif. Toxics Rule	0.0044	2	EPA 8270C
65	Bis(2-chloroethoxy) methane	111911	No Criteria Available		5	EPA 8270C



CTR #	Constituent	CAS Number	Controlling Water Quality Criterion for Surface Waters		Criterion Quantitation Limit ug/L or noted	Suggested Test Methods
			Basis	Criterion Concentration ug/L or noted <sup>1</sup>		
66	Bis(2-chloroethyl) ether	111444	National Toxics Rule	0.031	1	EPA 8270C
67	Bis(2-chloroisopropyl) ether	39638329	Aquatic Toxicity	122 <sup>(2)</sup>	10	EPA 8270C
68	Bis(2-ethylhexyl) phthalate	117817	National Toxics Rule	1.8	3	EPA 8270C
70	Butyl benzyl phthalate	85687	Aquatic Toxicity	3 <sup>(5)</sup>	10	EPA 8270C
73	Chrysene	218019	Calif. Toxics Rule	0.0044	5	EPA 8270C
81	Di-n-butylphthalate	84742	Aquatic Toxicity	3 <sup>(5)</sup>	10	EPA 8270C
84	Di-n-octylphthalate	117840	Aquatic Toxicity	3 <sup>(5)</sup>	10	EPA 8270C
74	Dibenzo(a,h)-anthracene	53703	Calif. Toxics Rule	0.0044	0.1	EPA 8270C
79	Diethyl phthalate	84662	Aquatic Toxicity	3 <sup>(5)</sup>	2	EPA 8270C
80	Dimethyl phthalate	131113	Aquatic Toxicity	3 (5)	2	EPA 8270C
86	Fluoranthene	206440	Calif. Toxics Rule	300	10	EPA 8270C
87	Fluorene	86737	Calif. Toxics Rule	1300	10	EPA 8270C
90	Hexachlorocyclopentadiene	77474	Taste and Odor	1	1	EPA 8270C
92	Indeno(1,2,3-c,d)pyrene	193395	Calif. Toxics Rule	0.0044	0.05	EPA 8270C
93	Isophorone	78591	National Toxics Rule	8.4	1	EPA 8270C
98	N-Nitrosodiphenylamine	86306	National Toxics Rule	5	1	EPA 8270C
96	N-Nitrosodimethylamine	62759	National Toxics Rule	0.00069	5	EPA 8270C
97	N-Nitrosodi-n-propylamine	621647	Calif. Toxics Rule	0.005	5	EPA 8270C
95	Nitrobenzene	98953	National Toxics Rule	17	10	EPA 8270C
53	Pentachlorophenol	87865	Calif. Toxics Rule	0.28	0.2	EPA 8270C
99	Phenanthrene	85018	No Criteria Available		5	EPA 8270C
54	Phenol	108952	Taste and Odor	5	1	EPA 8270C
100	Pyrene	129000	Calif. Toxics Rule	960	10	EPA 8270C
<b>PESTICIDES - PCBs</b>						
110	4,4'-DDD	72548	Calif. Toxics Rule	0.00083	0.02	EPA 8081A
109	4,4'-DDE	72559	Calif. Toxics Rule	0.00059	0.01	EPA 8081A
108	4,4'-DDT	50293	Calif. Toxics Rule	0.00059	0.01	EPA 8081A
112	alpha-Endosulfan	959988	National Toxics Rule	0.056 <sup>(6)</sup>	0.02	EPA 8081A
103	alpha-Hexachlorocyclohexane (BHC)	319846	Calif. Toxics Rule	0.0039	0.01	EPA 8081A
	Alachlor	15972608	Primary MCL	2	1	EPA 8081A
102	Aldrin	309002	Calif. Toxics Rule	0.00013	0.005	EPA 8081A
113	beta-Endosulfan	33213659	Calif. Toxics Rule	0.056 <sup>(6)</sup>	0.01	EPA 8081A
104	beta-Hexachlorocyclohexane	319857	Calif. Toxics Rule	0.014	0.005	EPA 8081A
107	Chlordane	57749	Calif. Toxics Rule	0.00057	0.1	EPA 8081A
106	delta-Hexachlorocyclohexane	319868	No Criteria Available		0.005	EPA 8081A
111	Dieldrin	60571	Calif. Toxics Rule	0.00014	0.01	EPA 8081A
114	Endosulfan sulfate	1031078	Ambient Water Quality	0.056	0.05	EPA 8081A

CTR #	Constituent	CAS Number	Controlling Water Quality Criterion for Surface Waters		Criterion Quantitation Limit ug/L or noted	Suggested Test Methods
			Basis	Criterion Concentration ug/L or noted <sup>1</sup>		
115	Endrin	72208	Calif. Toxics Rule	0.036	0.01	EPA 8081A
116	Endrin Aldehyde	7421934	Calif. Toxics Rule	0.76	0.01	EPA 8081A
117	Heptachlor	76448	Calif. Toxics Rule	0.00021	0.01	EPA 8081A
118	Heptachlor Epoxide	1024573	Calif. Toxics Rule	0.0001	0.01	EPA 8081A
105	Lindane (gamma-Hexachlorocyclohexane)	58899	Calif. Toxics Rule	0.019	0.019	EPA 8081A
119	PCB-1016	12674112	Calif. Toxics Rule	0.00017 <sup>(7)</sup>	0.5	EPA 8082
120	PCB-1221	11104282	Calif. Toxics Rule	0.00017 <sup>(7)</sup>	0.5	EPA 8082
121	PCB-1232	11141165	Calif. Toxics Rule	0.00017 <sup>(7)</sup>	0.5	EPA 8082
122	PCB-1242	53469219	Calif. Toxics Rule	0.00017 <sup>(7)</sup>	0.5	EPA 8082
123	PCB-1248	12672296	Calif. Toxics Rule	0.00017 <sup>(7)</sup>	0.5	EPA 8082
124	PCB-1254	11097691	Calif. Toxics Rule	0.00017 <sup>(7)</sup>	0.5	EPA 8082
125	PCB-1260	11096825	Calif. Toxics Rule	0.00017 <sup>(7)</sup>	0.5	EPA 8082
126	Toxaphene	8001352	Calif. Toxics Rule	0.0002	0.5	EPA 8081A
	Atrazine	1912249	Public Health Goal	0.15	1	EPA 8141A
	Bentazon	25057890	Primary MCL	18	2	EPA 643/ 515.2
	Carbofuran	1563662	CDFG Hazard Assess.	0.5	5	EPA 8318
	2,4-D	94757	Primary MCL	70	10	EPA 8151A
	Dalapon	75990	Ambient Water Quality	110	10	EPA 8151A
	1,2-Dibromo-3-chloropropane (DBCP)	96128	Public Health Goal	0.0017	0.01	EPA 8260B
	Di(2-ethylhexyl)adipate	103231	USEPA IRIS	30	5	EPA 8270C
	Dinoseb	88857	Primary MCL	7	2	EPA 8151A
	Diquat	85007	Ambient Water Quality	0.5	4	EPA 8340/ 549.1/HPLC
	Endothal	145733	Primary MCL	100	45	EPA 548.1
	Ethylene Dibromide	106934	OEHHA Cancer Risk	0.0097	0.02	EPA 8260B/504
	Glyphosate	1071836	Primary MCL	700	25	HPLC/EPA 547
	Methoxychlor	72435	Public Health Goal	30	10	EPA 8081A
	Molinate (Ordram)	2212671	CDFG Hazard Assess.	13	2	EPA 634
	Oxamyl	23135220	Public Health Goal	50	20	EPA 8318/632
	Picloram	1918021	Primary MCL	500	1	EPA 8151A
	Simazine (Princep)	122349	USEPA IRIS	3.4	1	EPA 8141A
	Thiobencarb	28249776	Basin Plan Objective/ Secondary MCL	1	1	HPLC/EPA 639
16	2,3,7,8-TCDD (Dioxin)	1746016	Calif. Toxics Rule	1.30E-08	5.00E-06	EPA 8290 (HRGC) MS
	2,4,5-TP (Silvex)	93765	Ambient Water Quality	10	1	EPA 8151A
	Diazinon	333415	CDFG Hazard Assess.	0.05	0.25	EPA 8141A/GCMS
	Chlorpyrifos	2921882	CDFG Hazard Assess.	0.014	1	EPA 8141A/GCMS

CTR #	Constituent	CAS Number	Controlling Water Quality Criterion for Surface Waters		Criterion Quantitation Limit ug/L or noted	Suggested Test Methods
			Basis	Criterion Concentration ug/L or noted <sup>1</sup>		

FOOTNOTES:

(1) - The Criterion Concentrations serve only as a point of reference for the selection of the appropriate analytical method. They do not indicate a regulatory decision that the cited concentration is either necessary or sufficient for full protection of beneficial uses. Available technology may require that effluent limits be set lower than these values.

(2) - For haloethers

(3) - For nitrophenols.

(4) - For chlorinated naphthalenes.

(5) - For phthalate esters.

(6) - Criteria for sum of alpha- and beta- forms.

(7) - Criteria for sum of all PCBs.

S:\NPDES\NPDES Facilities\Monterey Co\Uni-kool John Street, Salinas\R3-2013-0002\FINAL R3-2013-0002.docx