

Chronic Violators - Summary of Enforcement Actions

Facility	Violations	Enforcement Actions	Issues
Rancho San Carlos	238	2	Salts effluent limitations are unrealistic, WDRs should be revised
Pismo Beach WWTP	149	9	Spills, effluent limitation violations. Upgrading plant.
California Mens Colony	138	10	Many spills, insufficient capacity. Upgrading plant.
Solvang WWTP	107	21	Chronic salts violations
Mission Hills	100	25	Chronic salts violations
Lompoc Correctional	82	13	Chronic pH violations
San Luis Obispo WWTP	80	18	Spills, effluent violations. Several MMPs issued.
Laguna County SD	69	29	Many small spills, some effluent limitation violations.
Santa Cruz WWTP	64	33	Many small spills, some effluent limitation violations.
Hollister Domestic WWTP	63	10	Spills, effluent violations. Updating plant
City of Santa Barbara	58	8	Spills, effluent violations. MMPs issued.
Cielo Vista	53	1	Salts effluent limitations, should consider revising WDRs
Monarch Grove	50	10	Many turbidity violations. CAO issued.
Rancho Larios	45	2	Chronic chloride violations. New WDRs require salts management plan
Soledad	41	4	Chronic salts violations. WDRs recently revised.
Meridian Vineyards	31	1	TDS, pH
Treanna Winery	25	1	Spills, TDS, pH, N, Cl violations
Wild Horse Winery	19	0	pH and TDS violations
Pacific Grove Collection	13	2	Mostly small spills
Salinas Collection	12	3	Mostly small spills
Cal Poly SLO	9	4	Spills, unauthorized discharges

Item No. 17, Attachment 4
 Enforcement Report
 July 7-8, 2005 Meeting