



California Regional Water Quality Control Board
Central Coast Region



Winston H. Hickox
*Secretary for
 Environmental
 Protection*

Internet Address: <http://www.swrcb.ca.gov/~rwqcb3>
 81 Higuera Street, Suite 200, San Luis Obispo, California 93401-5427
 Phone (805) 549-3147 • FAX (805) 543-0397

Gray Davis
Governor

November 25, 2002

David Pierson
 P.O. Box 1833
 Rancho Santa Fe, CA 92067

**NOTICE OF VIOLATION; STORM WATER PERMITTING REQUIREMENTS; GOLDIE
 LANE PROPERTY; SANTA MARGARITA; SAN LUIS OBISPO COUNTY; WDID# 3 40S319357**

Dear Mr. Pierson:

On November 8, 2002, Ryan Lodge of my staff inspected the Goldie Lane Property and found it in violation of the General Construction Storm Water Permit (Permit). While on site, Regional Board staff observed no erosion control and no sediment control. The nearby Huerhuero Creek and a nearby-unnamed creek are tributary to the Salinas River, which is currently listed on the Federal and Regional Board 303(d) List of Impaired Water Bodies for excess silt and sediment.

The Storm Water Pollution Prevention Plan (SWPPP) for your site outlines erosion and sediment controls. We were assured by Dave Williams of your staff and by staff of your consultant, EDA Design Professionals, that erosion and sediment control would be in place prior to the first rains of the season as outlined in the SWPPP. However, no erosion control and no sediment control were in place after the first rains (Photos 1, 2). Failure to implement erosion and sediment control measures is a violation of Part C.2 of the Permit.




Photo 1 – No erosion or sediment control.




Photo 2 – Gully erosion down hillside.

The access road that transverses the property is also eroding in several locations. There were no erosion or sediment controls on the roadway. As a result the road is washing away at several locations (Photos 3, 4). The road threatens to wash into the unnamed tributary to Huerhuero Creek. Steps should be taken to stabilize the road to prevent further erosion.

California Environmental Protection Agency



Pierson ACL
July 8, 2005 Meeting
Attachment No. 6




Photo 3 - Road eroding away, no erosion or sediment control.




Photo 4 - Road eroding away, no erosion or sediment control.

General Permit Section A, paragraph 6, states in part:

"At a minimum, the discharger/operator must implement an effective combination of erosion and sediment control on all disturbed areas during the rainy season. These disturbed areas include rough graded roadways, slopes, and building pads. Until permanent vegetation is established, soil cover is the most cost-effective and expeditious method to protect soil particles from detachment and transport by rainfall. Temporary soil stabilization can be the single-most important factor in reducing erosion at construction sites."

You have failed to implement an effective combination of erosion and sediment control as required by the Permit.

Violations of the General Permit constitute violation of Section 13385 of the California Water Code. Corrective action is required immediately to avoid civil liability. Regional Board staff will revisit the site within the next two weeks to ensure compliance with the Permit. The violations outlined herein and any future violations are subject to civil liability, imposed administratively by the Regional Board in an amount not to exceed ten thousand dollars (\$10,000) for each day in which the violation occurs.

Please note that correspondence to our office after December 6, 2002 should be sent to 895 Aerovista Place, Suite 101, San Luis Obispo, CA 93401.

If you have any questions regarding this matter, please call Ryan Lodge at (805) 542-4642 or Jennifer Bitting at (805) 549-3334.

Sincerely,

Roger W. Briggs
Executive Officer

cc: Todd Tognazzini
Department of Fish & Game
P.O. Box 2785
Paso Robles, CA 93447

California Environmental Protection Agency



Recycled Paper

San Luis Obispo County District Attorney
County Government Center, Room 460
San Luis Obispo, CA 93408

James Caruso
San Luis Obispo County Dept. of Planning and Building
County Government Center
San Luis Obispo, CA 93408-2040

Tim Fielder
San Luis Obispo County Code Enforcement
County Government Center
San Luis Obispo, CA 93408-2040

David Williams
P.O. Box 320
Creston, CA 93432

Jeff Emerick
EDA Design Professionals
1998 Santa Barbara Street
San Luis Obispo, CA 93401

Sarah Christie
926 J Street, Suite 416
Sacramento, CA 95814

Gordon R. Hensley
P.O. Box 6884
Los Osos, CA 93412

S:\WB\Central Watershed\Storm Water\Construction\NOVs\Creston\PiersonNOV11-19-02

