design professionals
eda
civil engineers | land surveyors | land planners

March 3, 2003

Mr. Ryan Lodge
Regional Water Quality Control Board
895 Aerovista Place, Suite 101
San Luis Obispo, Ca. 93401

Re: Pierson Goldie Lane Property - WDID #3 40S319357

Dear Ryan:

Thank you for the opportunity to show you and Jennifer Bitting the erosion control measures in effect on this property. We appreciate your suggestions on how to improve our erosion control. During our tour of the site, the following was discussed:

1. Straw wattles need to be installed on the upper access way in the area shown on the enclosed photo.

2. The silt fences located at the lower end of the site need to be removed as shown on the current SWPPP.

3. The existing on site access road that is shown on the current SWPPP does not need to be included in the "construction" area of the property because no work has been done on the road for years, it is not used for storage of materials and it does not provide necessary access to any part of the "construction" area. Instead of being administered under the Nation Wide Permit, it would fall under the Point Pollution Discharge Program. We are researching this option to see if it will simplify our coordination with County staff.

Please contact us if you have any questions or comments.

Sincerely;
eda - design professionals

Jeffrey J. Emrick, P.E., AIA

cc David Pierson
D:\LTRS\22558000\swppp rev4.wpd

1998 Sa

Item No. 18 Attachment No. 11
July 7-8, 2005 Meeting
David Pierson ACL