

ATTACHMENT A

Treana Winery Permit Monitoring and Limits Comparison

Order #							
98-17				2008-0018			
Constituent	Limit	Monitoring	Units	Limit	Guidelines	Monitoring	Units
Flow	3000	WS, Eff	gpd	10k gpd peak		Eff	gpd
Flow	2000		gpd annual avg.	4k gpd 30-day avg.		Eff	
pH	$6.5 \leq \text{pH} \leq 8.4$	Eff	mg/L		$6.5 \leq \text{pH} \leq 8.5$	WS, Eff	mg/L
TDS	620	WS, Eff	mg/L			WS, Eff	mg/L
TSS		Inf, Eff	mg/L			none	
Boron						WS	
Sodium	146	WS, Eff	mg/L			WS, Eff	mg/L
Chloride	80	WS, Eff	mg/L			WS, Eff	mg/L
Nitrate - N	4					Eff	mg/L
Sulfate	100	Eff	mg/L			Eff	mg/L
BOD ₅		Inf, Eff	mg/L	300 lbs/acre/day	100 lbs/acre/day	Eff	mg/L
TN		Inf, Eff	mg/L			Eff	mg/L
DO						Eff	mg/L
Septic tanks		depths	inches			depths	inches
Salt Brine	Zero			Zero			
Total Chlorine Residual						Eff	mg/L
1,2 Dichloroethane						Eff	mg/L
1,1 Dichloroethylene						Eff	mg/L
1,1,2 Trichloroethane						Eff	mg/L