

**STATE OF CALIFORNIA  
REGIONAL WATER QUALITY CONTROL BOARD  
CENTRAL COAST REGION**

**SUPPLEMENTAL SHEET FOR REGULAR MEETING OF DECEMBER 8-9, 2016**

Prepared December 2, 2016

**ITEM NUMBER: 9**

**SUBJECT: Revision of Waste Discharge Requirements, Reissuance of National Pollutant Discharge Elimination System General Permit No. CAG993002 for Discharges of Highly Treated Groundwater, Order No. R3-2016-0035**

**STAFF CONTACT: Jessica Taylor, 805/542-4786, Jessica.Taylor@waterboards.ca.gov  
Wastewater Permitting Engineering/Architectural Student Intern**

**DISCUSSION**

This supplemental sheet provides staff's edits to clarify and correct the permit's monitoring and reporting program requirements. Recommended edits are:

1. Page E-7, Table E-2. Effluent Monitoring – all "sample types" should be identified as "Grab" samples (the acute toxicity sample type is incorrectly identified as a "Lab" sample in the table).
2. Page E-8, Table E-4. Chronic Toxicity Test Methods – add the following footnote:  
*<sup>1</sup>Dischargers shall choose the most-sensitive species that may be expected to live in the surface water body where effluent is being discharged into.* This footnote should be added to be consistent with EPA's chronic toxicity methodology rationale.

**RECOMMENDATION**

Adopt Order No. R3-2016-0035, with recommended edits.

R:\RB3\Shared\NPDES\Treated\_GW\Item9\_Dec2016\_Supp\_Sheet\_TreatedGW\_NPDES.docx