



Central Valley Regional Water Quality Control Board

9 October 2020

Curtis Paxton, Director of Utilities
City of Vacaville
650 Merchant Street
Vacaville, CA 95688

VIA EMAIL:
Curtis.Paxton@cityofvacaville.com
CERTIFIED MAIL
7019 2280 0001 9243 5630

MINOR MODIFICATIONS TO THE CITY OF VACAVILLE, EASTERLY WASTEWATER TREATMENT PLANT, WASTE DISCHARGE REQUIREMENTS ORDER R5-2019-0049 (NPDES PERMIT CA0077691), SOLANO COUNTY

Our office received an email on 26 May 2020 from the City of Vacaville (Discharger) notifying Central Valley Regional Water Quality Control Board Staff of a typographical oversight in the Monitoring and Reporting Program, Attachment E section IX.E.1, in Waste Discharge Requirements Order R5-2019-0049 (Order). The first sentence of the above-mentioned section erroneously requires monthly sampling collected at the EFF-001 and RSW-003. This is a typographical error, as bi-monthly (every other month) sampling was intended at the above-mentioned sampling locations. Additionally, the footer in Attachment F (F-1 through F-67) is incorrectly labeled as Attachment E – Monitoring and Reporting Program and should be Attachment F – Fact Sheet. Pursuant to Code of Federal Regulations, 40 CFR 122.63(a), a minor modification of an NPDES permit is allowed to correct typographical errors. The following minor modifications are made to the Order.

1. **Attachment E- Monitoring and Reporting Program (MRP), Section IX. EFFLUENT AND RECEIVING WATER CHARACTERIZATION.** Update the text in Section IX.E.1 with the following:
 1. **Bi-Monthly Monitoring.** Bi-Monthly samples shall be collected from the effluent and upstream receiving water (Monitoring Locations EFF-001 and RSW-003) and analyzed for the constituents listed in Table E-9, below. Bi-monthly monitoring (every other month) shall be conducted for one year beginning August 2020 and the results of such monitoring shall be submitted to the Central Valley Water Board with the monthly SMR's. Each individual monitoring event shall provide representative sample results for the effluent and upstream receiving water.
2. **Attachment F – Fact Sheet, footer.** Replace the current footer on pages F-1 through F-67 with the following:

ATTACHMENT F – FACT SHEET

The corrected Order is not currently available online but can be requested by email or phone from the NPDES Permitting Contacts [webpage](#)

KARL E. LONGLEY ScD, P.E., CHAIR | PATRICK PULUPA, ESQ., EXECUTIVE OFFICER

Curtis Paxton, Director of Utilities
City of Vacaville

9 October 2020

(https://www.waterboards.ca.gov/centralvalley/water_issues/waste_to_surface_water/contacts/).

If you have any questions regarding this minor modification, please contact Jim Marshall by phone at (916) 464-4772 or [email](mailto:James.Marshall@waterboards.ca.gov) at James.Marshall@waterboards.ca.gov.

Patrick Pulupa
Executive Officer

cc:

Elizabeth Sablad, U.S. EPA, Region IX, San Francisco (email only)
Peter Kozelka, U.S. EPA, Region IX, San Francisco (email only)
Afrooz Farsimadan, California State Water Resources Control Board (email only)
Renan Jauregui, California State Water Resources Control Board (email only)
Jarma Bennett, California State Water Resources Control Board (email only)
ICIS NPDES (Sarah Torres), PG Environmental, (email only)
Mindy Boele, City of Vacaville (email only)