

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
CENTRAL VALLEY REGION

**Fresno Office**  
1685 "E" Street  
Fresno, CA 93706-2007

**Sacramento Office (Main)**  
11020 Sun Center Drive #200  
Rancho Cordova, CA 95670-6114

**Redding Office**  
364 Knollcrest Drive #205  
Redding, CA 96002

[Regional Board Website](https://www.waterboards.ca.gov/centralvalley) (<https://www.waterboards.ca.gov/centralvalley>)

---

**WASTE DISCHARGE REQUIREMENTS ORDER**  
**R5-2022-0046**

---



**ORDER INFORMATION**

Order Type(s): Waste Discharge Requirements (WDRs)  
Status: ADOPTED  
Program: Non-15 Discharge to Land  
Region 5 Office: Sacramento (Rancho Cordova)  
Discharger(s): Pilot Travel Centers, LLC  
Facility: Pilot Travel Center No. 168  
Address: 30035 County Road 8, Dunnigan  
County: Yolo  
Parcel Nos.: 52-050-80  
CIWQS Place ID: 248404  
Prior Order(s): 05-01-266

**CERTIFICATION**

I, PATRICK PULUPA, Executive Officer, hereby certify that the following is a full, true, and correct copy of the order adopted by the California Regional Water Quality Control Board, Central Valley Region, on 10 June 2022.

\_\_\_\_\_  
PATRICK PULUPA, Executive Officer

## **REGIONAL BOARD INFORMATION**

### **Sacramento Office (Main)**

Rancho Cordova, CA 95670-6114  
11020 Sun Center Drive #200  
Telephone: (916) 464-3291

### **Fresno Office**

1685 "E" Street  
Fresno, CA 93706-2007  
Telephone: (559) 445-5116

### **Redding Office**

364 Knollcrest Drive #205  
Redding, CA 96002  
Telephone: (530) 224-4845

### **[Regional Board Website](https://www.waterboards.ca.gov/centralvalley)**

(<https://www.waterboards.ca.gov/centralvalley>)

## TABLE OF CONTENTS

<b>TABLE INDEX .....</b>	<b>III</b>
<b>GLOSSARY .....</b>	<b>IV</b>
<b>FINDINGS .....</b>	<b>1</b>
Introduction .....	1
Existing Facility and Discharge .....	1
Changes to Facility .....	6
Compliance History .....	6
Site Specific Conditions .....	7
Groundwater Conditions .....	7
Legal Authority .....	11
Basin Plan Implementation .....	12
Salt and Nitrate Control Programs .....	14
Antidegradation Policy .....	14
California Environmental Quality Act.....	18
Other Regulatory Matters.....	19
Reporting Requirements .....	20
Procedural Matters.....	21
<b>REQUIREMENTS .....</b>	<b>21</b>
<b>ENFORCEMENT.....</b>	<b>30</b>
<b>ADMINISTRATIVE REVIEW.....</b>	<b>30</b>
<b>LIST OF ATTACHMENTS .....</b>	<b>30</b>
<b>ATTACHMENT A – VICINITY LOCATION MAP .....</b>	<b>31</b>
<b>ATTACHMENT B – SITE PLAN AND MONITORING WELL LOCATION MAP .....</b>	<b>32</b>
<b>ATTACHMENT C – FLOW SCHEMATIC .....</b>	<b>33</b>

<b>INFORMATION SHEET .....</b>	<b>34</b>
Background.....	34
Wastewater and Sludge Disposal .....	34
Groundwater Considerations .....	34
Antidegradation.....	36
Discharge Prohibitions, Discharge Specifications, and Provisions .....	36
Legal Effect of Rescission of Prior WDRS or Orders on Existing Violations .....	37
Reopener .....	37
<b>STANDARD PROVISIONS &amp; REPORTING REQUIREMENTS FOR WASTE DISCHARGE REQUIREMENTS 1 MARCH 1991 EDITION .....</b>	<b>38</b>

## **TABLE INDEX**

Table 1. Pond Characteristics

Table 2. Historical Average Travel Center Influent Flows, gpd

Table 3. Historical Average Restaurant and Truck Care Service Building Influent Flows,  
gpd

Table 4. Average Water Supply Quality, 2010 – 2019

Table 5. Average Wastewater Quality, 2017 - 2019

Table 6. Groundwater Quality, Pre-2013

Table 7. Total Coliform Detection Summary, Pre-2013

Table 8. Groundwater Quality, 2018 - 2020

Table 9. Total Coliform Detection Summary, 2018 - 2020

Table 10. Wastewater and Groundwater Quality Comparison

Table 11. Flow Limitations

## GLOSSARY

<b>ac</b>	Acre
<b>ac-ft</b>	Acre-feet
<b>Antidegradation Policy</b>	<i>Statement of Policy with Respect to Maintaining High Quality Water in California</i> , State Water Board Resolution 68-16.
<b>Basin Plan</b>	Water Quality Control Plan for Sacramento and San Joaquin River Basins
<b>bgs</b>	Below Ground Surface
<b>BTEX</b>	Benzene, Toluene, Ethylbenzene, and Xylene
<b>BOD<sub>5</sub></b>	Five-day Biochemical Oxygen Demand
<b>BPTC</b>	Best Practicable Treatment and Control
<b>CEQA</b>	California Environmental Quality Act, Public Resources Code section 21000 et seq.
<b>C.F.R.</b>	Code of Federal Regulations
<b>COC[s]</b>	Constituent[s] of Concern
<b>DO</b>	Dissolved Oxygen
<b>DTSC</b>	California Department of Toxic Substances Control
<b>DWR</b>	California Department of Water Resources
<b>EC</b>	Electrical Conductivity at 25° C
<b>EIR</b>	Environmental Impact Report
<b>FDS</b>	Fixed Dissolved Solids
<b>FEMA</b>	Federal Emergency Management Agency
<b>ft</b>	Feet
<b>gpd</b>	Gallons per day
<b>HAL</b>	EPA Health Advisory Level.
<b>I/I</b>	Inflow and Infiltration
<b>MRP</b>	Monitoring and Reporting Program
<b>MW</b>	Monitoring Well
<b>MCL</b>	Maximum Contaminant Level per Title 22
<b>µg/L</b>	Micrograms per liter
<b>µmhos/cm</b>	Micromhos per centimeter
<b>MG[D]</b>	Million Gallons [per Day]
<b>mg/L</b>	Milligrams per liter

<b>MTBE</b>	Methyl Tert-Butyl Ether
<b>N</b>	Nitrogen
<b>ND</b>	Non-Detect
<b>NA</b>	Not Available
<b>PQL</b>	Practical Quantitation Limit
<b>R[O]WD</b>	Report of Waste Discharge
<b>SERC</b>	State Emergency Response Commission
<b>SPRRs</b>	Standard Provisions and Reporting Requirements
<b>SSGL</b>	Site-Specific Groundwater Limitation
<b>TDS</b>	Total Dissolved Solids
<b>Title 22</b>	California Code of Regulations, Title 22
<b>Title 23</b>	California Code of Regulations, Title 23
<b>Title 27</b>	California Code of Regulations, Title 27
<b>TKN</b>	Total Kjeldahl Nitrogen
<b>T&amp;O</b>	Taste & Odor Threshold
<b>TPH</b>	Total Petroleum Hydrocarbons
<b>TTHMs</b>	Total Trihalomethanes
<b>TSS</b>	Total Suspended Solids
<b><i>Unified Guidance</i></b>	<i>Statistical Analysis of Groundwater Monitoring Data at RCRA Facilities, Unified Guidance (USEPA, 2009)</i>
<b>USEPA</b>	United States Environmental Protection Agency
<b>WDRs</b>	Waste Discharge Requirements
<b>WQO[s]</b>	Water Quality Objective[s]

## FINDINGS

The Central Valley Regional Water Quality Control Board (Central Valley Water Board) hereby finds as follows:

### Introduction

1. Pilot Travel Centers, LLC owns and operates the Pilot Travel Center No. 168 wastewater treatment facility (Facility). Hereafter, Pilot Travel Centers, LLC is referred to as the Discharger. The Facility is located at 30035 County Road 8 in Dunnigan; Assessor Parcel Number (APN) 052-050-080; Section 26, T12N, R1W, MDB&M (38°51'45.14"N, 121°57'5.10"W). The Facility's location is depicted in **Attachment A** (Vicinity Map).
2. Waste Discharge Requirements (WDRs) Order 5-01-266, adopted on 7 December 2001 by the Central Valley Water Board, prescribed requirements for wastewater discharges to percolation disposal ponds. Separate monthly average and daily maximum influent flow limits were prescribed for the travel center, former truck wash facility, and stand-alone restaurant.
3. On 20 May 2019, the Discharger submitted a Report of Waste Discharge (RWD) for regulatory coverage under the State Water Resources Control Board Order WQ 2014-0153-DWQ requesting a combined flow limit in lieu of separate flow limits as prescribed in WDRs Order 5-01-266. Additional information was submitted on 31 January 2020. The Facility does not meet the conditions of WQ 2014-0153-DWQ because the Facility receives wash water generated by activities conducted at the former truck wash facility maintenance bays.
4. The WDRs are being updated to ensure the discharge is consistent with water quality plans and polices and to reflect current treatment operations. WDRs Order 5-01-266 will be rescinded and replaced with this Order.
5. As the owner and operator, the Discharger is responsible for compliance with the waste discharge requirements prescribed in this Order.
6. Also attached is **Monitoring and Reporting Program (MRP) R5-2022-0046**, which requires monitoring and reporting for the discharge regulated under these WDRs.

### Existing Facility and Discharge

7. The Facility serves a travel center, stand-alone diner-style restaurant, and a truck care service building (former truck wash facility).
  - a. The travel center and truck care service building are located on property owned by Pilot Travel Centers, LLC. The travel center houses a convenience store, a fuel sales counter, a fast-food restaurant, showers, and restrooms. The former truck wash facility was reconfigured into a truck care service building with a service maintenance bay, providing light



mechanical services such as fluids and filter replacements. There have been no truck washing activities since June 2018.

- b. The stand-alone restaurant is located on property owned by Dunnigan Co Brands, Inc. Contractual agreements between the Discharger and Dunnigan Co Brands, Inc are in place to allow wastewater discharges from the restaurant into the treatment and disposal ponds.
8. Wastewater is generated from the following:
    - a. Travel Center: toilet facilities, showers, food preparation kitchen, and fast-food restaurant.
    - b. Stand-alone restaurant: toilet facilities and food preparation kitchen.
    - c. Truck care service building: single restroom and floor drains located at the maintenance bays.
  9. Pretreatment consists of grease traps for the kitchens and an oil/water separator for the truck care service building.
  10. The collection system is comprised of gravity sewer piping and three lift stations.
    - a. One lift station receives wastewater from the travel center,
    - b. Second lift station receives wastewater from the stand-alone restaurant, and
    - c. Third lift station receives wastewater from the truck care service building.
  11. The Facility consists of five unlined ponds for treatment and disposal. At the time WDRs Order 5-01-266 was adopted, there were only Ponds 1, 2, and 3. Ponds 4 and 5 were installed in January 2002 to operate as emergency overflow ponds. Treatment is achieved by stabilization of the organic matter by algae and bacteria. Wastewater from the travel center and stand-alone restaurant is pumped through separate metering stations, then combined prior to discharge into any one of the five ponds. Wastewater from the truck care service building is pumped only to Pond 1. Ponds 1, 2, and 3 are interconnected to ensure 2 feet (ft) of freeboard. Ponds 2 and 3 overflows into Ponds 4 and 5. A site map and process flow schematic is shown in **Attachment B** (Site Plan and Monitoring Well Location Map) and **Attachment C** (Flow Schematic), respectively.
  12. Pond characteristics are summarized in **Table 1**. Pond depth and capacity estimated at 2 ft of freeboard from the top of berm.

**Table 1. Pond Characteristics**

Parameters	Pond 1	Pond 2	Pond 3	Pond 4	Pond 5
Surface Area, sq-ft	11,000	10,000	6,000	31,000	35,000
Depth, ft	7	7	7	7	7
Capacity, MG	0.4	0.34	0.21	1.4	1.6

13. Influent flows from the travel center from 2017 through 2020 as provided in the RWD and in the monthly monitoring reports are shown in **Table 2**. Wastewater flow from the travel center is metered prior to discharge into the ponds. Flows are shown as a monthly average in gallons per day (gpd).

**Table 2. Historical Average Travel Center Influent Flows, gpd**

Month	2017	2018	2019	2020
Jan	11,580	12,780	14,764	14,575
Feb	12,073	13,025	15,066	13,565
Mar	12,582	12,845	16,895	13,175
Apr	12,320	13,265	16,955	12,763
May	13,525	13,562	17,699	12,242
Jun	14,422	14,391	18,907	14,415
Jul	13,513	14,455	21,271	13,403
Aug	13,782	15,753	18,501	12,818
Sep	12,400	19,105	17,814	13,452
Oct	13,120	20,424	18,083	14,343
Nov	12,427	26,928	15,927	11,703
Dec	12,711	15,914	17,604	12,636

14. Influent flows from the stand-alone restaurant and truck care service building from 2017 through 2020 as provided in the RWD and in the monthly monitoring reports are shown in **Table 3**. Wastewater flow from the stand-alone restaurant is metered prior to discharge into the ponds. Wastewater flow from the truck care service building is estimated based on flow metered measurements of water into the building from the supply well. Flows are shown as a monthly average in gallons per day (gpd). The previous restaurant (Oasis Grill) was replaced with a Denny's restaurant that began operations in late 2017. Due to tenant occupancy, flows from the truck care service building have historically been intermittent. There were no discharges from the truck care service building in 2017 and 2020. Based on the available flow data, wastewater from the truck care service building is less than 1 percent of the total flow discharged to the ponds.

**Table 3. Historical Average Restaurant and Truck Care Service Building Influent Flows, gpd**

Month	2017	2018		2019		2020
	Restaurant	Restaurant	Truck Care	Restaurant	Truck Care	Restaurant
Jan	0	2,376	0	2,026	35	1,248
Feb	0	2,149	0	2,309	28	1,195
Mar	0	1,884	0	1,640	88	705
Apr	0	2,172	0	1,359	39	182
May	0	2,262	0	1,755	35	550
Jun	0	2,654	184	1,738	58	899
Jul	0	3,027	94	1,691	45	484
Aug	0	2,058	80	1,702	48	302
Sep	664	1,182	105	1,629	44	289
Oct	2,992	1,152	43	1,577	38	1,044
Nov	2,705	1,543	47	1,651	67	502
Dec	2,422	1,479	27	1,474	45	36

15. Source water is provided from two water supply wells: potable water supply well (WSW) and truck wash well (TWW). WSW is the primary source water. WSW is reported to be approximately 400 ft deep, sealed to a depth of 200 ft below ground surface (bgs), and the screened interval unknown. TWW is reported to be approximately 285 ft deep, sealed to a depth of 105 feet bgs, and screened from 200 to 210 ft and from 260 to 280 ft. The water supply wells are sampled annually. Water quality data from WSW is summarized in **Table 4** for select parameters. In accordance with revised Monitoring and Reporting Program (MRP) 5-01-266, source water is also analyzed for TPH-diesel, TPH-gasoline, benzene, toluene, ethylbenzene, xylenes, and methyl tert-butyl ether (MTBE), which have been non-detect and are not included in **Table 4** below. Average concentrations were calculated based on available data collected between February 2010 through September 2019 as provided in the annual reports. Units are in mg/L, unless shown otherwise. ND denotes non-detect with the Reporting Limit shown.

**Table 4. Average Supply Water Quality, 2010-2019**

Parameter/Constituent	Average Concentration	Min/Max Concentration
EC, $\mu$ mhos/cm	548	136 / 639
TDS	318	260 / 390
Nitrate as N	2.2	1.1 / 2.7

Parameter/Constituent	Average Concentration	Min/Max Concentration
TKN	0.39	0.3 / 0.47
Total Coliform, MPN/100mL	1.6	ND, <2 / 6.8
Sodium	31	28 / 34
Chloride	20	15 / 25
Chromium, Total	0.04	ND, <0.01 / 0.05
Chromium, Hexavalent	0.04	0.03 / 0.05

16. Wastewater quality data submitted in the monitoring reports from 2017 through 2019 are shown in **Table 5** for select parameters. Concentrations below are measured in mg/L, unless otherwise shown. Parameters that have historically been detected at very low concentrations or below their respective reporting limits were omitted from the table. Annual average concentrations are shown. The maximum concentration is in parenthesis. pH is a range of data.

**Table 5. Average Wastewater Quality, 2017-2019**

Parameter/Constituents	2017 Avg (Max) Concentrations	2018 Avg (Max) Concentrations	2019 Avg (Max) Concentrations
pH, std units	8.0 – 9.6	7.5 – 9.5	8.6 – 9.8
BOD <sub>5</sub>	606 (1,090)	638 (1,140)	512 (890)
EC, µmhos/cm	1,449 (1,634)	1,395 (1,698)	1,156 (1,676)
TDS	768 (885)	977 (3,990)	1,104 (3,170)
Nitrate as N	< 0.02	< 0.05	< 0.05
TKN	136 (249)	108 (142)	101 (157)
Sodium	196 (222)	230 (541)	223 (396)
Chloride	101 (217)	308 (2,490)	387 (442)
Chromium, Total	0.0304 (0.0344)	0.0298 (0.0325)	0.0255 (0.0288)

17. Wastewater is primarily domestic waste from commercial sources, including kitchen waste and nondomestic flows from the truck care service maintenance bay. Majority of the flow from the truck care service building is domestic waste from the single restroom. Overall, the wastewater is similar in character to municipal wastewater. Based on the available data, the wastewater is considered medium to strong domestic waste (Metcalf & Eddy, 3<sup>rd</sup> Ed, Table 3-16).
18. Based on available data shown in the above **Table 5**:

- a. Average Biochemical Oxygen Demand (BOD<sub>5</sub>) concentrations range from 500 to 640 mg/L. Sporadic BOD<sub>5</sub> concentrations up to 1,200 mg/L were reported and likely from the food preparation kitchens.
  - b. The average EC and TDS concentration is approximately 1,340 µmhos/cm and 950 mg/L, respectively.
  - c. Wastewater consists of primarily organic nitrogen and ammonia.
  - d. Wastewater consists of elevated sodium concentrations. Based on laboratory data sheets, samples were diluted due to sample matrix, resulting in elevated reporting limits.
19. WDRs Order 5-01-266 required wastewater monitoring for the following constituents: MTBE; BTEX; TPH-gasoline; TPH-diesel; metals (antimony, barium, copper, lead, mercury, molybdenum, nickel, selenium, silver, thallium, vanadium, and zinc); and minerals (barium, calcium, magnesium, and potassium). For the most part, these parameters have historically been detected at very low concentrations or below their respective reporting limits and therefore omitted from **Table 5**.

### **Changes to Facility**

20. No changes to the treatment and disposal ponds are being proposed. The Discharger is requesting a combined flow limit in lieu of separate flow limits for the travel center, restaurant, and truck care service building. The water balance submitted with the RWD demonstrated a pond disposal capacity of approximately 45,900 gpd based on pond dimensions; influent flows (ranging from 17,100 to 20,580 gpd) and measurements of freeboard obtained between March 2018 through March 2019; and reasonable estimates of precipitation, evaporation, and percolation rates. A maximum influent flow not to exceed 31,000 gpd and an annual total flow of 11.3 million gallons will be prescribed to allow some flexibility of higher flows during the year.

### **Compliance History**

21. The Travel Center has been investigated for leaking underground storage tanks, Regional Board Case Number 570254. Site remediation activities began in 1981 and have included removing liquid-phase hydrocarbons (LPH) with a recovery pump in a monitoring well, using passive skimmers in monitoring wells to remove LPH, operating a soil vapor extraction system to remove total petroleum hydrocarbons (TPH), and using vacuum trucks for periodic groundwater extraction events to remove LPH and impacted groundwater. No remediation has occurred since 2009. A separate network of monitoring wells and Monitoring and Reporting Program is used to monitor groundwater conditions associated with residual hydrocarbons that have been historically observed on the site. On 24 March 2022, a letter to the Discharger from the Central Valley Regional Water Board was issued confirming completion of the site investigation and corrective

actions for the underground storage tank(s) at the site and that no further action was required. Site remediation activities are not regulated under these WDRs.

### Site Specific Conditions

22. The Facility is located on relatively flat terrain. Based on boring logs, soils in the area of the ponds primarily consist of a silty clay with varying minor amounts of sand. Near surface soils in the vicinity of the Facility are generally comprised of Rg Rincon silty clay loam.
23. The Federal Emergency Management Agency (FEMA) designates the location of the Facility as an "Area of Minimal Flood Hazard", Flood Zone X.
24. The nearest California Irrigation Management Information System (CIMIS) station is the Zamora CIMIS Station (#27), approximately 6 miles to the southeast of the Facility. Based on data from the Zamora CIMIS Station, the annual average precipitation in the area is approximately 33.66 inches per year and the reference evapotranspiration is approximately 53.39 inches per year. The 100-year total annual precipitation is approximately 37.32 inches per year.
25. Local land use is primarily agricultural, rural residences, and mobile home parks. Commercial businesses, typically consisting of gas stations, restaurants, motels, and convenience stores are found along the Interstate 5 corridor. To the northeast, east of County Road 99W is the Dunnigan Wastewater Treatment Facility consisting of two lined treatment ponds and two disposal ponds.

### Groundwater Conditions

26. In September 1999, three groundwater monitoring wells ATC-1, ATC-2, and ATC-3 were installed to a depth of approximately 45 ft bgs to monitor groundwater near the treatment and disposal ponds. Well ATC-3 is located adjacent to a stormwater detention basin, which could influence water quality near this well. A fourth well, ATC-4, was installed in October 2000. Groundwater flow was known to fluctuate from the south-southeast to north-northwest, with a gradient of about 0.0001 ft/ft. Prior to 2013, available data showed groundwater at approximately 25 to 30 ft bgs with an occasional rise to 15 bgs. These wells were dry by the end of 2013. Groundwater data based on samples obtained from September 2009 through August 2013 are shown in **Table 6** for select parameters. Monitoring parameters that have historically been non-detect have been omitted from this table. Average concentrations are shown with maximum concentrations in parentheses. One half of the Reporting Limit was used to substitute non-detect results to calculate average concentrations. Units are mg/L, unless shown otherwise.

**Table 6. Groundwater Quality, Pre-2013**

<b>Constituent</b>	<b>ATC-1</b>	<b>ATC-2</b>	<b>ATC-3</b>	<b>ATC-4</b>	<b>WQO (Reference)</b>
EC, $\mu$ mhos/cm	1,411 (1,480)	1,093 (1,190)	960 (1,040)	1,730 (2,043)	700 (AG), 900 (sMCL recommended)
TDS	899 (1,530)	646 (833)	613 (833)	1,057 (1,780)	500 (sMCL recommended), 1,000 (sMCL upper)
Sodium, total	72 (170)	29 (35)	26 (22)	174 (260)	69 (AG)
Nitrate as N	9.3 (15)	15 (23)	16 (20)	4 (8)	10 (MCL)
TKN	0.7 (5.4)	0.4 (1.3)	0.5 (5.0)	4 (26)	none
Iron, total	20 (120)	7.5 (78)	10 (67)	22 (150)	0.3 (sMCL)
Manganese, total	0.4 (3.5)	0.1 (0.2)	0.1 (1.3)	1.0 (4.1)	0.05 (sMCL)
Total Coliform Organisms, MPN/100mL	2 (17)	4.4 (50)	0.9 (1.0)	3.2 (33)	2.2 (MUN)

27. EC is an indicator of salinity in groundwater. EC concentrations in all the wells are above the agricultural (AG) water quality goal of 700  $\mu$ mhos/cm. Based on available data between 1999 and 2013, concentrations were trending upwards in wells ATC-2 and ATC-4.
28. TDS concentrations in all the wells are above the recommended secondary maximum contaminant level (MCL) of 500 mg/L. Concentrations in ATC-1, ATC-3, and ATC-4 were trending downwards, while ATC-2 remain stable.
29. Nitrate as N concentrations above 10 mg/L, the primary MCL for nitrate, were observed in wells ATC-1, ATC-2, and ATC-3 with concentrations trending upwards.
30. Concentrations for sodium, iron, and manganese represent total metals. Elevated concentrations were observed and likely due to unfiltered samples being analyzed.
  - a. Sodium concentrations above the AG water quality goal of 69 mg/L were observed in wells ATC-1 and ATC-4.
  - b. Iron and manganese concentrations above the secondary MCL (sMCL) of 0.3 mg/L and 0.05 mg/L, respectively were observed in all the wells with concentrations trending upwards.
31. The Discharger does not provide active disinfection and must rely on site conditions (climate and soils) to control the persistence and transport of

pathogens into the aquifer. For the most part, total coliform organisms were non-detect, and the data shown in the above **Table 6** represent an occasional detection greater than 2.2 MPN/100mL, the water quality objective for groundwater used for domestic or municipal supply (MUN). A summary of the coliform detections based on data pre-2013 is shown in **Table 7** below.

**Table 7. Total Coliform Detection Summary, Pre-2013**

Well	Number of Data Points	Number of Non-detections	Minimum Concentration, MPN/100mL	Maximum Concentration, MPN/100mL
ATC-1	17	14	2	17
ATC-2	14	13	-	50
ATC-3	16	16	-	-
ATC-4	16	14	5	33

32. In accordance with Provision E.5.B of WDRs Order 5-01-266, the Discharger submitted a *Waste Stream and Groundwater Characterization Report* (Report). The report was to summarize analytical data of each waste stream and shallow groundwater and to indicate whether the ponds threaten or have impacted groundwater quality. If a threat to groundwater was identified, specified plans and an implementation time schedule was to be provided in a *Wastewater Facility Expansion/Pond Mitigation Plan*. The Report presented the following:
- a. Waste character was based on two waste streams: (1) a combined waste stream from the travel center and stand-alone restaurant and (2) waste stream from the former truck wash facility.
  - b. Gradient changes without clear seasonal patterns, and therefore difficult to determine if any well represents background groundwater quality.
  - c. Two approaches were used to evaluate existing groundwater quality:
    - i. The first approach compared upgradient to downgradient data results for each monitoring event based on the gradient direction on the day of sampling (event-by-event comparison, with upgradient and downgradient wells changing with each event). Discharger concluded that groundwater may have been degraded with respect to TDS, pH, and barium, and that copper and zinc have the potential to degrade groundwater quality.
    - ii. The second approach compared data results from the presumptive upgradient well ATC-2 to the presumptive downgradient well ATC-4. Based on this comparison, the Discharger concluded that groundwater quality has been degraded with respect to TDS, barium, chromium, copper, nickel, vanadium, and zinc.



- d. The Discharger speculated that previous soil contamination was from historical land uses, stormwater discharges from the adjacent freeway, and adjacent agricultural land uses have contributed to the degradation of groundwater.
  - e. The Discharger concluded that there is no evidence that the wastewater was causing degradation of the shallow groundwater.
33. In early 2018, four replacement groundwater wells ATC-1D, ATC-2D, ATC-3D, and ATC-4D were constructed to approximately 60 ft bgs. More recent data show depth to groundwater at approximately 40 to 50 ft bgs and groundwater flow to the northwest, with a gradient of about 0.001 to 0.002 ft/ft.
34. Well ATC-1D appears to be down-gradient of the ponds; well ATC-3 is up-gradient of the ponds; and wells ATC-2 and ATC-4 are cross-gradient. Groundwater data based on samples obtained from March 2018 through December 2020 are shown in **Table 8** below. Average concentrations are shown with maximum concentrations in parentheses. One half of the Reporting Limit was used to substitute non-detect results. Units are mg/L unless shown otherwise.

**Table 8. Groundwater Quality, 2018-2020**

Constituent	Down-gradient ATC-1D	Cross-gradient ATC-2D	Up-gradient ATC-3D	Cross-gradient ATC-4D	WQO (Reference)
EC, µmhos/cm	2,273 (2,560)	1,997 (2,320)	923 (1,090)	1,375 (1,530)	700 (AG), 900(sMCL recommended)
TDS	1,400 (1,500)	1,205 (1,800)	584 (820)	934 (1,000)	500 (sMCL recommended), 1,000 (sMCL upper)
Sodium	353 (390)	183 (200)	28 (35)	226 (239)	69 (AG)
Nitrate as N	0.2 (0.3)	4.3 (9.9)	13 (15)	13 (19)	10 (MCL)
TKN	0.7 (2.3)	1.0 (5.5)	0.8 (3.2)	1.1 (4.6)	None
Iron, total	71 (253)	246 (619)	168 (535)	94 (352)	0.3 (sMCL)
Manganese, total	1.0 (3.7)	3.6 (11.7)	3.4 (12)	2.8 (11)	0.05 (sMCL)
Total Coliform Organisms, MPN/100mL	18 (72)	3.6 (17)	13 (60)	152 (1,600)	2.2 (MUN)

35. EC concentrations in all the wells were above the AG water quality goal of 700 µmhos/com with downgradient EC concentrations noticeably higher than

upgradient groundwater quality. Concentrations in wells ATC-1D and ATC-3D show an increasing trend, while concentrations in ATC-2D and ATC-4D remain steady.

36. TDS concentrations in all the wells were above the recommended secondary maximum contaminant (sMCL) level of 500 mg/L with downgradient TDS concentrations noticeably higher than upgradient groundwater quality. Concentrations in wells ATC-1D and ATC-3D show an increasing trend, while concentrations in ATC-2D and ATC-4D are trending downward.
37. Nitrate as N concentrations in well ATC-1D are steady and below 10 mg/L, the primary MCL for nitrate. Concentrations in ATC-2D are below 10 mg/L and trending downward. Concentrations in ATC-3D are above 10 mg/L and trending downward. Concentrations in ATC-4D are above 10 mg/L and trending upwards. Upgradient nitrate concentrations exceed downgradient concentrations.
38. Frequent detections of total coliform above 2.2 MPN/100mL were observed in all the wells. A summary of the coliform detections based on data between 2018 through 2020 is shown in **Table 9** below.

**Table 9. Total Coliform Detection Summary, 2018 - 2020**

Well	Number of Data Points	Number of Non-detections	Minimum Concentration, MPN/100mL	Maximum Concentration, MPN/100mL
ATC-1D	11	2	2	72
ATC-2D	11	8	7	17
ATC-3D	11	5	2	17
ATC-4D	11	4	2	1,600

39. Elevated iron and manganese concentrations were observed in all the wells and trending upwards. Analysis was based on unfiltered samples and representative of total metals. Elevated concentrations are likely the result of insoluble metals present in the samples.
40. The Discharger has been monitoring groundwater for MTBE, BTEX, TPH-gasoline, and TPH-diesel on a quarterly basis since 2009. Based on available data, low concentrations or concentrations below their respective Reporting Limit have been observed since 2010.

### Legal Authority

41. This Order is adopted pursuant to Water Code section 13263, subdivision (a), which provides in pertinent part as follows:

*The regional board, after any necessary hearing, shall prescribe requirements as to the nature of any proposed discharge, existing discharge, or material change in an existing discharge..., with relation to the conditions existing in the disposal area or receiving waters upon, or into which, the discharge is made or proposed. The requirements shall implement any relevant water quality control plans that have been adopted, and shall take into consideration the beneficial uses to be protected, the water quality objectives reasonable required for that purpose, other waste discharges, the need to prevent nuisance, and the provisions of Section 13241.*

42. Compliance with section 13263, subdivision (a), including implementation of applicable water quality control plans, is discussed in the findings below.
43. The ability to discharge waste is a privilege, not a right, and adoption of this Order shall not be construed as creating a vested right to continue discharging waste. (Wat. Code, section 13263, subd. (g).)
44. This Order and its associated Monitoring and Reporting Program (MRP) are also adopted pursuant to Water Code section 13267, subdivision (b)(1), which provides as follows:

*[T]he regional board may require that any person who has discharged, discharges, or is suspected of having discharged or discharging, or who proposes to discharge waste ... shall furnish, under penalty of perjury, technical or monitoring program reports which the regional board requires. The burden, including costs, of these reports shall bear a reasonable relationship to the need for the report and the benefits to be obtained from the reports. In requiring those reports, the regional board shall provide the person with a written explanation with regard to the need for the reports, and shall identify the evidence that supports requiring that person to provide the reports.*

45. The reports required under this Order, as well as under the separately issued MRP, are necessary to verify and ensure compliance with WDRs. The burden associated with such reports is reasonable relative to the need for their submission.

### **Basin Plan Implementation**

46. Pursuant to Water Code section 13263, subdivision (a), WDRs must “implement any relevant water quality control plans, and shall take into consideration the beneficial uses to be protected, the water quality objectives reasonably required for that purpose, other waste discharges, the need to prevent nuisance, and the provisions of Section 13241.”

47. This Order implements the Central Valley Water Board's *Water Quality Control Plan for the Sacramento River and San Joaquin River Basin* (hereafter Basin Plan), which designates beneficial uses for surface water and groundwater and establishes water quality objectives (WQOs) necessary to preserve such beneficial uses. (See Wat. Code Section 13241 et seq.).
48. Local surface water drainage is to the Colusa Basin Drainage Canal, which is tributary to the Sacramento River at Knights Landing. The beneficial uses of the Colusa Basin Drain are agricultural supply (AGR); water contact recreation and canoeing and rafting (REC-1); warm and cold freshwater habitat (WARM and COLD); warm water migration (MIGR); warm water spawning, reproduction, and/or early development (SPWN); and wildlife habitat (WILD).
49. The beneficial uses of underlying groundwater as set forth in the Basin Plan are municipal and domestic supply (MUN), agricultural supply (AGR), industrial service supply (IND), and industrial process supply (PRO).
50. The Basin Plan establishes narrative WQOs for chemical constituents, taste and odors, and toxicity in groundwater. It also sets forth a numeric objective for total coliform organisms.
51. The Basin Plan's numeric water quality objective for bacteria requires that the most probable number (MPN) of coliform organisms over any seven-day period shall be less than 2.2 per 100 mL in MUN groundwater.
52. The Basin Plan's narrative WQOs for chemical constituents require MUN-designated water to at least meet the MCLs specified in California Code of Regulations, title 22 (Title 22). The Basin Plan recognizes that the Central Valley Water Board may apply limits more stringent than MCLs to ensure that waters do not contain chemical constituents in concentrations that adversely affect beneficial uses.
53. The narrative WQO for toxicity provides that groundwater shall be maintained free of toxic substances in concentrations producing detrimental physiological responses in human, animal, plant or aquatic life associated with designated beneficial uses.
54. Quantifying a narrative WQO requires a site-specific evaluation of those constituents that have the potential to impact water quality and beneficial uses. The Basin Plan states that when compliance with a narrative objective is required to protect specific beneficial uses, the Central Valley Water Board will, on a case-by-case basis, adopt numerical limitations to implement the narrative objective.
55. In the absence of specific numerical water quality limits, the Basin Plan methodology is to consider any relevant published criteria. General salt tolerance guidelines, such as *Water Quality of Agriculture* by Ayers and Westcott and similar references indicate that yield reductions in nearly all crops are not evident

when irrigation water has an electrical conductivity (EC) of less than 700  $\mu\text{mhos/cm}$ . There is, however, an eight- to ten-fold range in salt tolerance for agricultural crops and the appropriate salinity values to protect agriculture in the Central Valley are considered on a case-by-case basis. It is possible to achieve full yield potential with groundwater EC up to 3,000  $\mu\text{mhos/cm}$ , if the proper leaching fraction is provided to maintain soil salinity within the tolerance of the crop.

### **Salt and Nitrate Control Programs**

56. The Central Valley Water Board adopted Basin Plan amendments incorporating new programs for addressing ongoing salt and nitrate accumulation in the Central Valley at its 31 May 2018 Board Meeting. The Basin Plan Amendments were conditionally approved by the State Water Board on 16 October 2019 (Resolution 2019-0057) and by the Office of Administrative Law on 15 January 2020 (OAL Matter No. 2019-1203-03).
57. For the Salt Control Program, the Central Valley Water Board issued the Discharger a Notice to Comply (**CVSALTS ID: 2372**). The Discharger submitted a Notice to Intent and elected to participate in the Prioritization and Optimization Study (P&O Study) under Pathway Option 2, Alternative Salinity Permitting Approach. In the interim, to maintain existing salt discharges and minimize salinity impacts this Order does the following:
  - a. Requires the Discharger to continue efforts to control salinity in its discharges to the extent feasible; and
  - b. Sets a **Salinity Action Level of 1,700  $\mu\text{mhos/cm}$**  for the discharge of wastewater to the treatment and disposal ponds.
58. For the Nitrate Control Program, the Facility falls within the Yolo Sub-basin of the Sacramento Valley Groundwater Basin 5-021.67, a Priority 2 Basin. Notices to Comply for Priority 2 Basins will be issued within two to four years after the effective date of the Nitrate Control Program, between late 2022 and late 2024.
59. As these strategies are implemented, the Central Valley Water Board may find it necessary to modify the requirements of these WDRs to ensure the goals of the Salt and Nitrate Control Programs are met. This Order may be amended or modified to incorporate any newly applicable requirements. More information regarding this regulatory planning process can be found on the Central Valley [Water Board's CV-SALTS website](https://www.waterboards.ca.gov/centralvalley/water_issues/salinity).  
([https://www.waterboards.ca.gov/centralvalley/water\\_issues/salinity](https://www.waterboards.ca.gov/centralvalley/water_issues/salinity))

### **Antidegradation Policy**

60. The *Statement of Policy with Respect to Maintaining High Quality Waters in California*, State Water Board Resolution 68-16 (Antidegradation Policy) prohibits the Central Valley water board from authorizing degradation of "high quality water" unless it is shown that such degradation: (1) will be consistent with the

maximum benefit to the people of California; (2) will not unreasonably affect beneficial uses, or otherwise result in water quality less than as prescribed in applicable policies; and (3) is minimized through the discharger's best practicable treatment or control (BPTC).

61. Monitoring of the shallow groundwater began late 1999 with four groundwater monitoring wells. The groundwater monitoring wells have since dried and replaced with deeper wells installed in 2018. Given the unavailability of pre-1968 water quality information, compliance with the Antidegradation Policy will be determined on current groundwater quality.
62. Based on the data presented in **Table 4** (supply well), **Table 5** (wastewater quality), and **Table 8** (groundwater quality), constituents of concern (COCs) that have the potential to degrade groundwater underlying the ponds include salts (EC, TDS, sodium), nitrate as N, iron, and manganese.
63. A summary of the data as an average concentration is summarized in **Table 10** below. Effluent is shown as a range of data. Units are in mg/L unless shown otherwise. Potential Water Quality Objectives (WQO) are based on the Maximum Contaminant Level (MCL), Secondary MCL (sMCL), or Agricultural Water Quality Goals (AG). DG denotes down-gradient. CG denotes cross-gradient. UG denotes up-gradient. NA denotes not analyzed. ND denotes non-detect.

**Table 10. Wastewater and Groundwater Quality Comparison**

Parameters	Potential WQO (reference)	Supply Water	Wastewater	ATC-1D (DG)	ATC-2D (CG)	ATC-3D (UG)	ATC-4D (CG)
EC, $\mu$ mhos/cm	700 (AG), 900 (sMCL recommended)	548	1,156-1,449	2,273	1,997	923	1,375
TDS	500 (sMCL recommended), 1,000 (sMCL upper)	318	768-1,140	1,400	1,205	584	934
Sodium, total	69 (AG)	31	196-230	353	183	28	226
Nitrate as N	10 (MCL)	2.2	ND	0.2	4.3	13	13
TKN	none	NA	101-136	0.7	1.0	0.8	1.1
Iron, total	0.3 (sMCL)	NA	NA	71	246	168	94
Manganese, total	0.05 (sMCL)	NA	NA	1.0	3.6	3.4	2.8

64. **Salinity (EC and TDS).** For the purpose of evaluation, EC and TDS are representative of overall salinity. Based on available data, EC and TDS concentrations in the wastewater have been relatively stable, however they are above the AG water quality goal of 700  $\mu\text{mhos/cm}$  and recommended sMCL of 500 mg/L, respectively. In comparison to the source water quality, the discharge of wastewater has the potential to degrade groundwater with respect to salinity. Wastewater treatment and disposal is via a pond system and therefore relies on site conditions (climate and soils) to control the persistence and transport of constituents into the aquifer.

Groundwater EC and TDS concentrations are generally higher in the downgradient well in comparison to the upgradient well. However, upgradient well ATC-3D is located near a stormwater basin, which may influence water quality. Historically, EC and TDS concentrations in groundwater have exceeded their respective AG water quality goal and recommended sMCL. Based on available data in the new deeper wells, EC and TDS concentrations are trending upwards in wells ATC-1D (downgradient) and ATC-3D (up-gradient). This Order requires continued groundwater monitoring and a BPTC evaluation on improvements to the Facility.

The Discharger has elected to participate in the P&O Study under Pathway Option 2. For the protection of groundwater from discharges of wastewater, this Order establishes a **Salinity Action Level of 1,700  $\mu\text{mhos/cm}$**  as an annual average. The Salinity Action Level was based on historical wastewater data from the past six years. This Salinity Action Level is intended to prevent increases of EC and TDS concentrations in groundwater beyond current conditions. In addition, this Order requires the Discharger to continue its efforts to control and manage salinity in its discharge and comply with the new Salinity Control Program. Compliance with the Salinity Action Level shall constitute compliance with the water quality control plan and shall be deemed adequately protective of beneficial uses.

65. **Nitrate as Nitrogen.** For nutrients such as nitrate, the potential for groundwater degradation depends on wastewater quality and the ability of the vadose zone below the disposal ponds to support nitrification and denitrification to convert the nitrogen to nitrate or nitrogen gas (ammonia) before it reaches the water table.

Based on available wastewater data, total nitrogen is primarily TKN, which consists of organic nitrogen and ammonia nitrogen. TKN has the potential to mineralize and convert to nitrate (with some loss via ammonia volatilization). Nitrate as N concentrations in the wastewater have been non-detect.

Historically, nitrate as N concentrations above the primary MCL of 10 mg/L were observed in wells ATC-1, ATC-2, and ATC-3. Based on available data in the new deeper wells, concentrations in ATC-3D and ATC-4D are above 10 mg/L with an upward trend in ATC-4D. This Order requires continued groundwater monitoring for nitrate.

For the protection of groundwater quality, this Order requires the Discharger to comply with the new Nitrate Control Program to prevent increases of nitrate concentrations beyond current conditions.

66. **Total Coliform Organisms.** For coliform organisms, the potential for exceedance of the Basin Plan's numeric WQO depends on the ability of the vadose zone soils below the ponds to provide adequate filtration. The Facility does not provide active disinfection to remove pathogens in the wastewater and therefore relies on site conditions to control the persistence and transport of constituents into the aquifer. Shallow groundwater elevations in the area have dropped. Based on available data from the new deeper well, frequent detections of coliform organisms were observed. Cross contamination during subsequent sampling could result in coliform detections. As previously discussed, depth to groundwater at the new deeper wells is between 40 and 50 ft bgs. Prior to reaching the first encountered groundwater, the wastewater will percolate through approximately 40 ft of soil, which will aid in filtering out coliform organisms and prevent groundwater degradation. This Order requires continued groundwater monitoring for total coliform organisms and disinfection of the monitoring wells.
67. **Iron and Manganese.** Iron and manganese concentrations above the respective MCLs were observed in all the wells and appear to be trending upwards. As previously mentioned, analysis was based on unfiltered samples, therefore representative of total metals. Historically, monitoring did not require analysis of iron and manganese in the wastewater or supply water. Elevated concentrations of iron and manganese are not anticipated to be present in the wastewater. Excessive BOD<sub>5</sub> loading rates can deplete oxygen resulting in anoxic conditions that can solubilize naturally occurring metals in the soil, such as iron and manganese. Source control of BOD<sub>5</sub> or additional pretreatment prior to discharge to the ponds can minimize reducing conditions in the soil. Provision H.1.b of this Order requires a *BPTC Evaluation and Facilities System Improvement Workplan* to minimize threat to underlying groundwater quality with respect to iron and manganese. This Order requires continued monitoring of BOD<sub>5</sub> in the wastewater and monitoring of iron and manganese in groundwater to evaluate impacts to underlying groundwater. Groundwater samples shall be filtered prior to analysis.
68. **MTBE, BTEX, TPH-gasoline, and TPH-diesel.** Based on available data, detections for MTBE, BTEX, TPH-gasoline, and TPH-diesel do not appear to have impacted groundwater as discussed in **Finding 40**. In addition, low concentrations or detections below their respective reporting limits were observed in the wastewater as discussed in **Finding 19**. Based on these findings, this Order does not require monitoring for these parameters in the wastewater and groundwater.
69. The Discharger implements, or will implement, as required by this Order, the following BPTC measures, which will minimize the extent of water quality degradation resulting from the Facility's continued operation:



- a. Compliance with the Salt and Nitrate Control Programs.
  - b. Compliance with a Salinity Action Level for EC.
  - c. Appropriate solids management practices.
  - d. Continued groundwater monitoring to monitor the potential impact of the Facility's discharge on underlying groundwater.
  - e. Use of certified operators to ensure proper operation and maintenance of the Facility systems.
70. The Discharge's implementation of the above-listed BPTC measures including an evaluation of the treatment system in accordance with **Provisions H.1.b** will minimize the extent of further water quality degradation resulting from the Facility's continued operation.
71. The Discharger's operation provides a centralized treatment and disposal solution for domestic waste from multiple commercial properties where there is no regional wastewater collection system. A centralized treatment facility far exceeds any benefits derived from commercial properties otherwise reliant on numerous concentrated individual wastewater systems, and the impacts on water quality will be substantially less. The economic prosperity of Central Valley communities and associated industry is a maximum benefit to the people of the State and provides justification for allowing the limited groundwater degradation that may occur pursuant to this Order.
72. Based on the foregoing, the adoption of this Order is consistent with the State Water Board's Antidegradation Policy.

### **California Environmental Quality Act**

73. The issuance of this Order, which prescribes requirements and monitoring of waste discharges at an existing facility, with negligible or no expansion of its existing use, is exempt from the procedural requirements of the California Environmental Quality Act (CEQA), Public Resources Code section 21000 et seq., pursuant to California Code of Regulations, title 14, section 15301 (CEQA Guidelines). The discharges authorized under this Order are substantially within parameters established under prior WDRs, particularly with respect to character and volume of discharges.
74. This Order is further exempt from CEQA procedural requirements insofar as it is adopted for protection of the environment and does not authorize construction activities or the relaxation of standards allowing for environmental degradation, in accordance with California Code of Regulations, title 14, section 15308 (CEQA Guidelines).
75. In accordance with the California Environmental Quality Act (CEQA), Public Resources Code section 21000 et seq., Yolo County Community Development

Agency certified the 22 June 1999 Tiered Negative Declaration of Environmental Impact for the modification of the Conditional Use Permit for the expansion of the former truck service station and for a lot-line adjustment. No potentially significant impacts to water quality were identified and no mitigation measures to prevent such impacts were imposed. Compliance with these waste discharge requirements will avoid significant impacts to water quality.

### **Other Regulatory Matters**

76. Pursuant to Water Code section 106.3, subdivision (a), it is “the established policy of the state that every human being has the right to safe, clean, affordable, and accessible water adequate for human consumption, cooking, and sanitary purposes.” Although this Order is not subject to Water Code section 106.3, as it does not revise, adopt or establish a policy, regulation or grant criterion, (see § 106.3, subd. (b)), it nevertheless promotes the policy by requiring discharges to meet maximum contaminant levels (MCLs) for drinking water, which are designed to protect human health and ensure that water is safe for domestic use.
77. This Order, which prescribes WDRs for discharges of domestic sewage, commercial waste, or treated effluent from a privately owned treatment plant, is exempt from the prescriptive requirements of California Code of Regulations, title 27 (Title 27), section 20005 et seq. (See Cal. Code Regs., tit. 27, section 20090, subd. (a) - (b).)
78. This Order does not cover stormwater and other discharges that are subject to the Clean Water Act’s National Pollution Discharge Elimination System (NPDES). The Facility has a design capacity of less than 1.0 mgd and does not have a pretreatment program, therefore the Discharger is not required to obtain coverage under the Statewide General Permit for Storm Water Discharges Associated with Industrial Activities, State Water Board Order 2014-0057 DWQ, NPDES General Permit CAS000001 (Industrial General Permit) at this time.
79. On 2 May 2006, the State Water Board adopted Statewide General Waste Discharge Requirements for Sanitary Sewer Systems, State Water Board Order 2006-0003-DWQ (SSO General Order), which requires that all public agencies owning or operating sanitary sewer systems with total system lengths in excess of one mile enroll under the SSO General Order. The Facility’s collection system is privately owned, and therefore is not subject to regulation under the SSO General Order.
80. Existing DWR standards for the construction and destruction of groundwater wells, as well as any more stringent standards that are subsequently adopted, shall apply to all monitoring wells used to monitor impacts of wastewater storage or disposal governed by this Order. (see Cal. Well Stds. Bulletin 74-90 [DWR, June 1991]; Water Wells Stds. Bulletin 74-81 [DWR, Dec. 2918].)
81. Statistical data analysis methods outlined in the US EPA’s Statistical Analysis of Groundwater Monitoring Data at RCRA Facilities, Unified Guidance (Unified

Guidance) are appropriate for determining compliance with the Groundwater Limitations of this Order. Depending on the circumstances, other methods may also be appropriate.

82. Order is issued in part pursuant to Water Code section 13263, subdivision (a), which provides as follows:

*The regional board, after any necessary hearing, shall prescribe requirements as to the nature of any proposed discharge, existing discharge, or material change in an existing discharge..., with relation to the conditions existing in the disposal area ... into which, the discharge is made or proposed. The requirements shall implement any relevant water quality control plans that have been adopted, and shall take into consideration the beneficial uses to be protected, the water quality objectives reasonably required for that purpose, other waste discharges, the need to prevent nuisance, and the provisions of [Water Code] Section 13241.*

83. This Order implements the Central Valley Water Board's Basin Plan, which designates beneficial uses for surface water and groundwater and establishes water quality objectives (WQOs) necessary to preserve such beneficial uses (Wat. Code, section 13241 et seq.). Designated beneficial uses of surface water and groundwater are discussed in **Finding 48** and **Finding 49**, respectively.

84. For the purposes of the California Code of Regulations (CCR), title 23 (Title 23), section 2200, the Facility has a threat-complexity rating of 2-B, where:

- a. Threat Category "2" reflects waste discharges that can impair receiving water beneficial uses, cause short-term water quality objective violations, cause secondary drinking water standard violations, and cause nuisances; and
- b. Category "B" reflects any discharger not included in Category A that has physical, chemical, or biological treatment systems (except for septic systems with subsurface disposal), or any Class 2 or Class 3 waste management units.

85. Pursuant to Water Code section 13263, subdivision (g), the ability to discharge waste is a privilege, not a right, and adoption of this Order does not create a vested right to continue the discharge.

### **Reporting Requirements**

86. This Order is also issued in part pursuant to Water Code section 13267, subdivision (b)(1), which provides that:

*[T]he regional board may require that any person who has discharged, discharges, or is suspected of having discharged or discharging, or who proposes to discharge waste within its region*

*... shall furnish, under penalty of perjury, technical or monitoring program reports which the regional board requires. The burden, including costs, of these reports shall bear a reasonable relationship to the need for the report and the benefits to be obtained from the reports. In requiring those reports, the regional board shall provide the person with a written explanation with regard to the need for the reports, and shall identify the evidence that supports requiring that person to provide the reports.*

87. The technical reports required under this Order, as well as those required under the separately issued MRP, are necessary to ensure compliance with prescribed WDRs. Additionally, the burdens associated with such reports are reasonable relative to the need for their submission.
88. Failure to comply with the reporting requirements under this Order and the MRP may result in enforcement action pursuant to Water Code section 13268.

### **Procedural Matters**

89. All of the above information, as well as the information contained in the attached Information Sheet (incorporated herein), was considered by the Central Valley Water Board in prescribing the WDRs set forth below.
90. The discharger, interested agencies, and interested persons were notified of the Central Valley Water Board's intent to prescribe the WDRs in this Order, and provided an opportunity to submit their written views and recommendations at a public hearing. (Wat. Code, section 13167.5; Title 27, section 21730.)
91. At a public meeting, the Central Valley Water Board heard and considered all comments pertaining to the discharges regulated under this Order.
92. The Central Valley Water Board will review and revise the WDRs in this Order as necessary.

### **REQUIREMENTS**

**IT IS HEREBY ORDERED**, pursuant to Water Code sections 13263 and 13267, that the Discharger and their agents, employees and successors shall comply with the following.

#### **A. Standard Provisions**

1. Except as expressly provided herein, the Discharger shall comply with the Standard Provisions and Reporting Requirements dated 1 March 1991 (SPRRs), which are incorporated herein. This attachment and its individual paragraphs are referred to as SPRRs.

#### **B. Discharge Prohibitions**

1. Discharge of wastes to surface waters or surface water drainage courses is prohibited.

2. Discharge of waste classified as 'hazardous', as defined in the California Code of Regulations, title 22, section 66261.1 et seq., is prohibited.
3. Discharge of waste classified as 'designated', as defined in California Code of Regulations, title 22 section 13173, in a manner that causes violation of groundwater limitations, is prohibited.
4. Treatment system bypass of untreated or partially treated waste is prohibited, except as allowed by Section E.2 of the SPRRs.
5. Discharge of waste at a location or in a manner different from that described in the Findings herein is prohibited.
6. Discharge of toxic substances into any wastewater treatment system or the disposal field such that biological treatment mechanisms are disrupted is prohibited.

### C. Flow Limitations

1. The combined influent flow discharged to the treatment and disposal ponds monitored at INF-001, INF-002, and INF-003 (as defined in the MRP) shall not exceed the limits shown in **Table 11** below.

**Table 11. Flow Limitations**

Influent Flow Measurement	Influent Flow Limit
Monthly Maximum	31,000 gallons per day
Annual influent flow	11.3 million gallons

### D. Salinity Action Level

1. To comply with the Salt Control Program, the Discharger has selected the Alternative Pathway Option 2 (i.e., participate in the P&O Study). Therefore, as discussed in **Finding 64**, these WDRs establish a **Salinity Action Level of 1,700 µmhos/cm** as an annual average.
2. As part of the Annual Report required in the MRP, the Discharger shall evaluate the Facility's annual average effluent EC to the Salinity Action Level. If the Facility's discharge exceeds the Salinity Action Level, the Discharger shall submit a *Salinity Action Level Report* by **1 March** of the year following the exceedance of the Salinity Action Level. The *Salinity Action Level Report* shall, at a minimum, include the following:
  - a. An evaluation of the Facility's salinity effluent levels. This evaluation should include a discussion of any changes to the source water for the area served by the Facility, any new dischargers discharging to the Facility, any increased or changes to conservation efforts

implemented within the Facility's service area (with flow data demonstrating decreased flows to the Facility), and any other changes to Facility's collection or treatment system that could have contributed to the increased salinity concentrations.

- b. If additional time is needed to investigate the source(s) of the salinity in the Facility's discharge, the *Salinity Action Level Report* shall include a detailed work plan describing what actions the Discharger will conduct (with completion dates) to investigate the source(s) of salinity and report its findings to the Central Valley Water Board. The findings from the investigation shall be submitted to the Central Valley Water Board **no later than October 1<sup>st</sup>** of the year following the exceedance of the Salinity Action Level
- c. The *Salinity Action Level Report* shall evaluate the potential impact the increased salinity concentrations could have on underlying groundwater and downgradient users. If additional time is needed for this evaluation, the *Salinity Action Level Report* shall propose a submittal date (**no later than October 1<sup>st</sup>** of the year following the exceedance of the Salinity Action Level).

#### **E. Discharge Specifications**

1. No waste constituent shall be released, discharged, or placed where it will be released or discharged, in a concentration or in a mass that causes violation of the Groundwater Limitations of this Order.
2. Wastewater treatment, storage, and disposal shall not cause pollution or a nuisance as defined by Water Code section 13050.
3. The Discharger shall operate all systems and equipment to optimize the quality of the discharge.
4. Public contact with wastewater shall be precluded or controlled through such means as fences and signs, or acceptable alternatives.
5. The discharge shall remain within the permitted waste treatment or containment structures and conveyance structures at all times.
6. Objectionable odors shall not be perceivable beyond the limits of the property boundary at an intensity that creates or threaten to create nuisance conditions.
7. As a means of ensuring compliance with Discharge Specification E.6, the dissolved oxygen (DO) content in the upper one foot of any wastewater treatment or storage pond shall not be less than 1.0 mg/L for three consecutive sampling events. Notwithstanding the DO monitoring frequency specified in the monitoring and reporting program, if the DO in

any single pond is below 1.0 mg/L for any single sampling event and objectionable odors are perceivable beyond the property limits, the Discharger shall report the findings to the Central Valley Water Board in accordance with Section B.1 of the SPRRs. The written notification shall include a specific plan to resolve the low DO results within 30 days of the first date of violation.

8. The wastewater ponds shall be managed to prevent breeding of mosquitos or other vectors. Specifically:
  - a. An erosion control program shall be implemented to ensure that small coves and irregularities are not created around the perimeter of the water surface.
  - b. Weeds shall be minimized through control of water depth, harvesting, or herbicides.
  - c. Dead algae, vegetation, and debris shall not accumulate on the water surface.
  - d. The Discharger shall consult and coordinate with the local Mosquito Abatement District to minimize the potential for mosquito breeding as needed to supplement the above measures.
9. The Discharger shall design, construct, operate, and maintain all ponds sufficiently to protect the integrity of containment dams and berms and prevent overtopping and/or structural failure. The operating freeboard in any pond shall never be less than 2 ft (measured vertically from the lowest possible point of overflow). As a means of management and to discern compliance with this requirement, the Discharger shall install and maintain in each pond a permanent staff gauge or other suitable measurement device with calibration marks that clearly show the water level at design capacity and enable determination of available operational freeboard.
10. Wastewater treatment, storage, and disposal ponds or structures shall have sufficient capacity to accommodate allowable wastewater flow, design seasonal precipitation, and ancillary inflow and infiltration during the winter while ensuring continuous compliance with all requirements of this Order. Design seasonal precipitation shall be based on total annual precipitation using a return period of 100 years, distributed monthly in accordance with historical rainfall patterns.
11. On or about **1 October of each year**, available capacity shall at least equal the volume necessary to comply with Discharge Specifications E.9 and E.10.
12. The Discharger shall monitor sludge accumulation in the wastewater treatment/disposal ponds at least every five years beginning in 2023 and shall periodically remove sludge as necessary to maintain adequate

storage capacity. If the estimated volume of sludge in the reservoir exceeds 25 percent of the permitted pond capacity (or other approved percentage by the Executive Officer), the Discharger shall complete sludge cleanout within 12 months after the date of the estimate.

#### **F. Groundwater Limitations**

1. Release of waste constituents from any portion of the Facility shall not cause groundwater to:
  - a. Contain waste constituents that exceed either the Primary or Secondary MCLs established in Title 22 of the California Code of Regulations, excluding salinity and nitrates.
  - b. Exceed a total coliform organism level of 2.2 MPN/100 mL over any seven-day period.
  - c. Contain taste or odor-producing constituents, toxic substances, or any other constituents in concentrations that cause nuisance or adversely affect beneficial uses.

#### **G. Solids Disposal Specifications**

1. For the purpose of this Order, sludge includes the solid, semisolid, and liquid organic matter removed from wastewater treatment system. Solid waste refers to solid inorganic matter removed by screens and soil sediments from washing of unprocessed fruit or vegetables. Except for waste solids originating from meat processing, residual solids mean organic food processing byproducts such as culls, pulp, stems, leaves, and seeds that will not be subject to treatment prior to disposal or land application.
2. Residual solids shall be removed from screens, sumps, and ponds as needed to ensure optimal operation, prevent nuisance conditions, and maintain adequate storage capacity.
3. Any handling and storage of residual solids shall be controlled and contained in a manner that minimizes leachate formation and precludes infiltration of waste constituents into soils in a mass or concentration that will violate the groundwater limitations of this Order.
4. If removed from the site, residual solids shall be disposed of in a manner approved by the Executive Officer and consistent with Title 27, division 2. Removal for reuse as animal feed, or land disposal at facilities (i.e., landfills, composting facilities, soil amendment sites operated in accordance with valid waste discharge requirements issued by a Regional Water Board) will satisfy this specification.



5. Any proposed change in residual solids use or disposal practice shall be reported in writing to the Executive Officer at least 90 days in advance of the change.

## H. Provisions

1. The following reports shall be submitted pursuant to Water Code section 13267 and shall be prepared as described in Provision H.4.
  - a. By **10 December 2022**, the Discharger shall submit a *Groundwater Monitoring Well Disinfection Workplan*. The workplan shall provide detailed procedures for well disinfection and include a schedule to complete the work prior to the next sampling event. Completion of any well disinfection activities shall be reported in the quarterly monitoring reports. This Workplan shall be used following a detection of total coliforms in any groundwater monitoring well.
  - b. By **10 June 2025**, the Discharger shall submit a *BPTC Evaluation and Facilities System Improvement Workplan* to minimize threat to underlying groundwater quality with respect to salinity, nitrates, iron, and manganese. The workplan shall include an evaluation of the treatment system, propose mitigation controls to be implemented to minimize threat to water quality and include a schedule for treatment improvement activities, if applicable to be completed by **10 June 2028**, and implementation of BPTCs. The Discharger shall report **quarterly** facility progress reports until such time that the treatment improvement activities as proposed in the Workplan are complete and the proposed BPTC have been implemented. Alternatively, if it can be shown that increasing groundwater trends are the result of activities outside the Discharger's control, the report shall include justification that supports that determination.
2. If groundwater monitoring results show that the discharge of waste is causing groundwater to contain any waste constituent concentrations statistically greater than the Groundwater Limitations of this Order, **within 120 days** of the request of the Executive Officer, the Discharger shall submit a BPTC Evaluation Workplan. The workplan shall set forth the scope and schedule for a systematic and comprehensive technical evaluation of each component of the facility's waste treatment and disposal system to determine best practicable treatment and control for each waste constituent that exceeds a Groundwater Limitation. The workplan shall contain a preliminary evaluation of each component of the wastewater treatment, storage, and disposal system and propose a time schedule for completing the comprehensive technical evaluation. The schedule to complete the evaluation shall be as short as practicable and shall not exceed one year. Alternatively, if it can be shown that the increase is the result of activities outside the Discharger's control, a

technical report shall be submitted that justifies and supports that determination.

3. A discharger whose waste flow has been increasing, or is projected to increase, shall estimate when flows will reach hydraulic and treatment capacities of its treatment, collection, and disposal facilities. The projections shall be made in January, based on the last three years' average dry weather flows, peak wet weather flows and total annual flows, as appropriate. When any projection shows that capacity of any part of the facilities may be exceeded in four years, the discharger shall notify the Central Valley Water Board by 31 January.
4. In accordance with California Business and Professions Code sections 6735, 7835, and 7835.1, engineering and geologic evaluations and judgments shall be performed by or under the direction of registered professionals competent and proficient in the fields pertinent to the required activities. All technical reports specified herein that contain workplans for investigations and studies, that describe the conduct of investigations and studies, or that contain technical conclusions and recommendations concerning engineering and geology shall be prepared by or under the direction of appropriately qualified professional(s), even if not explicitly stated. Each technical report submitted by the Discharger shall bear the professional's signature and stamp.
5. The Discharger shall submit the technical reports and work plans required by this Order for consideration by the Executive Officer and incorporate comments the Executive Officer may have in a timely manner, as appropriate. Unless expressly stated otherwise in this Order, the Discharger shall proceed with all work required by the foregoing provisions by the due dates specified.
6. The Discharger shall comply with the separately issued **MRP R5-2022-0046**, and any revisions thereto as ordered by the Executive Officer. The submittal dates of Discharger self-monitoring reports shall be no later than the submittal date specified in the MRP.
7. The Discharger shall comply with all conditions of this Order, including timely submittal of technical and monitoring reports. On or before each report due date, the Discharger shall submit the specified document to the Central Valley Water Board or, if appropriate, a written report detailing compliance or noncompliance with the specific schedule date and task. If noncompliance is being reported, then the Discharger shall state the reasons for such noncompliance and provide an estimate of the date when the Discharge will be in compliance. The Discharger shall notify the Central Valley Water Board in writing when it returns to compliance with the time schedule. Violations may result in enforcement action, including Central Valley Water Board or court orders requiring corrective action or imposing civil monetary liability, or in revision or rescission of this Order.

8. The Discharger shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) that are installed or used by the Discharger to achieve compliance with the conditions of this Order. Proper operation and maintenance also include adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems that are installed by the Discharger when the operation is necessary to achieve compliance with the conditions of this Order.
9. The Discharger shall use the best practicable cost-effective control technique(s) including proper operation and maintenance, to comply with this Order.
10. Per the SPRRs, the Discharger shall report promptly to the Central Valley Water Board any material change or proposed change in the character, location, or volume of the discharge.
11. In the event that the Discharger reports toxic chemical release data to the State Emergency Response Commission (SERC) pursuant to section 313 of the "Emergency Planning and Community Right to Know Act of 1986" (42 U.S.C. section 11023), the Discharger shall also report the same information to the Central Valley Water Board within 15 days of the report to the SERC.
12. In the event of any change in control or ownership of the Facility, the Discharger must notify the succeeding owner or operator of the existence of this Order by letter, a copy of which shall be immediately forwarded to the Central Valley Water Board.
13. To assume operation as Discharger under this Order, the succeeding owner or operator must apply in writing to the Executive Officer requesting transfer of the Order. The request must contain the requesting entity's full legal name, the state of incorporation if a corporation, the name and address and telephone number of the persons responsible for contact with the Central Valley Water Board, and a statement. The statement shall comply with the signatory paragraph of SPRR B.3 and state that the new owner or operator assumes full responsibility for compliance with this Order. Failure to submit the request shall be considered a discharge without requirements, a violation of the Water Code. If approved by the Executive Officer, the transfer request will be submitted to the Central Valley Water Board for its consideration of transferring the ownership of this Order at one of its regularly scheduled meetings.
14. If the discharge to land permitted under this Order ceases, and these WDRs are no longer necessary, the Discharger must contact the Central Valley Water Board's Compliance and Enforcements Unit to discuss wastewater treatment system closure requirements prior to rescission of

this Order. Submittal of a Site Closure Plan may be required prior to rescission of this Order.

15. A copy of this Order (including Information Sheet, Attachments, and SPRRs) and the MRP, shall be kept at the Facility for reference by operating personnel. Key operating personnel shall be familiar with their contents.
16. The Central Valley Water Board will review this Order periodically and will revise requirements when necessary.

### **ENFORCEMENT**

If, in the opinion of the Executive Officer, the California American Water fail to comply with the provisions of this Order, the Executive Officer may refer this matter to the Attorney General for judicial enforcement, may issue a complaint for administrative civil liability, or may take other enforcement actions. Failure to comply with this Order may result in the assessment of Administrative Civil Liability of up to \$10,000 per violation, per day, depending on the violation, pursuant to the Water Code, including sections 13268, 13350 and 13385. The Central Valley Water Board reserves its right to take any enforcement actions authorized by law.

### **ADMINISTRATIVE REVIEW**

Any person aggrieved by this Central Valley Water Board action may petition the State Water Board for review in accordance with Water Code section 13320 and California Code of Regulations, title 23, section 2050 et seq. To be timely, the petition must be received by the State Water Board by 5:00 pm on the 30th day after the date of this Order; if the 30th day falls on a Saturday, Sunday or state holiday, the petition must be received by the State Water Board by 5:00 pm on the next business day. The law and regulations applicable to filing petitions are available on the [State Water Board website](http://www.waterboards.ca.gov/public_notices/petitions/water_quality) ([http://www.waterboards.ca.gov/public\\_notices/petitions/water\\_quality](http://www.waterboards.ca.gov/public_notices/petitions/water_quality)). Copies will also be provided upon request.

### **LIST OF ATTACHMENTS**

Attachment A – Vicinity Location Map

Attachment B – Site Plan and Monitoring Well Location Map


Attachment C – Flow Schematic

Information Sheet


Standard Provisions and Reporting Requirements

Monitoring and Reporting Program R5-2022-0046 (separate document)

### ATTACHMENT A – VICINITY LOCATION MAP




**ATTACHMENT B – SITE PLAN AND MONITORING WELL LOCATION MAP**



<p>Source:                  Report of Waste Discharge                  20 May 2019</p>	<p>Approximate Scale                  Not to Scale</p>	<p><b>SITE PLAN AND                  MONITORING WELL LOCATION MAP</b>                   Travel Pilot Center No. 168                  Yolo County</p>
--	--	--

**ATTACHMENT C – FLOW SCHEMATIC**



<p>Source:          Report of Waste Discharge          20 May 2019</p>	<p>Approximate Scale          Not to Scale</p>	<p><b>FLOW SCHEMATIC</b>          Travel Pilot Center No. 168          Yolo County</p>
--	--	--



## **INFORMATION SHEET**

### **Background**

Pilot Travel Centers, LLC owns and operates the Pilot Travel Center No. 168 wastewater treatment facility (Facility) which is located at 30035 County Road 8 in Dunnigan. The Facility consists of five unlined treatment and disposal ponds. The Facility serves a travel center, stand-alone diner-style restaurant, and a truck care service building (former truck wash facility). The travel center houses a convenience store, a fuel sales counter, a fast-food restaurant, showers, and restrooms. The Central Valley Regional Water Quality Control Board previously regulated the discharge under Waste Discharge Requirements (WDRs) Order 5-01-266.

### **Wastewater and Sludge Disposal**

The collection system is comprised of gravity sewer piping and three lift stations. One lift station receives wastewater from the travel center, a second lift station receives wastewater from the stand-alone restaurant, and a third lift station receives wastewater from the truck care service building. There are five unlined ponds for treatment and disposal. Treatment is achieved by stabilization of the organic matter by algae and bacteria. Wastewater from the travel center and stand-alone restaurant can be pumped to Ponds 1 through 5. Wastewater from the truck care service building is pumped only to Pond 1. Ponds 1, 2, and 3 are interconnected at the high-water elevation. Ponds 2 and 3 have high-water overflows into Ponds 4 and 5.


### **Groundwater Considerations**

Groundwater conditions are discussed in Findings 26 through 40 of the Order.


September 1999, a monitoring well network consisting of three wells (ATC-1, ATC-2, and ATC-3) was constructed to a depth of approximately 45 ft bgs to monitor groundwater quality near the treatment and disposal ponds. Well ATC-3 is located adjacent to a stormwater detention basin, which could influence water quality near this well. October 2000, a fourth well, ATC-4, was installed.

Groundwater data was not available between September 2013 through February 2018 due to decreasing water elevations and wells going dry. As a result, deeper wells (ATC-1D, ATC-2D, ATC-3D, and ATC-4D) were installed to a depth approximately 60 ft bgs. Groundwater trends based on available data from 2018 through 2020 for salinity (EC and TDS) and nitrates as N submitted in the 2020 Annual Groundwater Monitoring Report are shown in the figures below.


**Figure 1. EC Groundwater Trends**



**Figure 2 TDS Groundwater Trends**



**Figure 3 Nitrate as N Groundwater Trends**



### Antidegradation

Antidegradation analysis and conclusions are discussed in Finding 60 through 72 of the Order.

### Discharge Prohibitions, Discharge Specifications, and Provisions

The Order prescribes an average daily dry weather influent flow of 31,000 gpd and a maximum annual discharge up to 11.3 million gallons. The RWD included a water balance that demonstrated adequate disposal capacity based on projected flows, pond dimensions, and reasonable estimates of precipitation and evaporation.

For the Salt Control Program, the Discharger has selected to participate in the P&O Study. This Order prescribes an annual average Salinity Action Level of 1,700  $\mu\text{mhos/cm}$ , which was set based on historical average annual EC levels. This limit is to ensure the Discharge is implementing appropriate salinity measures at the Facility.

To address the increasing salinity, nitrate, iron, and manganese concentration trends observed in the groundwater monitoring wells, this Order requires the Discharger to evaluate the treatment system to improve wastewater quality and impacts to groundwater quality.

This Order does not contain a TSS effluent limit. TSS limits are technology based and not appropriate for pond systems.

This Order does not contain a total coliform effluent limit. The Facility does not provide active disinfection. Wastewater is discharged into ponds that are enclosed within a fence with proper signage to minimize public contact. The Order requires monitoring of total coliform in groundwater and disinfection of the groundwater monitoring wells.

### **Legal Effect of Rescission of Prior WDRS or Orders on Existing Violations**

The Board's rescission of prior waste discharge requirements and/or monitoring and reporting orders does not extinguish any violations that may have occurred during the time those waste discharge requirements or orders were in effect. The Central Valley Water Board reserves the right to take enforcement actions to address violations of prior prohibitions, limitations, specifications, requirements, or provisions of rescinded waste discharge requirements or orders as allowed by law.

### **Reopener**

The conditions of discharge in the Order were developed based on currently available technical information and applicable water quality laws, regulations, policies, and plans, and are intended to assure conformance with them. The Order sets limitations based on the information provided thus far. If applicable laws and regulations change, or once new information is obtained that will change the overall discharge and its potential to impact groundwater, it may be appropriate to reopen the Order.

**STANDARD PROVISIONS & REPORTING REQUIREMENTS  
FOR  
WASTE DISCHARGE REQUIREMENTS  
1 MARCH 1991 EDITION**

Duplicate signed copies of these reports shall be submitted to the Board and:

Regional Administrator  
U.S. Environmental Protection Agency  
W-5 75 Hawthorne Street San Francisco, CA 94105

State Water Resource Control Board  
Division of Water Quality  
P.O. Box 100 Sacramento, CA 95812

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
CENTRAL VALLEY REGION

STANDARD PROVISIONS AND REPORTING REQUIREMENTS  
FOR  
WASTE DISCHARGE REQUIREMENTS

1 March 1991

**A. General Provisions:**

1. The requirements prescribed herein do not authorize the commission of any act causing injury to the property of another, or protect the Discharger from liabilities under federal, state, or local laws. This Order does not convey any property rights or exclusive privileges.
2. The provisions of this Order are severable. If any provision of this Order is held invalid, the remainder of this Order shall not be affected.
3. After notice and opportunity for a hearing, this Order may be terminated or modified for cause, including, but not limited to:
  - a. Violation of any term or condition contained in this Order;
  - b. Obtaining this Order by misrepresentation, or failure to disclose fully all relevant facts;
  - c. A change in any condition that results in either a temporary or permanent need to reduce or eliminate the authorized discharge;
  - d. A material change in the character, location, or volume of discharge.
4. Before making a material change in the character, location, or volume of discharge, the discharger shall file a new Report of Waste Discharge with the Regional Board. A material change includes, but is not limited to, the following:
  - a. An increase in area or depth to be used for solid waste disposal beyond that specified in waste discharge requirements.
  - b. A significant change in disposal method, location or volume, e.g., change from land disposal to land treatment.
  - c. The addition of a major industrial, municipal or domestic waste discharge facility.
  - d. The addition of a major industrial waste discharge to a discharge of essentially domestic sewage, or the addition of a new process or product by an industrial facility resulting in a change in the character of the waste.

## Waste Discharge to Land

5. Except for material determined to be confidential in accordance with California law and regulations, all reports prepared in accordance with terms of this Order shall be available for public inspection at the offices of the Board. Data on waste discharges, water quality, geology, and hydrogeology shall not be considered confidential.
6. The discharger shall take all reasonable steps to minimize any adverse impact to the waters of the state resulting from noncompliance with this Order. Such steps shall include accelerated or additional monitoring as necessary to determine the nature and impact of the noncompliance.
7. The discharger shall maintain in good working order and operate as efficiently as possible any facility, control system, or monitoring device installed to achieve compliance with the waste discharge requirements.
8. The discharger shall permit representatives of the Regional Board (hereafter Board) and the State Water Resources Control Board, upon presentations of credentials, to:
  - a. Enter premises where wastes are treated, stored, or disposed of and facilities in which any records are kept,
  - b. Copy any records required to be kept under terms and conditions of this Order,
  - c. Inspect at reasonable hours, monitoring equipment required by this Order, and
  - d. Sample, photograph and video tape any discharge, waste, waste management unit, or monitoring device.
9. For any electrically operated equipment at the site, the failure of which would cause loss of control or containment of waste materials, or violation of this Order, the discharger shall employ safeguards to prevent loss of control over wastes. Such safeguards may include alternate power sources, standby generators, retention capacity, operating procedures, or other means.
10. The fact that it would have been necessary to halt or reduce the permitted activity in Order to maintain compliance with this Order shall not be a defense for the discharger's violations of the Order.
11. Neither the treatment nor the discharge shall create a condition of nuisance or pollution as defined by the California Water Code, Section 13050.
12. The discharge shall remain within the designated disposal area at all times.

**B. General Reporting Requirements:**

1. In the event the discharger does not comply or will be unable to comply with any prohibition or limitation of this Order for any reason, the discharger shall notify the Board by telephone at **(916) 464-3291**  
[Note: Current phone numbers for all three Regional Board offices may be found on the Central Valley Waterboards' website ([http://www.waterboards.ca.gov/centralvalley/about\\_us/contact\\_us/](http://www.waterboards.ca.gov/centralvalley/about_us/contact_us/))]  
as soon as it or its agents.

## Waste Discharge to Land

have knowledge of such noncompliance or potential for noncompliance, and shall confirm this notification in writing within **two weeks**. The written notification shall state the nature, time and cause of noncompliance, and shall include a timetable for corrective actions.

2. The discharger shall have a plan for preventing and controlling accidental discharges, and for minimizing the effect of such events.

This plan shall:

- a. Identify the possible sources of accidental loss or leakage of wastes from each waste management, treatment, or disposal facility.
- b. Evaluate the effectiveness of present waste management/treatment units and operational procedures, and identify needed changes of contingency plans.
- c. Predict the effectiveness of the proposed changes in waste management/treatment facilities and procedures and provide an implementation schedule containing interim and final dates when changes will be implemented.

The Board, after review of the plan, may establish conditions that it deems necessary to control leakages and minimize their effects.

3. All reports shall be signed by persons identified below:
  - a. For a corporation: by a principal executive officer of at least the level of senior vice-president.
  - b. For a partnership or sole proprietorship: by a general partner or the proprietor.
  - c. For a municipality, state, federal or other public agency: by either a principal executive officer or ranking elected or appointed official.
  - d. A duly authorized representative of a person designated in 3a, 3b or 3c of this requirement if;
    - (1) the authorization is made in writing by a person described in 3a, 3b or 3c of this provision;
    - (2) the authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as the position of plant manager, operator of a waste management unit, superintendent, or position of equivalent responsibility. (A duly authorized representative may thus be either a named individual or any individual occupying a named position); and
    - (3) the written authorization is submitted to the Board



Any person signing a document under this Section shall make the following certification:

“I certify under penalty of law that I have personally examined and am familiar with the information submitted in this document and all attachments and that, based on my inquiry of the those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.”

4. Technical and monitoring reports specified in this Order are requested pursuant to Section 13267 of the Water Code. Failing to furnish the reports by the specified deadlines and falsifying information in the reports, are misdemeanors that may result in assessment of civil liabilities against the discharger.
5. The discharger shall mail a copy of each monitoring report and any other reports required by this Order to:

California Regional Water Quality Control Board  
Central Valley Region  
11020 Sun Center Drive, #200  
Rancho Cordova, CA 95670-6114

Note: Current addresses for all three Regional Board offices may be found on the Central Valley Waterboard website ([http://www.waterboards.ca.gov/centralvalley/about\\_us/contact\\_us](http://www.waterboards.ca.gov/centralvalley/about_us/contact_us)) or the current address if the office relocates.

### **C. Provisions for Monitoring:**

1. All analyses shall be made in accordance with the latest edition of: (1) *Methods for Organic Chemical Analysis of Municipal and Industrial Wastewater* (EPA 600 Series) and (2) *Test Methods for Evaluating Solid Waste* (SW 846-latest edition). The test method may be modified subject to application and approval of alternate test procedures under the Code of Federal Regulations (40 CFR 136).
2. Chemical, bacteriological, and bioassay analysis shall be conducted at a laboratory certified for such analyses by the State Department of Health Services. In the event a certified laboratory is not available to the discharger, analyses performed by a noncertified laboratory will be accepted provided a Quality Assurance-Quality Control Program is instituted by the laboratory. A manual containing the steps followed in this program must be kept in the laboratory and shall be available for inspection by Board staff. The Quality Assurance-Quality Control Program must conform to EPA guidelines or to procedures approved by the Board.

Unless otherwise specified, all metals shall be reported as Total Metals.

3. The discharger shall retain records of all monitoring information, including all calibration and maintenance records, all original strip chart recordings of continuous monitoring instrumentation, copies of all reports required by this Order, and records of all data used to

## Waste Discharge to Land

complete the application for this Order. Records shall be maintained for a minimum of three years from the date of the sample, measurement, report, or application. This period may be extended during the course of any unresolved litigation regarding this discharge or when requested by the Regional Board Executive Officer.

Record of monitoring information shall include:

- a. the date, exact place, and time of sampling or measurements,
  - b. the individual(s) who performed the sampling of the measurements,
  - c. the date(s) analyses were performed,
  - d. the individual(s) who performed the analyses,
  - e. the laboratory which performed the analysis,
  - f. the analytical techniques or methods used, and
  - g. the results of such analyses.
4. All monitoring instruments and devices used by the discharger to fulfill the prescribed monitoring program shall be properly maintained and calibrated at least yearly to ensure their continued accuracy.
  5. The discharger shall maintain a written sampling program sufficient to assure compliance with the terms of this Order. Anyone performing sampling on behalf of the discharger shall be familiar with the sampling plan.
  6. The discharger shall construct all monitoring wells to meet or exceed the standards stated in the State Department of Water Resources *Bulletin 74-81* and subsequent revisions, and shall comply with the reporting provisions for wells required by Water Code Sections 13750 through 13755.22

**D. Standard Conditions for Facilities Subject to California Code of Regulations, Title 23, Division 3, Chapter 15 (Chapter 15)**

1. All classified waste management units shall be designed under the direct supervision of a California registered civil engineer or a California certified engineering geologist. Designs shall include a Construction Quality Assurance Plan, the purpose of which is to:
  - a. demonstrate that the waste management unit has been constructed according to the specifications and plans as approved by the Board.
  - b. provide quality control on the materials and construction practices used to construct the waste management unit and prevent the use of inferior products and/or materials which do not meet the approved design plans or specifications.
2. Prior to the discharge of waste to any classified waste management unit, a California registered civil engineer or a California certified engineering geologist must certify that the waste management unit meets the construction or prescriptive standards and performance goals in Chapter 15, unless an engineered alternative has been approved by the Board. In the case of an engineered alternative, the registered civil engineer or a certified engineering geologist must

## Waste Discharge to Land

certify that the waste management unit has been constructed in accordance with Board-approved plans and specifications.

3. Materials used to construct liners shall have appropriate physical and chemical properties to ensure containment of discharged wastes over the operating life, closure, and post-closure maintenance period of the waste management units.
4. Closure of each waste management unit shall be performed under the direct supervision of a California registered civil engineer or a California certified engineering geologist.

**E. Conditions Applicable to Discharge Facilities Exempted from Chapter 15 Under Section 2511**

1. If the discharger's wastewater treatment plant is publicly owned or regulated by the Public Utilities Commission, it shall be supervised and operated by persons possessing certificates of appropriate grade according to California Code of Regulations, Title 23, Division 4, Chapter 14.
2. By-pass (the intentional diversion of waste streams from any portion of a treatment facility, except diversions designed to meet variable effluent limits) is prohibited. The Board may take enforcement action against the discharger for by-pass unless:
  - a. (1) By-pass was unavoidable to prevent loss of life, personal injury, or severe property damage. (Severe property damage means substantial physical damage to property, damage to the treatment facilities that causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a by-pass. Severe property damage does not mean economic loss caused by delays in production); and
    - (2) There were no feasible alternatives to by-pass, such as the use of auxiliary treatment facilities or retention of untreated waste. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a by-pass that would otherwise occur during normal periods of equipment downtime or preventive maintenance; or
  - b. (1) by-pass is required for essential maintenance to assure efficient operation; and
    - (2) neither effluent nor receiving water limitations are exceeded; and
    - (3) the discharger notifies the Board ten days in advance.

The permittee shall submit notice of an unanticipated by-pass as required in paragraph B.1. above.

3. A discharger that wishes to establish the affirmative defense of an upset (see definition in E.6 below) in an action brought for noncompliance shall demonstrate, through properly signed, contemporaneous operating logs, or other evidence, that:

## Waste Discharge to Land

- a. an upset occurred and the cause(s) can be identified;
- b. the permitted facility was being properly operated at the time of the upset;
- c. the discharger submitted notice of the upset as required in paragraph B.1. above; and
- d. the discharger complied with any remedial measures required by waste discharge requirements.

In any enforcement proceeding, the discharger seeking to establish the occurrence of an upset has the burden of proof.

4. A discharger whose waste flow has been increasing, or is projected to increase, shall estimate when flows will reach hydraulic and treatment capacities of its treatment, collection, and disposal facilities. The projections shall be made in January, based on the last three years' average dry weather flows, peak wet weather flows and total annual flows, as appropriate. When any projection shows that capacity of any part of the facilities may be exceeded in four years, the discharger shall notify the Board by **31 January**.
5. Effluent samples shall be taken downstream of the last addition of wastes to the treatment or discharge works where a representative sample may be obtained prior to disposal. Samples shall be collected at such a point and in such a manner to ensure a representative sample of the discharge.
6. Definitions
  - a. Upset means an exceptional incident in which there is unintentional and temporary noncompliance with effluent limitations because of factors beyond the reasonable control of the Discharger. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper action.
  - b. The monthly average discharge is the total discharge by volume during a calendar month divided by the number of days in the month that the facility was discharging. This number is to be reported in gallons per day or million gallons per day.

Where less than daily sampling is required by this Order, the monthly average shall be determined by the summation of all the measured discharges by the number of days during the month when the measurements were made.
  - c. The monthly average concentration is the arithmetic mean of measurements made during the month.
  - d. The "daily maximum" **discharge** is the total discharge by volume during any day.

## Waste Discharge to Land

- e. The “daily maximum” **concentration** is the highest measurement made on any single discrete sample or composite sample.
- f. A “grab” sample is any sample collected in less than 15 minutes.
- g. Unless otherwise specified, a composite sample is a combination of individual samples collected over the specified sampling period;
  - (1) at equal time intervals, with a maximum interval of one hour
  - (2) at varying time intervals (average interval one hour or less) so that each sample represents an equal portion of the cumulative flow.

The duration of the sampling period shall be specified in the Monitoring and Reporting Program. The method of compositing shall be reported with the results.

#### 7. Annual Pretreatment Report Requirements:

Applies to dischargers required to have a Pretreatment Program as stated in waste discharge requirements.)

The annual report shall be submitted **by 28 February** and include, but not be limited to, the following items:

- a. A summary of analytical results from representative, flow-proportioned, 24-hour composite sampling of the influent and effluent for those pollutants EPA has identified under Section 307(a) of the Clean Water Act which are known or suspected to be discharged by industrial users.

The discharger is not required to sample and analyze for asbestos until EPA promulgates an applicable analytical technique under 40 CFR (Code of Federal Regulations) Part 136. Sludge shall be sampled during the same 24-hour period and analyzed for the same pollutants as the influent and effluent sampling analysis. The sludge analyzed shall be a composite sample of a minimum of 12 discrete samples taken at equal time intervals over the 24-hour period. Wastewater and sludge sampling and analysis shall be performed at least annually. The discharger shall also provide any influent, effluent or sludge monitoring data for nonpriority pollutants which may be causing or contributing to Interference, Pass Through or adversely impacting sludge quality. Sampling and analysis shall be performed in accordance with the techniques prescribed in 40 CFR Part 136 and amendments thereto.

- b. A discussion of Upset, Interference, or Pass Through incidents, if any, at the treatment plant which the discharger knows or suspects were caused by industrial users of the system. The discussion shall include the reasons why the incidents occurred, the corrective actions taken and, if known, the name and address of the industrial user(s) responsible. The discussion shall also include a review of the applicable pollutant limitations to determine whether any

## Waste Discharge to Land

additional limitations, or changes to existing requirements, may be necessary to prevent Pass Through, Interference, or noncompliance with sludge disposal requirements.

- c. The cumulative number of industrial users that the discharger has notified regarding Baseline Monitoring Reports and the cumulative number of industrial user responses.
- d. An updated list of the discharger's industrial users including their names and addresses, or a list of deletions and additions keyed to a previously submitted list. The discharger shall provide a brief explanation for each deletion. The list shall identify the industrial users subject to federal categorical standards by specifying which set(s) of standards are applicable. The list shall indicate which categorical industries, or specific pollutants from each industry, are subject to local limitations that are more stringent than the federal categorical standards. The discharger shall also list the noncategorical industrial users that are subject only to local discharge limitations. The discharger shall characterize the compliance status through the year of record of each industrial user by employing the following descriptions:
  - (1) Complied with baseline monitoring report requirements (where applicable);
  - (2) Consistently achieved compliance;
  - (3) Inconsistently achieved compliance;
  - (4) Significantly violated applicable pretreatment requirements as defined by 40 CFR 403.8(f)(2)(vii);
  - (5) Complied with schedule to achieve compliance (include the date final compliance is required);
  - (6) Did not achieve compliance and not on a compliance schedule;
  - (7) Compliance status unknown.

A report describing the compliance status of any industrial user characterized by the descriptions in items (d)(3) through (d)(7) above shall be **submitted quarterly from the annual report date** to EPA and the Board. The report shall identify the specific compliance status of each such industrial user. This quarterly reporting requirement shall commence upon issuance of this Order.

- e. A summary of the inspection and sampling activities conducted by the discharger during the past year to gather information and data regarding the industrial users. The summary shall include but not be limited to, a tabulation of categories of dischargers that were inspected and sampled; how many and how often; and incidents of noncompliance detected.

## Waste Discharge to Land

- f. A summary of the compliance and enforcement activities during the past year. The summary shall include the names and addresses of the industrial users affected by the following actions:
- (1) Warning letters or notices of violation regarding the industrial user's apparent noncompliance with federal categorical standards or local discharge limitations. For each industrial user, identify whether the apparent violation concerned the federal categorical standards or local discharge limitations;
  - (2) Administrative Orders regarding the industrial user's noncompliance with federal categorical standards or local discharge limitations. For each industrial user, identify whether the violation concerned the federal categorical standards or local discharge limitations;
  - (3) Civil actions regarding the industrial user's noncompliance with federal categorical standards or local discharge limitations. For each industrial user, identify whether the violation concerned the federal categorical standards or local discharge limitations;
  - (4) Criminal actions regarding the industrial user's noncompliance with federal categorical standards or local discharge limitations. For each industrial user, identify whether the violation concerned the federal categorical standards or local discharge limitations.
  - (5) Assessment of monetary penalties. For each industrial user identify the amount of the penalties;
  - (6) Restriction of flow to the treatment plant; or
  - (7) Disconnection from discharge to the treatment plant.
- g. A description of any significant changes in operating the pretreatment program which differ from the discharger's approved Pretreatment Program, including, but not limited to, changes concerning: the program's administrative structure; local industrial discharge limitations; monitoring program or monitoring frequencies; legal authority of enforcement policy; funding mechanisms; resource requirements; and staffing levels.
- h. A summary of the annual pretreatment budget, including the cost of pretreatment program functions and equipment purchases.
- i. A summary of public participation activities to involve and inform the public.
- j. A description of any changes in sludge disposal methods and a discussion of any concerns not described elsewhere in the report.

Duplicate signed copies of these reports shall be submitted to the Board and:

Regional Administrator  
U.S. Environmental Protection Agency W-5  
75 Hawthorne Street  
San Francisco, CA 94105

and

State Water Resource Control Board  
Division of Water Quality  
P.O. Box 100  
Sacramento, CA 95812

Revised January 2004 to update addresses and phone numbers