

**15/16 OCTOBER 2020 BOARD MEETING  
UNCONTESTED AGENDA ITEM**

**AGENDA ITEM: 22**

**SUBJECT:**

The following is a proposed permit for consideration of adoption. All agencies and dischargers concur or have offered no comments

**BOARD ACTION:**

Consideration of NPDES Permit Renewal

**BACKGROUND:**

**a. Aerojet Rocketdyne, Inc., Groundwater Extraction And Treatment Systems, ARGET, GET E/F, GET HA, GET J, GET KA, GET LA, GET LB, GET AB, White Rock GET, Sailor Bar Park GET, Golden State Water Wells and Low Threat Discharges, Sacramento County**

The permit revision is being proposed to allow increased flows at the GET KA and White Rock GET facilities to accommodate new extraction wells and provide additional treatment systems to remove perchlorate (GET KA) and N-nitrosodimethylamine (White Rock). The White Rock GET will also have another discharge point for its effluent, in this case to the headwaters of Morrison Creek. The deminimus discharge from a cooling tower servicing Building 20-019 has also been added to the permit and the discharge from Golden State supply well AC23 has been deleted. Effluent limitations, with the exceptions of increased flow have not changed.

**RECOMMENDATION:**

Adopt the NPDES Permit

**REVIEWS:**

Management Review:	Stewart Black
Legal Review:	

**BOARD MEETING LOCATION:**

Central Valley Regional Water Quality Control Board meeting  
11020 Sun Center Dr. #200  
Rancho Cordova, CA 95670

***Internet Zoom Meeting***