



Orange County's Groundwater Replenishment System


*Jason S. Dadakis
Director of Health & Regulatory Affairs
Orange County Water District
Fountain Valley, CA*

*DPR in CA Specialty Seminar
September 23, 2015*

Outline

- ▶ **Intro to OCWD & the Groundwater Replenishment System (GWRS)**
- ▶ **Source Control**
- ▶ **Monitoring & Water Quality**
 - Pathogens
 - Chemicals
 - CECs
- ▶ **Operations & Use of Critical Control Points (CCPs)**
- ▶ **Public Outreach**
- ▶ **Conclusions**

Orange County Water District (OCWD)



- OCWD, formed in 1933, is responsible for managing and protecting the Orange County groundwater basin
- OCWD covers ~350 mi² (925 km²) in the lower watershed of the Santa Ana River (SAR)
- Groundwater supply for over 2.4 million people

The Groundwater Replenishment System (GWRS)



- ▶ 100 million gallons per day (MGD) advanced water purification facility
- ▶ Influent is secondary-treated wastewater that would otherwise be discharged to the Pacific Ocean
- ▶ Provides a new 103,000 acre-feet per year source of water, which is enough water for nearly 850,000 people
- ▶ Operational since January 2008 (70 MGD)
- ▶ Initial Expansion on line in June 2015



GWRS Partnership



OCSD



OCWD

Source
Control

Sewage

Primary
Treatment

Secondary
Treatment

Advanced Water
Purification

Reuse




Source Control

- ▶ Narrative requirement in GWRS Permit & DDW GRRP Regulations
- ▶ Commitment included in OCWD-OCSD GWRS Agreement
- ▶ Testing for DDW/SWRCB-specified wastewater contaminants
 - OCSD Lab – Raw Wastewater -> Secondary Effluent (WW Methods)
 - OCWD Lab – Secondary Effluent -> GWRS Final Product (DW Methods)
- ▶ Industrial discharge permitting recognizes potable reuse
- ▶ Chemical inventory of permitted industrial dischargers
- ▶ GIS/Database of “sewershed”
- ▶ Contaminant Source Investigations
- ▶ Outreach programs to public and industry



GWRS Advanced Water Purification Process



Rationale for Treatment Process Selection

- ▶ 100% RO+AOP required for direct aquifer injection component
- ▶ Surface recharge component required >50% RO for RWQCB Basin Plan for salt & nutrient limits
- ▶ 100% RO+UV/AOP selected for multiple benefits
 - UV required for disinfection + NDMA
 - One unified treatment process for all flows
 - One common water quality for all recharge + injection
 - Greater overall salt reduction
 - Best available treatment for potable reuse




Control of Pathogenic Microorganisms

| Pathogen | Minimum Log Reduction Requirements ¹ | Pathogen Log Reduction Credits for GWRS | | | | | Total |
|--------------------------------|---|---|------------------------|----|--------|----------------------------|-------|
| | | OCS D Plant 1 | MF and Cl ₂ | RO | UV/AOP | Underground Retention Time | |
| <i>Giardia</i> cysts | 10 | 0 | 4 | 2 | 6 | 0 | 12 |
| <i>Cryptosporidium</i> oocysts | 10 | 0 | 4 | 2 | 6 | 0 | 12 |
| Viruses | 12 | 0 | 1 | 2 | 6 | 3 | 12 |

- ▶ GWRS meets or exceeds the CA DDW 12/10/10 requirements for pathogen log removals (LRVs)
- ▶ LRVs established through demonstration testing, full-scale performance documentation, and allowances in specific regulations (e.g., retention time)
- ▶ LRVs tied to operating requirements/conditions documented in required Operation Optimization Plan (OOP)

Control of Chemical Risk



- ▶ **Source control**
- ▶ **RO + UV/AOP removes/treats a wide range of chemicals**
- ▶ **Continuous online monitoring to verify performance**
 - OOP document includes response plans for excursions
 - Use historical operations as baseline
- ▶ **Regular laboratory testing for a wide range of chemicals**
 - Comprehensive organic & inorganic testing required quarterly
 - More frequent individual unit process monitoring

- ▶ **DDW helped develop Regional Board permit requirements**
- ▶ **Test Final Product Water (FPW) quarterly for 400+ targets**
 - Volatile Organic Compounds (e.g., industrial solvents)
 - Non-Volatile Synthetic Organic Compounds (e.g., pesticides)
 - Inorganics and metals (e.g., arsenic, lead, copper, nitrate)
 - Disinfection By-Products (e.g., TTHMs, HAAs, NDMA)
 - EPA Priority Pollutants
 - Pharmaceuticals and personal care products (PPCPs)
 - Endocrine Disrupting Compounds (EDCs)
- ▶ **All results below permit limits or non-detect (ND)**

Current OCWD CEC Monitoring Targets

Hormones

| Compound | Type/Use |
|------------------------------------|-----------------------------|
| 17a-Estradiol | hair loss & hormone therapy |
| 17a-ethynylestradiol | estrogen, contraceptive |
| 17b-Estradiol | human sex hormone & steroid |
| 4-androstene-3,17-dione | steroid hormone |
| Diethylstilbestrol | synthetic estrogen |
| Epitestosterone (cis-testosterone) | natural steroid |
| Equilin | horse estrogen, Premarin |
| Estriol | estrogen |
| Estrone | estrogen |
| Progesterone | steroid hormone |

Personal Care Products & Other

| Compound | Type/Use |
|--------------------------------|---------------------------|
| Aspartame | artificial sweetener |
| Bisphenol A | plasticizer |
| Caffeine | stimulant, food additive |
| N,N-diethyl-m-toluamide (DEET) | insect repellent |
| Neotame | artificial sweetener |
| Sucralose | artificial sweetener |
| Triclosan | antibacterial, antifungal |
| Tris-2-chloroethyl phosphate | flame retardant |
| NDMA | disinfection by-product |

Pharmaceuticals

| Compound | Type/Use |
|------------------|-----------------------------------|
| Acetaminophen | analgesic medicine |
| Atenolol | beta blocker |
| Azithromycin | antibiotic |
| Carbamazepine | anticonvulsant |
| Diclofenac | anti-inflammatory (Voltaren) |
| Dilantin | anti-convulsant |
| Erythromycin | antibiotic |
| Fluoxetine | anti-depression (Prozac) |
| Gemfibrozil | anti-cholesterol (Lopid) |
| Ibuprofen | anti-inflammatory (Advil, Motrin) |
| Iohexol | phase contrast media |
| Iopromide | phase contrast media |
| Meprobamate | anti-anxiety |
| Naproxen | anti-inflammatory (Aleve) |
| Primidone | anti-convulsant (Mysoline) |
| Sulfamethoxazole | antibiotic |
| Trimethoprim | bacteriostatic antibiotic |

Covers original CDPH/DDW requirements + newer SWRCB CEC monitoring requirements

GWRS CEC Monitoring Results



- ▶ **Quarterly Final Product Water (FPW) testing since 2008**
 - Hormones & other EDCs never detected (RDLs = 1-2 ng/L)
 - Quantifiable detections of PPCPs are rare
 - NDMA: a bit more frequently detected, but consistently < 10 ng/L DDW NL
- ▶ **Periodic assessments CEC removal by RO + AOP systems**
 - CEC detections rare in RO permeate, similar to FPW
 - Paired AOP testing consistently ND
 - Loss of RO salt rejection w/ membrane age appears to generally precede loss of CEC rejection

Use of Critical Control Points (CCPs)



- ▶ Hazard Analysis and Critical Control Points (HACCP) concept
 - Designed to manage process risks vs. end of product/pipe testing
 - Widely applied to food & beverage industry
 - Water supply safety management by New Zealand, Australia, and WHO
- ▶ CCPs → steps/points where controls can be applied and measured
 - Have critical operating limits (ranges)
 - Response action(s) when process outside limits
- ▶ CCPs monitored w/ (semi)continuous online analyzers
 - Provide real-time feedback to operators
 - Generate large historical datasets on process performance
- ▶ CCPs included as voluntarily element in GWRS permit-required OOP via NWRI Independent Advisory Panel recommendation
- ▶ Compliments daily/weekly lab-analyzed process control monitoring

GWRS CCPs

- ▶ MF: Cl₂, turbidity, integrity (PDT), Δpressure (TMP)
- ▶ RO: Cl₂, Turbidity, EC, TOC
- ▶ UV/AOP: UV dose, power, transmittance
- ▶ Established response to deviations via OOP


Clear CCP Response Procedures



- ▶ Bulk RO Feed & Permeate analyzed for TOC every four minutes
- ▶ Make sure operators have clear response procedures to excursions

| Response Level | ROP TOC (mg/L) | Duration | Response Type |
|----------------|----------------|----------------|--------------------|
| I | 0.10 | 1 hour | Investigate |
| II | 3.00 | 1 hour | Shutdown |
| II | 1.50 | 1 day | Shutdown |
| II | 0.50 | 4 days | Shutdown |
| II | 0.45 | 20 days | Shutdown |

TOC Response Level I Decision Matrix





EC >60 μmhos/cm (Bulk)
EC >80 μmhos/cm (Unit Specific)

Observe Response Level II:
 ≥ 3.0 mg/L for more than 1 hour
 ≥ 1.5 mg/L average for daily average
 ≥ 0.5 mg/L average for 4 days
 ≥ 0.45 mg/L average for 20 days

CCP Critical Limits

- ▶ CCP limits \neq permit limits
- ▶ Make CCP limits (or equivalent) relevant and meaningful
- ▶ Continuous online data archive allows for powerful statistical analysis
- ▶ Periodic updates to limits important as facility ages



Public Outreach Key to GWRS Implementation

- ▶ Proactive face-to-face outreach with more than 1,200 presentations, 700 tours and many news stories that resulted in:
- ▶ No active opposition and support from:
 - 100% support from cities in OCWD service area
 - 100% support from OC state and federal elected officials
 - 100% support from Chambers of Commerce & OCBC
 - Many businesses including Edison and Sempra Energy
 - All major environmental groups
 - Several health experts, medical doctors, hospitals, pharmacists and scientists
 - Several key minority leaders
 - Educational, religious, police and fire leaders
 - More than 200 community groups like Kiwanis, Rotary, etc.
 - OC Tax, AARP, OC Farm Bureau and others



Conclusions

- ▶ RO+AOP treatment is generally robust and reliable
- ▶ Commitment to source control is important
- ▶ Monitoring demonstrates & verifies performance
- ▶ CCPs can aid in reliable operations when coupled with clear response actions
- ▶ CCP limits can be updated periodically to remain relevant and take advantage of historical performance database
- ▶ Public outreach key to implementation & ongoing support

Thank you!



A joint effort of the
Orange County Water District and Orange County Sanitation District

