

# WATER QUALITY MONITORING SCHEDULE

## Transient Noncommunity System (NSTNC)

UPDATED - April 2018

*This schedule contains default frequencies and does not change any approved modified frequencies specific to your water system. Contact your district office if you have any questions.*

| Chemical - Title 22                        | MCL (mg/L)     | Frequency                            |
|--|----------------|--------------------------------------|
| <b>Primary Inorganics - Section 64432</b>  |                |                                      |
| Aluminum                                   | 1              | Not Required                         |
| Antimony                                   | 0.006          | Not Required                         |
| Arsenic                                    | 0.010          | Not Required                         |
| Barium                                     | 1              | Not Required                         |
| Beryllium                                  | 0.004          | Not Required                         |
| Cadmium                                    | 0.005          | Not Required                         |
| Chromium (Total Chromium)                  | 0.05           | Not Required                         |
| Cyanide                                    | 0.15           | Not Required                         |
| Fluoride                                   | 2.0            | Once only                            |
| Mercury                                    | 0.002          | Not Required                         |
| Nickel                                     | 0.1            | Not Required                         |
| Perchlorate                                | 0.006          | Not Required                         |
| Selenium                                   | 0.05           | Not Required                         |
| Thallium                                   | 0.002          | Not Required                         |
| <b>Asbestos - Section 64432.2</b>          |                |                                      |
| Asbestos - Source Water                    | 7 MFL          | Not Required                         |
| <b>Nitrate/Nitrite - Section 64432.1</b>   |                |                                      |
| <b>Nitrate (as N)</b>                      | 10             | Every 9 years if $\leq 5$ mg/L (1)   |
| Nitrite (as nitrogen)                      | 1              | Every 9 years if $\leq 0.5$ mg/L (1) |
| Nitrate + Nitrite (sum as nitrogen)        | 10             | N/A                                  |
| <b>Secondary Standards - Table 64449-A</b> |                |                                      |
| Aluminum                                   | 0.2            | Not Required                         |
| Color                                      | 15             | Not Required                         |
| Copper                                     | 1.0            | Not Required                         |
| Foaming Agents                             | 0.5            | Not Required                         |
| Iron                                       | 0.3            | Once only                            |
| Manganese                                  | 0.05           | Once only                            |
| Methyl-tert-butyl ether (MTBE)             | 0.005          | Not Required                         |
| Odor                                       | 3              | Not Required                         |
| Silver                                     | 0.1            | Not Required                         |
| Thiobencarb                                | 0.001          | Not Required                         |
| Turbidity                                  | 5              | Not Required                         |
| Zinc                                       | 5              | Not Required                         |
| <b>General Minerals - Section 64449</b>    |                |                                      |
| Bicarbonate                                | N/A            | Once only                            |
| Carbonate                                  | N/A            | Once only                            |
| Hydroxide Alkalinity                       | N/A            | Once only                            |
| Calcium                                    | N/A            | Once only                            |
| Magnesium                                  | N/A            | Once only                            |
| Sodium                                     | N/A            | Once only                            |
| Hardness                                   | N/A            | Once only                            |
| pH   | N/A            | Once only                            |
| <b>Secondary Standards - Table 64449-B</b> |                |                                      |
| TDS  | 500-1000;1500  | Not Required                         |
| Specific Conductance                       | 900-1600; 2200 | Once only                            |
| Chloride                                   | 250-500;600    | Not Required                         |
| Sulfate                                    | 250-500;600    | Not Required                         |

MCL = Maximum Contaminant Level

**Contact your district office with any questions.**

- (1) Nitrate/Nitrite sampling: A standby source that has previous monitoring results indicating nitrate or nitrite levels equal to or greater than 50 percent of the MCL shall collect and analyze a sample for nitrate/nitrite annually. In addition, upon activation a sample shall be collected and analyzed for these constituents and the analytical results reported to the Division within 24 hours of activation.