

ERRATA SHEET
Tentative Order No. R9-2007-0026 (NPDES NO. CA0109355)
Waste Discharge Requirements for Hubbs –Seaworld Research Institute
LEON RAYMOND HUBBARD, JR. MARINE FISH HATCHERY

1. Page 14, Provision VI.g: January 18, 2007 is changed to January 1, 2013, .
2. Page 10, Table 7: An interim effluent limitation is added for zinc as follows:

Table 7. Interim Effluent Limitations

Parameter	Units	Effluent Limitations			
		Average Monthly	Maximum Daily	Rationale	Expiration Date
Zinc	<u>mg/l</u>		<u>90.0</u>	<u>(i)</u>	<u>4 years</u>
	<u>lbs/day</u>		<u>(g)</u>		
Total Nitrogen	mg/L		4.0	(f)	4 years
	lbs/day ^(h)		(g)		
Phosphorus	mg/L		0.70	(f)	4 years
	lbs/day ^(h)		(g)		

- f. Based on the maximum daily effluent concentration reported by the Discharger since 2001.
- g. The maximum daily MER shall not exceed the maximum daily influent mass emission of the intake water collected from INF-001.
- h. The MER are calculated using the following calculation:
Mass Emission Rate (lb/Day) = 8.34 x Q x C
- i. Based on the CTR limit for saltwater