

EXECUTIVE OFFICER SUMMARY REPORT  
April 8, 2009

- ITEM: 9
- SUBJECT: Revision of Waste Discharge Requirements:  
Riverside County Regional Park and Open Space District,  
Skinner Lake Recreation Area, Riverside County (Tentative  
Addendum No.1 to Order No. 95-018) (*Fisayo Osibodu*)
- PURPOSE: To adopt tentative Addendum No.1 to Order No. 95-018,  
modifying the monitoring and reporting requirements.
- PUBLIC NOTICE: Notification of this action was posted on the Regional Board  
web page on March 4, 2009. This action satisfies the public  
notification requirements of California Water Code, Division  
7 section 13167.5 for a 30 day notice.
- DISCUSSION: Order No. 95-018 prescribes Waste Discharge  
Requirements (WDRs) to Riverside County Regional Park  
and Open Space District (hereinafter Discharger) for the  
discharge of up to 0.6 million gallons per day (MGD) of  
domestic wastewater at Skinner Lake Recreation Area  
(SLRA), Riverside County. The proposed modification of  
this Order will provide the Discharger flexibility in the method  
for monitoring dissolved oxygen in the SLRA oxidation ponds  
and simplify the reporting of the data.
- SLRA is a Recreational Vehicle (RV) park, which includes  
accommodations for approximately 300 vehicles, picnic  
tables, boat launching and rental areas, fish cleaning  
facilities, equestrian camping areas, and a ranger's  
residence. Domestic wastewater from the SLRA is  
discharged to two aerated oxidation ponds and a non-  
aerated evaporation pond.
- The Monitoring and Reporting Program of Order No. 95-018  
currently requires the Discharger to collect biweekly grab  
samples of wastewater in the oxidation ponds, and have  
those samples analyzed for dissolved oxygen at a  
commercial laboratory. The tentative Addendum would allow  
the discharger to take field measurements using portable  
dissolved oxygen meters, which can now measure dissolved  
oxygen in the field with an acceptable level of accuracy.

The tentative Addendum clarifies that the Discharger only needs to submit the dissolved oxygen monitoring data upon request by the Regional Board. The addendum requires that Discharger notify the Regional Board within 24 hours if the dissolved oxygen concentration in the evaporation ponds falls below 2.0 milligrams per liter (mg/L).

To date, the Regional Board has not received any public comments regarding this item.

**SIGNIFICANT  
CHANGES:**

None

**KEY ISSUES:**

Dissolved oxygen levels in the facility oxidation ponds can be accurately measured to an acceptable degree of accuracy using a portable dissolved oxygen meter.

**LEGAL CONCERNS:**

None

**COMPLIANCE  
RECORD:**

None

**SUPPORTING  
DOCUMENTS:**

1. Location Map
2. Transmittal letter to Riverside County Regional Park and Open Space District.
3. Tentative Addendum No.1 to Order No. 95-018

**RECOMMENDATION:** Adoption of tentative Addendum No.1 to Order No. 95-018