

Errata Sheet
Tentative Order No. R9-2012-0042, NPDES Permit No. CA0107433
City of Oceanside

The following changes have been made to Tentative Order No. R9-2012-0042:

Directive No. 1 on page 2 will be replaced with the following:

1. Section VII.E, Compliance with the Instantaneous Maximum Effluent Limitation, shall be modified as follows:

The instantaneous maximum effluent concentration limitations shall apply to grab sample determinations **and continuous turbidimeter recorded levels. For grab samples, if** the analytical result of a single ~~grab~~ sample is higher than the instantaneous maximum effluent limitation for a parameter, a violation will be flagged and the Discharger will be considered out of compliance for that parameter for that single sample. Non-compliance for each sample will be considered separately (e.g., the results of two grab samples taken within a calendar day that both exceed the instantaneous maximum effluent limitation would result in two instances of noncompliance with the instantaneous maximum effluent limitation). **For a continuous turbidimeter, turbidity shall be recorded at intervals of no more than 1-hour (i.e. recorded at least once per hour). If the instantaneous maximum recorded level for a calendar day for turbidity is higher than the instantaneous maximum effluent limitation for turbidity, a violation will be flagged and the Discharger will be considered out of compliance for turbidity for that calendar day.**