



**Matthew Rodriguez**  
Secretary for  
Environmental Protection

# California Regional Water Quality Control Board San Diego Region

Over 50 Years Serving San Diego, Orange, and Riverside Counties  
Recipient of the 2004 Environmental Award for Outstanding Achievement from U.S. EPA



**Edmund G. Brown Jr.**  
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353  
(858) 467-2952 • Fax (858) 571-6972  
<http://www.waterboards.ca.gov/sandiego>

December 13, 2011

Mr. David Rebensdorf  
Assistant City Engineer  
City of San Clemente  
910 Calle Negocio, Suite 100  
San Clemente, CA 92672

In reply refer to  
**255218: oosibodu**

Dear Mr. Rebensdorf:

**SUBJECT: CONSIDERATION OF ADOPTION OF TENTATIVE ORDER NO. R9-2011-0073, AN ORDER MODIFYING ORDER NO. R9-2003-0123, MASTER RECLAMATION PERMIT FOR THE CITY OF SAN CLEMENTE WATER RECLAMATION PLANT, ORANGE COUNTY**

This serves to inform you that the California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has postponed considering adoption of the enclosed Tentative Order No. R9-2011-0073 (tentative Order) to its scheduled board meeting on February 8, 2012. The meeting will begin promptly at 9:00 AM and will be held at the following location:

Board Room  
California Regional Water Quality Control Board  
San Diego Region  
9174 Sky Park Court, Suite 100  
San Diego, CA 92123-4340

The tentative Order, if adopted, would modify Order No. 2003-0123, *Master Reclamation Permit with Waste Discharge Requirements for the Production and Purveyance of Recycled Water for City of San Clemente Water Reclamation Plant, Orange County*. The proposed tentative Order would, if adopted increase the average monthly flow limit specified in Order No. R9-2003-0123 for the City of San Clemente Water Reclamation Plant from 2.2 to 5.0 million gallons per day as requested by the City of San Clemente. The proposed tentative Order would also require the City of San Clemente to participate in the development of a salt and nutrient management plan for the San Juan Groundwater Basin. The South Orange County Wastewater Authority will lead the development of a salt and nutrient management plan for the San Juan Groundwater Basin.


*California Environmental Protection Agency*

Copies of the Tentative Order as well as an underline strikeout version of the original Order No. R9-2003-0123 showing the proposed revisions are available on our website at: <http://www.waterboards.ca.gov/sandiego/>.

Comments must be received in the San Diego Water Board's office no later than 5:00 pm on Wednesday, January 12, 2012. Written comments should be submitted electronically to [oosibodu@waterboards.ca.gov](mailto:oosibodu@waterboards.ca.gov) in Portable Document Format (PDF) or Microsoft Word.

In the subject line of any response, please include the requested **"In reply refer to"** information located in the heading of this letter. For questions pertaining to the subject, please contact Mr. Fisayo Osibodu at (858)-637-5594 or via e-mail at [oosibodu@waterboards.ca.gov](mailto:oosibodu@waterboards.ca.gov).

Sincerely,



Julie Chan  
Chief, Cleanup and Land Discharge Branch

JC:bdk:oo

Enclosure: Tentative Order No. R9-2011-0073

cc w/enclosure: Mr. Jay Elston, Utility Operations Supervisor  
City of San Clemente Water Reclamation Plant  
380 Avenida Pico, San Clemente, CA 92672

Mr. Tom Rosales, General Manager  
South Orange County Wastewater Authority  
34156 Del Obispo Street, Dana Point, CA 92629