



California Regional Water Quality Control Board

San Diego Region



Linda S. Adams
Secretary for
Environmental Protection

Over 50 Years Serving San Diego, Orange, and Riverside Counties
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA

Arnold Schwarzenegger
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353
(858) 467-2952 • Fax (858) 571-6972
<http://www.waterboards.ca.gov/sandiego>

March 22, 2010

In reply refer to:
205079:adai

Mr. Larry Tardie
All Seasons RV Park and Campground
P.O. Box 21838
Eugene, Oregon 97402

Dear Mr. Tardie

SUBJECT: ALL SEASONS RV PARK AND CAMPGROUND

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the January - June 2009 and July - December 2009 semiannual monitoring reports, and the January-December 2009 annual monitoring report. The referenced reports were submitted in accordance with the Monitoring and Reporting Program of Order No. 94-05.

The following violations of Order No. 94-05 were identified in the reports submitted:

1. The Discharge Specification for the daily maximum effluent concentration for Biochemical Oxygen Demand (BOD), established at 45 milligrams per liter (mg/L), was exceeded on March 13 and September 17, 2009 with reported values of 97 mg/L and 50 mg/L respectively.
2. The Discharge Specification for the daily maximum effluent concentration for boron, established at 0.75 mg/L, was exceeded on June 8, 2009 with a reported value of 0.76 mg/L.
3. The Discharge Specification for the daily maximum effluent concentration for chloride, established at 200 mg/L, was exceeded on October 29, 2009 with a reported value of 230 mg/L.

California Environmental Protection Agency

Mr. Larry Tardie
All Seasons RV Park and Campground

-2-


March 22, 2010

Please be aware these violations subject you to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring the you to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;¹ referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

The next monitoring required to be submitted is the January - June 2010 report, which is due by July 30, 2010.

In the subject line of any response, please include the requested "**In reply refer to:**" information located in the heading of this letter. For questions pertaining to the subject matter, please contact Ms. Amanda Dai at (858) 627-3977 or at email adai@waterboards.ca.gov.

Sincerely,



Robert W. Morris, P.E.
Senior Water Resource Control Engineer
Ground Water Branch

¹ Under authority of California Water Code section 13350.