



Linda S. Adams  
Secretary for  
Environmental Protection

# California Regional Water Quality Control Board San Diego Region

Over 50 Years Serving San Diego, Orange, and Riverside Counties  
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA



Arnold Schwarzenegger  
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353  
(858) 467-2952 • Fax (858) 571-6972  
<http://www.waterboards.ca.gov/sandiego>

May 6, 2010

In reply refer to:  
263145:oosibodu

Mr. Anthony Pack  
General Manager  
Eastern Municipal Water District  
P.O. Box 8300  
Perris, CA 92572-8300

Dear Mr. Pack:

**SUBJECT: REVIEW OF MONITORING REPORTS FOR THE TEMECULA VALLEY  
REGIONAL WATER RECLAMATION FACILITY**

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the September 2009-March 2010 monthly monitoring reports submitted by the Eastern Municipal Water District (district) in accordance with Order No. 2000-165. The following violations of Discharge Specification B.3 of Order No. 2000-165 were identified in the submitted reports:

1. The daily effluent discharge specification for manganese established at 0.06 milligrams per liter (mg/L) was exceeded on October 21, 2009 with a reported value of 0.17 mg/L.
2. The daily effluent discharge specification for total dissolved solids established at 825 mg/L was exceeded on January 10 and February 10, 2010 with reported values of 830 and 839 mg/L respectively.

Please be aware these violations subject you to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring you to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;<sup>1</sup> referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution

The next monitoring report required to be submitted is the April 2010 monthly monitoring report, which is due by May 30, 2010.

<sup>1</sup> Under authority of California Water Code section 13350.

