



# California Regional Water Quality Control Board San Diego Region



Linda S. Adams  
Secretary for  
Environmental Protection

Over 50 Years Serving San Diego, Orange, and Riverside Counties  
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA

Arnold Schwarzenegger  
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353  
(858) 467-2952 • Fax (858) 571-6972  
<http://www.waterboards.ca.gov/sandiego>

May 4, 2010

Mr. Gerald Saladino  
Manager  
Tucalota Springs RV Park & Campground  
41601 Benton Road  
Hemet, CA 92544

In reply refer to:  
266668:adai

Dear Mr. Saladino:

**SUBJECT: REVIEW OF MONITORING REPORT FOR ORDER NO. 95-84  
TUCALOTA SPRINGS RV PARK & CAMPGROUND**


The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the January-December 2009 annual monitoring report submitted for Tucalota Springs RV Park & Campground in accordance with Monitoring and Reporting Program No. 95-84.

The following violations of Section C.2 (Facility, Design, and Operations Specifications) of Order No. 95-84 were identified in the report submitted:

1. Septic tank effluent analyses results for your facility have not been submitted since January 2004. Section C.1 (Effluent Monitoring) of Monitoring and Reporting Program No. 95-84 requires you analyze a sample of the septic tank effluent for pH, total dissolved solids, total nitrogen, and methylene blue activated substances at least once every four years; and also requires you submit the analyses results with the annual monitoring report.
2. The January-December 2009 annual report was received on March 30, 2010. Section D of Monitoring and Reporting Program No. 95-84 specifies that the annual report shall be submitted by January 30 each year.

Please be aware these violations subject you to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring you to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability

**California Environmental Protection Agency**



OPON/D/S

May 4, 2010

in amounts of up to \$5,000 per day per violation;<sup>1</sup> referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

The next monitoring report required to be submitted is January-December 2010 annual report, which is due by January 30, 2011.

In the subject line of any response, please include the requested "In reply refer to:" information located in the heading of this letter. For questions pertaining to the subject matter, please contact Amanda Dai at (858) 627-3977 or [adai@waterboards.ca.gov](mailto:adai@waterboards.ca.gov).

Sincerely,



Robert W. Morris, P.E  
Senior WRC Engineer  
Ground Water Branch

cc: Mr. Clifford Ronnenberg, Tucalota Park, LLC., 11292 Western Avenue, Stanton, CA 90680

---

<sup>1</sup> Under authority of California Water Code section 13350.