



California Regional Water Quality Control Board

San Diego Region

Over 50 Years Serving San Diego, Orange, and Riverside Counties¹

Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA



Arnold Schwarzenegger
Governor

Linda S. Adams
Secretary for
Environmental Protection

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353

(858) 467-2952 • Fax (858) 571-6972

http://www.waterboards.ca.gov/sandiego

October 5, 2010

In reply refer to:

Adai:263145

Mr. Anthony Pack
General Manger
Eastern Municipal Water District
P.O. Box 8300
Perris, CA 92572-8300

Dear Mr. Pack:

**SUBJECT: REVIEW OF MONITORING REPORTS FOR TEMECULA VALLEY
REGIONAL WATER RECLAMATION FACILITY**

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the April 2010 through August 2010 monthly monitoring reports submitted by the Eastern Municipal Water District in accordance with the Monitoring and Reporting Program No. 2000-165.

The San Diego Water Board has the following identified the following violation of the Section B:3 (Discharge Specifications) of Order No. 2000-165:

The effluent coliform bacteria concentration was reported as 1,600 Most Probable Number (MPN) per 100 milliliter (mL) on April 26, 2010. Title 22, Section 60301.23 of the California Code of Regulations specifies that the coliform bacteria concentration of disinfected tertiary recycled water used for landscape irrigation shall not exceed 240 MPN per 100 mL.

Please be aware this violation subjects you to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring the you to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;¹ referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

The next monitoring report to be submitted is the September 2010 monthly monitoring report due by October 30, 2010.

¹ Under authority of California Water Code section 13350.

Mr. Pack

- 2 -

October 5, 2010

In the subject line of any response, please include the requested "In reply refer to:" information located in the heading of this letter. For questions pertaining to the subject matter, please contact Amanda Dai at (858) 627-3977 or via email at adai@waterboards.ca.gov.


Sincerely,

Robert Morris

Robert Morris, P.E.
Senior Water Resource Control Engineer
Cleanup and Land Discharge Branch

Regulatory Measure ID: 376125
Violation ID: 882162

California Environmental Protection Agency



040N\0\04