



California Regional Water Quality Control Board

San Diego Region



Linda S. Adams
Secretary for
Environmental Protection

Over 50 Years Serving San Diego, Orange, and Riverside Counties
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA

Arnold Schwarzenegger
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353
(858) 467-2952 • Fax (858) 571-6972
<http://www.waterboards.ca.gov/sandiego>

October 19, 2010

In reply refer to:
235097:adai

Mr. Thaddeus Suh
Kkottongnae Inc.
37885 Highway 79 South
Temecula, CA 92592

Dear Mr. Suh:

**SUBJECT: REVIEW OF MONITORING REPORT FOR ORDER NO. 93-43
KKOTTONGNAE RETREAT CAMP**

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the January-June 2010 semiannual monitoring report submitted by Kkottongnae Inc. in accordance with Monitoring and Reporting Program No. 93-43.

The following violations of Section B.1 (Discharge Specifications) of Order No. 93-43 were identified in the submitted report:

1. The daily maximum discharge specification for nitrate established at 10 milligrams per liter (mg/L), was exceeded on June 24, 2010 with a reported value of 62 mg/L.
2. The 30-day average discharge specification for nitrate established at 10 milligrams per liter (mg/L), was exceeded on June 2010 with a reported value of 62 mg/L.

The following violations of Section D.4 (Reporting Requirements) of Order No. 93-43 were identified in the submitted report:

3. Information regarding disposal of solids removed from the facility was not included in the January-June 2010 semiannual report. Section E (Sewage Solids) of Monitoring and Reporting Program No. 93-43 requires you to submit a log of the type, quantity, and manner of disposal of sewage solids removed during sewage treatment semiannually.
4. Information regarding visitor-use-days and water consumption was not included in the January-June 2010 semiannual report. Section F (Visitor Use Days and Water Consumption) of Monitoring and Reporting Program No. 93-43 requires

California Environmental Protection Agency



0100000101

you to submit monthly logs of visitor-use days and water consumption semiannually.


Please be aware these violations subject you to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring the you to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;¹ referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

The next monitoring report required to be submitted is the July-December 2010 semiannual and January-December 2010 annual report, which are due by January 30, 2011.

For questions pertaining to the subject matter, please contact Amanda Dai at (858) 627-3977 or via email at adai@waterboards.ca.gov.

PLEASE INCLUDE "235097:ADAI" IN THE SUBJECT LINE OF FUTURE CORRESPONDANCE.

Sincerely,



Robert W. Morris, P.E.
Senior Water Resource Control Engineer
Cleanup and Land Discharge Branch

Regulatory Measure ID: 376266
Violation ID: 883002, 883003, 883004, 883005

¹ Under authority of California Water Code section 13350.