



California Regional Water Quality Control Board San Diego Region



Linda S. Adams
Secretary for
Environmental Protection

Over 50 Years Serving San Diego, Orange, and Riverside Counties
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA

Arnold Schwarzenegger
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353
(858) 467-2952 • Fax (858) 571-6972
[http:// www.waterboards.ca.gov/sandiego](http://www.waterboards.ca.gov/sandiego)

October 14, 2010

In reply refer to:
376232: oosibodu

Mr. Ken Pintus
Lilac Enterprises Inc.
Hideaway Lake Mobile Home Estates
13076 Falcon Place
Chino, CA 91710

Dear Mr. Pintus:

**SUBJECT: REVIEW OF MONITORING REPORT AND MODIFICATION OF ORDER
NO. 93-27 FOR HIDEAWAY LAKE MOBILE HOME ESTATES**

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the January-June 2010 semiannual monitoring report submitted for Hideaway Lake Mobile Home Estates in accordance with the Monitoring and Reporting Program of Order No. 93-27.

The following violation of Order No. 93-27 was noted in the report submitted:

1. The daily maximum discharge specification for boron, established at 0.5 milligrams per liter (mg/L), was exceeded on January, 29, 2010 with a reported value of 0.56 mg/L.

In addition the San Diego Water Board has the following comments:


2. In response to recurring exceedances of the discharge specification for boron, Lilac Enterprises Inc. submitted a Form 200 on July 29, 2010 requesting an increase of the discharge specification for boron from 0.5 to 0.75 mg/L. The San Diego Water Board plans to modify the discharge specification for boron. A tentative addendum modifying Order No. 93-27 will be presented to the San Diego Water Board for adoption at a future board meeting. A copy of the tentative addendum will be sent to you prior to presenting it for adoption.
3. The next monitoring reports required to be submitted are the July-December 2010 semiannual and January-December 2010 annual monitoring reports both due by January 30, 2011.

California Environmental Protection Agency



In the subject line of any response, please include the requested **"In reply refer to:"** information located in the heading of this letter. For questions pertaining to the subject matter, please contact Mr. Fisayo Osibodu at (858) 637-5594 or via email at osibodu@waterboards.ca.gov.

Sincerely,

A handwritten signature in cursive script that reads "Robert Morris".

Robert Morris, P.E.
Senior Water Resource Control Engineer
Cleanup and Land Discharge Branch

Regulatory Measure: 376232
CIWQS Violation: 882759