



Linda S. Adams
Secretary for
Environmental Protection

California Regional Water Quality Control Board San Diego Region

Over 50 Years Serving San Diego, Orange, and Riverside Counties
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA



Arnold Schwarzenegger
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353
(858) 467-2952 • Fax (858) 571-6972
[http:// www.waterboards.ca.gov/sandiego](http://www.waterboards.ca.gov/sandiego)

October 27, 2010

In reply refer to:
234117:adai

Ms. Milica Kaludjerski
Department of Public Works
County of San Diego
5555 Overland Ave., Suite 2188
San Diego, CA 92123-1295

Dear Ms. Kaludjerski:

**SUBJECT: REVIEW OF MONITORING REPORTS FOR THE
JULIAN WATER POLLUTION CONTROL FACILITY**

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the April-June 2010 quarterly monitoring report submitted by the County of San Diego (County) in accordance with Monitoring and Reporting Program Order No. 83-09.

The following violations of Order No. 83-09 were identified in the report submitted:

1. The 12-month average Discharge Specification B.1 for chloride, established at 120 milligrams per liter (mg/L), was exceeded for the month of April, May, and June with reported values of 138.2 mg/L, 127.3 mg/L, and 125.6 mg/L, respectively.
2. The County failed to submit an annual water supply analysis by July 30, 2010, which is requested by the Monitoring and Reporting Program No. 83-09 Section G (Report Schedule). It should be a sample of the general water supply to the area served by the treatment plant. We would accept the data from the annual water quality report of Julian Community Services District.

Please be aware these violations subject the County to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring the County to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;¹ referral to the State

¹ Under authority of California Water Code section 13350.


Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

The next monitoring report to be submitted is the July-September 2010 quarterly monitoring report, which is due by October 30, 2010.

For questions pertaining to the subject matter, please contact Amanda Dai at (858) 627-3977 or via email at adai@waterboards.ca.gov.

PLEASE INCLUDE "234117:ADAI" IN THE SUBJECT LINE OF FUTURE CORRESPONDANCE.

Sincerely,



Robert W. Morris, P.E.
Senior Water Resource Control Engineer
Cleanup and Land Discharge Branch

Regulatory Measure ID	141929
Place ID	234117
Enforcement ID	376342
Violation ID	883495 883496 883497 883500