



California Regional Water Quality Control Board, San Diego Region

By Email Only

October 8, 2014

In reply refer to:
Place ID:243989:kschwall

Mark Edson
Installation Environmental Program Manager
Naval Base San Diego
3455 Senn Road, Building 72
San Diego, CA 92136-5084
mark.a.edson@navy.mil

SUBJECT: Review of Self-Monitoring Reports for Order No. R9-2013-0064, NPDES No. CA0109169; Naval Base San Diego

Mr. Edson:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the 2014 first and second quarterly, 2014 first semiannual, 2014 annual, and 2014 storm water monitoring reports submitted for Naval Base San Diego. The San Diego Water Board noted the following violations of Order No. R9-2013-0064:

<u>Violation No.</u>	<u>Violation ID</u>	<u>Date Occurred</u>	<u>Violation Description</u>	<u>Permit Section Violated</u>
1	977222	1/17/2014	182 gallons of diesel fuel marine was discharged to San Diego Bay.	III.A
2	977223	1/25/2014	90 gallons of diesel fuel marine was discharged to San Diego Bay.	III.A
3	973186	1/29/2014	pH Instantaneous Minimum limit at SC-101.	IV.A.1 Table 8
4	973187	1/29/2014	pH Instantaneous Minimum limit at SC-016.	IV.A.1 Table 8
5	967789	2/24/2014	Copper, Total Maximum Daily limit at NGD-001 & 002.	IV.A.2 Table 9
6	975496	2/24/2014	Nickel, Total Maximum Daily limit at NGD-004.	IV.A.4 Table 11
7	976734	2/24/2014	Nickel, Total Monthly Average (Mean) limit at NGD-004.	IV.A.4 Table 11
8	975497	2/24/2014	Chronic Toxicity Failed at NGD-003.	IV.A.3 Table 10
9	976683	4/1/2014	500 gallons of Oil - F76 was discharged to San Diego Bay.	III.A
10	977224	4/22/2014	81 gallons of fuel oil was discharged to San Diego Bay at the USS John Paul Jones. 350" x 30" area contained with boom.	III.A

<u>Violation No.</u>	<u>Violation ID</u>	<u>Date Occurred</u>	<u>Violation Description</u>	<u>Permit Section Violated</u>
11	976681	5/5/2014	103 gallons of oily waste water mixture spilled to San Diego Bay.	III.A
12	976684	6/25/2014	650 gallons of diesel fuel marine was discharged to San Diego Bay.	III.A
13	977225	6/30/2014	During the year, there were 21 small spills to San Diego Bay ranging from an unknown sheen to 5 gallons. Material spilled included diesel fuel marine, oily waste, hydraulic oil, black paint, gear oil, cosmoline (oil), white paint, oil-F76, and fuel oil.	III.A

Please take steps to ensure that the violations noted above do not occur in the future. Pursuant to the California Water Code, violations may result in enforcement by the San Diego Water Board, including issuance of an enforcement order and/or financial penalties.

In the subject line of any response, please include the following: "Place ID: 243989; KSchwall". For questions or concerns regarding this letter, please contact Kristin Schwall at 619-521-3368 or kschwall@waterboards.ca.gov.

Respectfully,



Brandi N. Outwin-Beals, P.E.
Senior Water Resources Control Engineer
Source Control Unit

cc: Jessica Palmer, NBSD, jessica.palmer@navy.mil
Rebecca Keller, NBSD, rebecca.keller@navy.mil
Len Sinfield, US Navy, len.sinfield@navy.mil

Tech Staff Info & Use	
Order No.	R9-2013-0064
Time Schedule Order No.	R9-2013-0095
WDID	9 000000497
NPDES No.	CA0109169
Reg. Measure ID	390231 (Order)
Reg. Measure ID	393217 (TSO)
Place ID	243989
Enforcement ID	398348