San Diego Regional Water Quality Control Board

Sent Via Email Only

December 8, 2015

Mr. Mark Edson
Installation Environmental Program Manager
Naval Base San Diego
mark.a.edson@navy.mil

In reply refer to:
243989:Kschwall

Subject: Staff Enforcement Letter for Naval Base San Diego, Order No. R9-2013-0064, NPDES Permit No. CA0109169

Mr. Edson:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has noted the following violations for Naval Base San Diego:

1. Violation – Effluent Exceedance, Section IV.A.2

   a. The Total Recoverable Copper daily max limit of 13.8 ug/L was exceeded on September 19, 2015 with a reported value of 16 ug/L at Monitoring Location NGD-001 and NGD-002.

Pursuant to the California Water Code (CWC), the violation noted is subject to additional enforcement action(s) by the San Diego Water Board including a time schedule order, cease and desist order, cleanup and abatement order, imposition of administrative civil liability, referral to the district attorney for criminal prosecution, or referral to the attorney general. Administrative civil liability amounts that may be imposed by the San Diego Water Board under authority of CWC Section 13385 include up to $10,000 per day, or up to $10 per gallon for each gallon of waste discharged.

In the subject line of any response, please include the reference "243989:Kschwall".
For questions or concerns regarding this letter, please contact Kristin Schwall at 619-521-3368 or kristin.schwall@waterboards.ca.gov.

Respectfully,

Dat Quach, P.E.
Water Resources Control Engineer
Source Control Unit

cc: Len Sinfield, len.sinfield@navy.mil

Tech Staff Info & Use	
Order No.	R9-2013-0064
Party IDs	9093 (USNSWD), 504822 (Edson)
WDID	9 000000497
NPDES No.	CA0109169
Reg. Measure IDs	403816 (R9-2013-0064)
Place ID	243989
Violation IDs	
1a.	998334