

San Diego Regional Water Quality Control Board

August 11, 2016

Ms. Cari Dale
Director
City of Oceanside
5950 El Camino Real
Carlsbad, CA 92028
cdale@ci.oceanside.ca.us

Sent Via Email Only

In reply refer to / attn:
245795:DQuatch

Subject: Staff Enforcement Letter for Oceanside Ocean Outfall, Order No. R9-2011-0016, NPDES Permit No. CA0107433

Ms. Dale:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the following self-monitoring reports (SMRs) for the facilities associated with the Oceanside Ocean Outfall:

- Monthly SMRs – March 2016 through May 2016
- Quarterly SMRs – January 2016 through March 2016

The following is a summary of the San Diego Water Board's findings:

1. Violation – Effluent Limitation, Section IV.A

On April 1, 2016, the total suspended solids (TSS) monthly mean was reported as 85.6 mg/L, exceeding the average monthly effluent limitation of 60.0 mg/L at Monitoring Location No. M-003.

2. Comments – Surface Water Limitations, Section V.A

- a. On March 16, 2016, the enterococci density at Monitoring Location No. A4 was reported to be 453 MPN/100mL, exceeding the receiving water limitation of 104 MPN/100mL.
- b. On March 16, 2016, the enterococci density at Monitoring Location No. B1 was reported to be 111 MPN/100mL, exceeding the receiving water limitation of 104 MPN/100mL.
- c. On March 16, 2016, the enterococci density at Monitoring Location No. B1-Mid was reported to be 1,180 MPN/100mL, exceeding the receiving water limitation of 104 MPN/100mL.

Pursuant to the California Water Code (CWC), the violations noted maybe subject to additional enforcement action(s) by the San Diego Water Board including a time schedule order, cease and desist order, cleanup and abatement order, referral to the district attorney for criminal prosecution, or referral to the attorney general. Pursuant to CWC section 13385(h)(1), a mandatory minimum penalty of three thousand dollars shall be assessed for each "serious

violation," and pursuant to CWC section 13385(i)(1), a mandatory minimum penalty of three thousand dollars shall be assessed whenever a violation occurs four or more times in any period of six consecutive months.

In the subject line of any response, please include the reference "245795:DQuatch". For questions or concerns regarding this letter, please contact me at 619-521-5899 or Dat.Quach@waterboards.ca.gov.

Respectfully,



Dat Quach, P.E.
Water Resources Control Engineer
Source Control Unit

cc by email:

Joann Lim, San Diego Water Board, Joann.Lim@waterboards.ca.gov

Chiara Clemente, San Diego Water Board, Chiara.Clemente@waterboards.ca.gov

Tech Staff Info & Use	
Order No.	R9-2011-0016
Party IDs	32483 (Oceanside City), 357824 (Dale)
WDID	9 000000146
NPDES No.	CA0107433
Reg. Measure IDs	377272 (R9-2011-0016), 407646 (SEL)
PIN	245795
Violation IDs	
1	1008127