

EDMUND G. BROWN JR.
GOVERNOR

MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

San Diego Regional Water Quality Control Board

November 28, 2016

Ms. Lori Rigby
Compliance Officer
City of Oceanside
3950 North River Road
Oceanside, California, 92058

In reply refer to / attn:
255386:BBushnell

Subject: Review of Monitoring Reports for Order No. 93-007, San Luis Rey Land Disposal

Ms. Rigby:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the January 2015 through September 2016 monthly monitoring reports, the January-March 2015, April-June 2015, July-September 2015, October-December 2015, January-March 2016, April-June 2016, July-September 2016 quarterly and the 2015 annual recycled water users reports. The City of Oceanside (City) submitted the monitoring reports as required by the Monitoring and Reporting Program No. 93-07.

Violations of Section B.1 (Discharge Specifications) of Order No. 93-07 identified in the monitoring reports are listed below:

1. The number of coliform organisms shall not exceed 23 Most Probable Number per 100 millimeter (MPN/100 mL) in any samples, when recycling water for irrigation use. Exceedances occurred on the following dates:


Date	Exceedances in MPN/100 mL	Violation ID
March 24, 2015	50.0	1014395
July 8, 2016	220.0	1014391

On May 22, 2016 the sample for coliform was above 1600 MPN/100 mL, however this was not a violation because no water was being distributed to recycled water use sites. .

Please continue to implement follow-up actions necessary to ensure that the violations noted above do not occur in the future. These violations may subject the City to possible further enforcement action by the San Diego Water Board including but not limited to: administrative enforcement orders requiring the City to cease and desist from violations, or administrative assessments of civil liabilities in amounts of up to \$5,000 per day per violation; referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

In the subject line of any response, please include reference 255386:**BBushnell**. Please contact Mr. Brandon Bushnell at 619-521-8044, or at brandon.bushnell@waterboards.ca.gov if you have any questions or comments.

Respectfully,



John R. Odermatt, P.G, Senior Engineering Geologist
Land Discharge Unit

JRO: ac: bb

Tech Staff Info & Use	
Place ID	255283
Reg. Measure ID	410051
Violation ID	1014395
	1014391