

San Diego Regional Water Quality Control Board

November 3, 2016

Mr. Andrew Entingh
Head, Environmental Compliance
Environmental Security
Marine Corps Base Camp Pendleton
Building 22-165
Camp Pendleton, CA 92055

In reply refer to:
638334: BBushnell

Subject: Monitoring Reports for Southern Regional Tertiary Treatment Plant

Mr. Entingh:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the January-August 2016 monthly monitoring reports, the April-June 2105, July-September 2015, and October-December 2015, January-March 2016, April-June 2016, July-September 2016 quarterly monitoring reports, and the 2015 annual monitoring report submitted by Camp Pendleton, in compliance with Order No. R9-2009-0021.

The San Diego Water Board has the following comments on the reports referenced above.

1. Monitoring and Reporting Program (MRP) No. R9-2009-0021 section C.2., requires the discharger to monitor for total suspended solids (TSS) on a weekly basis and report the results in the monthly monitoring report. However, TSS was not sampled for the week of September 14, 2015 to September 21, 2015.
2. MRP No. R9-2009-0021 requires the discharger to monitor Biochemical Oxygen Demand (BOD), TSS and pH on a weekly basis. The BOD, TSS and pH were not sampled or reported the week of January 10, 2016 to January 16, 2016.
3. Order R9-2009-0021, Discharge Specification section B.2, requires the total coliform bacteria concentration must not exceed an MPN of 23 total coliform bacteria per 100 milliliters in more than one sample in any 30 day period. The reported total coliform concentration exceeded 23 MPN on August 10, 2016 and August 15, 2016 with a total coliform concentration of 50 MPN in both instances.


The next monitoring report required to be submitted is the October 2016 monthly monitoring report due by November 30, 2016.

Please submit all future responses to the San Diego Water Board by email. Email submittals must include a signed cover/transmittal letter (with the facility name, facility contact information, and reference code **638334:BBushnell**), and be sent via email

tosandiego@waterboards.ca.gov. Information required by Order No. R9-2009-0021 should be mailed to sandiego@waterboards.ca.gov. Routine email correspondence, however, may be sent to individual San Diego Water Board staff members. If you have any specific questions about email submittals procedures, please contact Ms. Cleo Munoz, of our Mission Support Unit staff, at 619-521-3384 or cleo.munoz@waterboard.ca.gov.

In the subject line of any response, please include reference **638334:BBushnell**. Please contact Mr. Brandon Bushnell at (619) 521-8044, or at brandon.bushnell@waterboards.ca.gov if you have any questions or comments.

Sincerely,



JOHN R. ODERMATT, M.Sc. P.G., Senior Engineering Geologist
Land Discharge Unit

JRO: ac: bb

Tech Staff Info & Use	
Place ID	638334
Party ID	627
Reg. Measure ID	350670
SEL Reg Measure	409954
Violation ID	1014141, 1013818, 1014111