

**ACCEPTANCE OF CONDITIONAL RESOLUTION  
AND WAIVER OF RIGHT TO HEARING  
ORDER R2-2026-1008**

**SUMCO Phoenix Corporation  
Former 401 National Avenue  
620 National Avenue, Mountain View, Santa Clara County  
NPDES Permit CAG912002, Regulatory Measure 463599**

By signing below and returning this Acceptance of Conditional Resolution and Waiver of Right to Hearing (Acceptance and Waiver) to the San Francisco Bay Regional Water Quality Control Board (Regional Water Board), SUMCO Phoenix Corporation (Discharger) hereby accepts the conditional offer to settle alleged violations through payment of a mandatory minimum penalty and waives the right to a hearing before the Regional Water Board to dispute the alleged violation. The violation is attached to this Acceptance and Waiver as Exhibit A and incorporated by reference.

The Discharger agrees that Exhibit A shall serve as a complaint pursuant to Article 2.5 of the Water Code and that no separate complaint is required for the Regional Water Board to assert jurisdiction over the alleged violations. The Discharger agrees to pay the penalty authorized by Water Code section 13385, which shall be deemed payment in full of any civil liability pursuant to Water Code section 13385 that otherwise might be assessed for the violation described in Exhibit A. The Discharger understands that this Acceptance and Waiver waives its right under Water Code section 13323 to contest the allegation in Exhibit A and the amount of civil liability assessed for the violation.

The Discharger understands that this Acceptance and Waiver does not address or resolve liability for any violation not specifically identified in Exhibit A.

This Acceptance and Waiver may be executed and delivered in any number of counterparts, each of which when executed and delivered shall be deemed to be an original, but such counterparts shall together constitute one document. This Acceptance and Waiver may be executed by wet or electronic signature, and may be transmitted by hand, mail service, facsimile, or email. Any such signature shall be deemed to be an original signature and shall be binding to the same extent as if it were an original signature.

Upon execution, the Discharger shall return the Acceptance and Waiver to the following:

California Regional Water Quality Control Board, San Francisco Bay Region  
NPDES Wastewater Enforcement Section  
Attention: Debbie Phan  
1515 Clay Street, Suite 1400  
Oakland, California 94612

or

[R2NPDES.MMPS@waterboards.ca.gov](mailto:R2NPDES.MMPS@waterboards.ca.gov)

The Discharger understands that federal regulations set forth in Code of Federal Regulations, title 40, section 123.27(d)(2)(iii), require the Regional Water Board to publish notice of, and provide at least 30 days for public comment on, any proposed resolution of an enforcement action. Accordingly, prior to execution by the Regional Water Board's Executive Officer, this Acceptance and Waiver will be published for public comment as required by law.

Acceptance of Conditional Resolution and Waiver of Right to Hearing  
SUMCO Phoenix Corporation

The Discharger understands that the Executive Officer may execute this Acceptance and Waiver as a Stipulated Order if no comments are received within the public notice period and the Executive Officer agrees that the assessment of the mandatory minimum penalty appropriately resolves the alleged violations. The Regional Water Board's resolution of the violations will preclude State Water Resources Control Board (State Water Board) action for the same violations.

The Discharger understands that the conditional offer may be withdrawn if significant comments are received in opposition to it. In that circumstance, Regional Water Board staff will advise the Discharger of the withdrawal and may issue an administrative civil liability complaint and schedule the matter for a hearing before the Regional Water Board or State Water Board.

The Discharger understands that funds collected for violations pursuant to Water Code section 13385 shall be deposited in the State Water Pollution Cleanup and Abatement Account.

The Discharger understands that, in lieu of full payment of the assessed mandatory minimum penalty to the State Water Pollution Cleanup and Abatement Account, it may elect to pay a portion toward a supplemental environment project (SEP). The SEP option is the SEP Fund, which supplements Regional Monitoring Program (RMP) studies that would not otherwise be conducted through the RMP's annually approved RMP cost allocations.

The Discharger understands that once the Regional Water Board's Executive Officer executes this Acceptance and Waiver as a Stipulated Order, payment no later than 30 days after the date of the Executive Officer's signature is a condition of this Acceptance and Waiver. The Discharger shall pay the assessed civil liability to the State Water Pollution Cleanup and Abatement Account and/or San Francisco Estuary Institute (for the SEP Fund) as selected above. The State Water Board will send an invoice for any payment due to the State Water Pollution Cleanup and Abatement Account. The Regional Water Board will send an invoice for any payment due to the SEP Fund.

The Discharger agrees to pay the amounts indicated below to the State Water Pollution Cleanup and Abatement Account and, if chosen, the SEP Fund. The Regional Water Board will consider the Discharger to have fulfilled any SEP obligation if and when the San Francisco Estuary Institute receives the Discharger's contribution to the SEP Fund. (Place a "✓" or "x" in **one** box below and fill in the blanks as appropriate. Electing to pay a portion of the assessed liability to the SEP Fund will not change the total amount to be paid.)

The Discharger's acceptance of the conditional offer and payment of the settlement amount is not an admission of liability, but Discharger understands that this Stipulated Order may be used as evidence of a prior "history of violations" consistent with Water Code sections 13327 and 13385, subdivision (e).

**Payment Options:**

- Option 1: Pay a portion of the assessed liability to the RMP SEP Fund:  
\$ \_\_\_\_\_ Amount to be paid to the SEP Fund (cannot exceed \$3,000)  
\$ \_\_\_\_\_ Amount to be paid to the State Water Pollution Cleanup and Abatement Account (\$3,000 minus amount inserted above)  
\$ 3,000 Total assessed mandatory minimum penalty (sum of amounts above).


Or

- Option 2: Pay the total assessed mandatory minimum liability (\$3,000) to the State Water Pollution Cleanup and Abatement Account.

**I hereby affirm that I am duly authorized to act on behalf of, and to bind, the Discharger in the making and giving of this Acceptance and Waiver.**

SUMCO Phoenix Corporation

By: Mike Goodwin Sr EHS Manager  
Printed or typed name Title

 1/15/2026  
Signature Date

**Note: Please return the signed Acceptance and Waiver with Exhibit A, together**

Acceptance of Conditional Resolution and Waiver of Right to Hearing  
SUMCO Phoenix Corporation

IT IS SO ORDERED PURSUANT TO WATER CODE SECTION 13323 AND GOVERNMENT  
CODE SECTION 11415.60

By: \_\_\_\_\_ Date \_\_\_\_\_  
Eileen White  
Executive Officer  
California Regional Water Quality Control Board  
San Francisco Bay Region

## EXHIBIT A

**Discharger: SUMCO Phoenix Corporation**

The following table lists the alleged violation for which the Discharger is subject to civil liabilities pursuant to Water Code section 13385. The table lists the mandatory minimum penalty (MMP) that applies.

**Table 1. Alleged Violation**

CIWQS Violation ID No.	Violation Date	Parameter (units)	Group	Effluent Limitation	Reported Value	Percent Exceedance <sup>[1]</sup>	Violation Type	MMP <sup>[2]</sup>
1148177	05/17/2024	Copper, Monthly Average (µg/L)	2	7.0	9.0	29%	C1, S	\$3,000

**Total Penalty: \$3,000**

### Legend:

CIWQS = California Integrated Water Quality System database that the Water Boards use to track violations and enforcement.

Violation ID = Identification number assigned to each permit violation within CIWQS.

C = Count – Number of violations within past 180 days, including this violation. A penalty applies under Water Code section 13385(i) when the count is greater than three (>C3).

S = Serious – A penalty applies under Water Code section 13385(h) whenever an effluent limitation is exceeded by 40 percent or more for a Group 1 pollutant or 20 percent or more for a Group 2 pollutant.

### Footnotes:

<sup>[1]</sup> Percent that a discharger's reported value exceeds the effluent limitation for a Group 1 or 2 pollutant.

<sup>[2]</sup> The MMP is required under Water Code section 13385(h) and/or (i).