

**Table 3-5: Water Quality Objectives for Municipal Supply**

<u>Parameter</u>	<u>Objective (in MG/L)</u>	<u>Parameter</u>	<u>Objective (in MG/L)</u>	<u>Parameter</u>	<u>Objective (in MG/L)</u>
<b>Physical:</b>		<b>Synthetic Organic Chemicals:</b>		<b>Volatile Organic Chemicals (cont'd):</b>	
Color (units) <sup>a</sup> .....	15.0	Alachor <sup>h</sup> .....	0.002	1,1,2-Trichloro-1,2,2-trifluoromethane <sup>h</sup> .....	1.2
Odor (number) <sup>a</sup> .....	3.0	Atrazine <sup>h</sup> .....	0.001	Toluene <sup>h</sup> .....	0.15
Turbidity (NTU) <sup>a</sup> .....	5.0	Bentazon <sup>h</sup> .....	0.018	Vinyl Chloride <sup>h</sup> .....	0.0005
pH <sup>b</sup> .....	6.5 - 8.0	Benzo(a)pyrene <sup>h</sup> .....	0.0002	Xylenes (single or sum of isomers) <sup>h</sup> .....	1.750
TDS <sup>c</sup> .....	500.0	Dalapon <sup>h</sup> .....	0.2		
EC (mmhos/cm) <sup>c</sup> .....	900	Dinoseb <sup>h</sup> .....	0.007		
Corrosivity .....	non-corrosive	Diquat <sup>h</sup> .....	0.02		
<b>Inorganic Parameters:</b>		Endothal <sup>h</sup> .....	0.1		
Aluminum <sup>d</sup> .....	1.0 <sup>d</sup> / 0.2 <sup>a</sup>	Ethylene dibromide <sup>h</sup> .....	0.00005		
Antimony <sup>d</sup> .....	0.006	Glyphosate <sup>h</sup> .....	0.7		
Arsenic <sup>d</sup> .....	0.05	Heptachlor <sup>h</sup> .....	0.00001		
Asbestos <sup>d</sup> .....	7 MFL <sup>e</sup>	Heptachlor epoxide <sup>h</sup> .....	0.00001		
Barium <sup>d</sup> .....	1.0	Hexachloreyclopentadiene <sup>h</sup> .....	0.001		
Beryllium <sup>d</sup> .....	0.004	Molinate <sup>h</sup> .....	0.02		
Chloride <sup>c</sup> .....	250.0	Oxarnyl <sup>h</sup> .....	0.05		
Cadmium <sup>d</sup> .....	0.005	Pentachlorophenol <sup>h</sup> .....	0.001		
Chromium <sup>d</sup> .....	0.05	Picloram <sup>h</sup> .....	0.5		
Copper <sup>a</sup> .....	1.0	Polychlorinated Biphenyls <sup>h</sup> .....	0.0005		
Cyanide <sup>d</sup> .....	0.15	Simazine <sup>h</sup> .....	0.004		
Fluoride <sup>f</sup> .....	0.6 - 1.7 <sup>g</sup>	Thiobencarb <sup>h</sup> .....	0.07 / 0.001		
Iron <sup>a</sup> .....	0.3				
Lead <sup>b</sup> .....	0.05				
Manganese <sup>a</sup> .....	0.05				
Mercury <sup>d</sup> .....	0.002				
Nickel <sup>d</sup> .....	0.1				
Nitrate (as NO <sub>3</sub> ) <sup>d</sup> .....	45.0				
Nitrate + Nitrite (as N) <sup>d</sup> .....	10.0				
Nitrite (as N) <sup>d</sup> .....	1.0				
Selenium <sup>d</sup> .....	0.05				
Silver <sup>b</sup> .....	0.1				
Sulfate <sup>c</sup> .....	250.0				
Thallium <sup>d</sup> .....	0.002				
Zinc <sup>a</sup> .....	5.0				
<b>Organic Parameters:</b>					
MBAS (Foaming agents) <sup>a</sup> .....	0.5				
Oil and grease <sup>b</sup> .....	none				
Phenols <sup>b</sup> .....	0.001				
Trihalomethanes <sup>b</sup> .....	0.1				
<b>Chlorinated Hydrocarbons:</b>					
Endrin <sup>h</sup> .....	0.002				
Lindane <sup>h</sup> .....	0.0002				
Methoxychlor <sup>h</sup> .....	0.03				
Toxaphene <sup>h</sup> .....	0.003				
2,3,7,8-TCDD (Dioxin) <sup>h</sup> .....	3 x 10 <sup>-8</sup>				
2,4-D <sup>h</sup> .....	0.07				
2,4,4-TP Silvex <sup>h</sup> .....	0.05				

MG/L Milligrams per liter  
pCi/L pico Curries per liter