

## State Water Resources Control Board

May 4, 2023

Mr. Dave Emmington  
125 Powder Forest Drive  
PO Box 2003  
Simsbury, CT 06070

### **ENHANCED VAPOR RECOVERY APPLICABILITY OF VEEDER-ROOT'S TLS-450 PLUS MONITORING PANEL**

Dear Mr. Emmington:

Section 25290.1.2(a) of the Health and Safety Code (H&SC) requires the California Air Resources Board (CARB) and State Water Resources Control Board (State Water Board) to certify, to the best of their knowledge and using existing resources, that equipment meeting the CARB's Enhanced Vapor Recovery (EVR) requirements also meets underground storage tank (UST) requirements located in H&SC, division 20, chapter 6.7, section 25280 et seq (H&SC Chapter 6.7) and title 23, division 3, chapter 16 (UST Regulations).

On April 11, 2023, the State Water Board received the enclosed documentation detailing Veeder-Root's TLS-450 Plus monitoring panel with In-Station Diagnostics (ISD). Based on the information provided, the State Water Board has found no evidence that the TLS-450 Plus monitoring panel with ISD conflicts with the requirements in H&SC Chapter 6.7 or UST Regulations. This determination assumes the ISD is installed in accordance with applicable CARB Executive Orders and manufacturer's instructions as required by UST Regulations. Therefore, the State Water Board certifies, to the best of its knowledge, that the TLS-450 Plus with ISD meets the requirements of H&SC Chapter 6.7 and UST Regulations.

If you have questions, please contact Austin Lemire-Baeten at (916) 327-5612 or [Austin.Lemire-Baeten@waterboards.ca.gov](mailto:Austin.Lemire-Baeten@waterboards.ca.gov).

Sincerely,



Karen Mogus  
Division of Water Quality  
Deputy Director  
State Water Resources Control Board  
[Karen.Mogus@waterboards.ca.gov](mailto:Karen.Mogus@waterboards.ca.gov)

Enclosure: Overview of Veeder-Root's TLS-450 Plus with In-Station Diagnostics (ISD)

cc: *(via email only)*

Annalisa Kihara  
Division of Water Quality  
Assistant Deputy Director  
State Water Resources Control Board  
[Annalisa.Kihara@waterboards.ca.gov](mailto:Annalisa.Kihara@waterboards.ca.gov)

Cheryl Prowell  
UST and Site Cleanup Programs Section Supervisor  
State Water Resources Control Board  
[Cheryl.Prowell@waterboards.ca.gov](mailto:Cheryl.Prowell@waterboards.ca.gov)

Tom Henderson  
UST Leak Prevention Unit and Tank Tester Licensing Manager  
State Water Resources Control Board  
[Tom.Henderson@waterboards.ca.gov](mailto:Tom.Henderson@waterboards.ca.gov)

George Lew  
Engineering and Certification Branch  
Air Resources Board  
[George.Lew@arb.ca.gov](mailto:George.Lew@arb.ca.gov)

Julie M. Osborn, Attorney IV  
Office of Chief Counsel  
State Water Resource Control Board  
[Julie.Osborn@waterboards.ca.gov](mailto:Julie.Osborn@waterboards.ca.gov)

Austin Lemire-Baeten, WRCE  
UST Leak Prevention Unit

Mr. Dave Emmington

-3-

May 4, 2023

State Water Resources Control Board  
[Austin.Lemire-Baeten@waterboards.ca.gov](mailto:Austin.Lemire-Baeten@waterboards.ca.gov)