

Issue Date: March 15, 2022

## Pneumercator Company, Inc.

### TMS 4000 Series with Level Sensor Model RSU810

#### INTERSTITIAL DETECTOR (LIQUID-PHASE)

#### Detector:

Output type: qualitative

Sampling frequency: continuous

Operating principle: float switch

#### Test Results:

	Water	Diesel	Unleaded Gasoline
<b>RSU810 Single Float</b>			
Detection time (min)	<1	<1	<1
Fall time (min)	<1	<1	<1
Height to Alarm (in)	0.759	0.860	0.928

#### Specificity Results:

**California Code of Regulations require a written statement of compatibility for systems containing products other than petroleum-based fuels (biodiesel blends greater than 20%, ethanol blends greater than 10%, solvents, etc.).**

#### Manufacturer's Specifications:

RSU810 is a hydrostatic tank collar reservoir, and has normally closed low-level alarm.

Pneumercator Company, Inc.

Evaluator: Ken Wilcox Associates

1785 Expressway Drive North

Tel: (816) 443-2494

Hauppauge, NY 11788

Date of Evaluation: 03/19/10, 12/03/2020

Tel: (800) 209-7858, (631) 293-8450 x112

Email: [jlevy@pneumercator.com](mailto:jlevy@pneumercator.com)

URL: [www.pneumercator.com](http://www.pneumercator.com)



---

| [Home](#) | [Vendors: A - F](#) | [Vendors: G - M](#) | [Vendors: N - S](#) | [Vendors: T - Z](#) | [Method Index](#) | [Glossary](#) |

Appearance on this list is not to be construed as an endorsement by any regulatory agency nor is it any guarantee of the performance of the method or equipment. Equipment should be installed and operated in accordance with all applicable laws and regulations. For full details, please refer to our expanded "[DISCLAIMER](#)" page.