

AquaLab Water Analysis
 P.O. Box 356
 Twain Harte CA 95383

State Certification # 1359
 (209) 586-3400
 Fax: (209) 586-1492

BACTERIOLOGICAL EXAMINATION OF WATER

CENTRAL SIERRA
 ENVIRONMENTAL RESOURCE COUNCIL
 P O BOX 396
 TWAIN HARTE CA 95383

LAB TURBIDITY
 NTU=~~*~~

Phone: 586 7440 JOHN BUCKLEY

Date: 7/9/09

Sampler: L. Myers & R. Crocker

Source		Reason	Type
1) Surface/ Spring	4) Reservoir	A) Routine	C) Total Coliform
2) Well Head	5) Distribution	B) Repeat	F) Fecal Coliform
3) Well Distribution	6) Treatment Plant	C) Special	H) Heterotrophic Plate Count
			E) E. coli

1538-S Collection Data							Five Portions							Presence/Absence			CFU mL 35 C @ 48HR	
Lab ID Bottle ID	Time	Location	CL2	Source	Reason	Type	Vol mL	# Positive Tubes							Coliform			
								Prsmp		Confirmed			#	P/A or MPN				
								24	48	24	24	48		48	Total	Fecal		E.coli
S A=5	11:35 AM	BBM * 2.43	/				10.0 1.0 0.1	5 5 1	- - 4	5 5 1				5 3 1	300	300	240	
T 01/1	12:30	BR * 1.58	/				10.0 1.0 0.1	5 5 1	- - 4	5 5 1				5 5 1	300	300	300	
U 1/16	1:35 PM	UFG * 0.78	/				10.0 1.0 0.1	5 4 4	- 4 2	5 - 2	- 4 2			5 4 2	220	23	23	
V 0=3	2:48 PM	LRM * 3.05	/				10.0 1.0 0.1	5 5 3	- - 4	5 5 3				5 5 3	900	900	900	

Notification/Comments:

Set-Up: Date/Time/By: 7-9 10:45 AM

Completed: Date/By: 7-12-09 CAB