

AquaLab Water Analysis  
P.O. Box 356  
Twain Harte CA 95383

State Certification # 1359  
(209) 586-3400  
Fax: (209) 586-1492

## BACTERIOLOGICAL EXAMINATION OF WATER

CENTRAL SIERRA  
ENVIRONMENTAL RESOURCE COUNCIL  
P O BOX 396  
TWIN HARTS CA 95383

LAB TURBIDITY  
NTU = \*

pg 1 of 2

Phone: 586 7440 JOHN BUCKLEY

Date: 7/31/09

Sampler: M. DeFurter  
J. Myers

Source				Reason			Type					
1) Surface/ Spring	4) Reservoir	A) Routine	C) Total Coliform	2) Well Head	5) Distribution	B) Repeat	F) Fecal Coliform	3) Well Distribution	6) Treatment Plant	C) Special	H) Heterotrophic Plate Count	E) E. coli

156111 Collection Data								Five Portions						Presence/Absence			* NTU
Lab ID Bottle ID	Time	Location	CL2	Source	Reason	Type	Vol ml	# Positive Tubes						Coliform			
								Pramp		Confirmed				P/A or MPN			
								24	48	24	24	48	48	#	Total	Fecal	
U F03	14:18 pm	B0M	/			CE	10.0 1.0 0.1	3 2 1	2 0 0	3 2 1	2 - -		5 2 1	70	17	17	0.52
V 922	12:18 pm	B0D	/			CE	10.0 1.0 0.1	3 0 0	2 0 0	3 - -	2 - -		5 0 0	23	8	8	0.52
W 901	2:50 pm	B0M2	/			CE	10.0 1.0 0.1	5 4 1	- 0 0	5 4 1			5 4 1	170	170	170	1.0
X H45	2:50 pm	B0D	/			CE	10.0 1.0 0.1	5 5 1	- - 0	5 5 1			5 5 1	300	300	300	1.1
Y 2=2	3:03	B0M1	/			CE	10.0 1.0 0.1	5 5 2	- - 0	5 5 2			5 5 2	500	500	500	3.5

Notification/Comments:

Set-Up: Date/Time/By: 7.31 1700 AG

Completed: Date/By: 8.3.09 CAD