

AquaLab Water Analysis  
 P.O. Box 356  
 Twain Harte CA 95383

State Certification # 1353  
 (209) 586-3400  
 Fax: (209) 586-1492

## BACTERIOLOGICAL EXAMINATION OF WATER

CENTRAL SIERRA  
 ENVIRONMENTAL RESOURCE COUNCIL  
 P O BOX 396  
 TWAIN HARTE CA 95383

LAB TURBIDITY  
 NTU=

pg 1 of 2

Phone: 586 7440 JOHN BUCKLEY

Date: 8/13/09

Sampler: L. Myers J. Stephens

Source	Reason	Type
1) Surface/ Spring	4) Reservoir	A) Routine
2) Well Head	5) Distribution	B) Repeat
3) Well Distribution	6) Treatment Plant	C) Special
		C) Total Coliform
		F) Fecal Coliform
		H) Heterotrophic Plate Count
		E) E. coli

Collection Data							Five Portions								Presence/Absence			NTU	
Lab ID Bottle ID	Time	Location	CL2	Source	Reason	Type	Vol mL	# Positive Tubes								Coliform			
								Prsmp		Confirmed				P/A or MPN					
								24	48	24	24	48	48	#	Total	Fecal	E.coli		
G R5#	11:15 am	BOM	/				10.0 1.0 0.1	0 0 0	2 0 0	2 - -			2 0 0	4	12	12	0.52		
H 74E	12:38 pm	WC	/				10.0 1.0 0.1	5 4 1	- 0 0	5 4 1			5 4 1	170	170	170	0.52		
I 018	1:45 pm	BPS	/				10.0 1.0 0.1	5 5 2	- - 2	5 5 2			5 5 4	1600	500	500	1		
J K9#	1:58 pm	BR	/				10.0 1.0 0.1	5 2 1	- 0 0	5 2 1			5 2 1	70	70	70	1.1		
K 1K4	2:08 pm	BRJ	/				10.0 1.0 0.1	5 2 3	- 3 1	5 2 3	- 2 1			5 5 -4	1600	120	90	1.7	

Notification/Comments:

Set-Up: Date/Time/By: 8.13 1600 LLS  
 Completed: Date/By: 8.17.09 CAP