

AquaLab Water Analysis
 P.O. Box 356
 Twain Harte CA 95383

State Certification # 1359
 (209) 586-3400
 Fax: (209) 586-1492

BACTERIOLOGICAL EXAMINATION OF WATER

CENTRAL SIERRA
 ENVIRONMENTAL RESOURCE COUNCIL
 P O BOX 396
 TWAIN HARTE CA 95383

LAB TURBIDITY
 NTU=

Phone: 586 7440 JOHN BUCKLEY

Date: 8/27/09

Sampler: L. Myers J. Stephens

Source		Reason	Type
1) Surface/ Spring	4) Reservoir	A) Routine	C) Total Coliform
2) Well Head	5) Distribution	B) Repeat	F) Fecal Coliform
3) Well Distribution	6) Treatment Plant	C) Special	H) Heterotrophic Plate Count E) E. coli

Collection Data				Five Portions										Presence/Absence			NTU	
Lab ID Bottle ID	Time	Location	CL2	Source	Reason	Type	Vol mL	# Positive Tubes							Coliform			
								Prsmp		Confirmed			P/A or MPN		Total	Fecal		E.coli
								24	48	24	24	48	48	#				
1588 W U=4	1:22 pm	RC	/	ICE	E		10.0 1.0 0.1	5 5 1	- - 1	5 5 1	- - 0	- - 1	5 5 2	500	300	300	1.1	

Notification/Comments:

Set-Up: Date/Time/By: 8-27 1600 ASC

Completed: Date/By: 8-31-09 CAP