

AquaLab Water Analysis  
 P.O. Box 356  
 Twain Harte CA 95383

State Certification # 1359  
 (209) 586-3400  
 Fax: (209) 586-1492

### BACTERIOLOGICAL EXAMINATION OF WATER

CENTRAL SIERRA  
 ENVIRONMENTAL RESOURCE COUNCIL  
 P O BOX 396  
 TWAIN HARTE CA 95383

LAB TURBIDITY  
 NTU=

Phone: 586 7440 JOHN BUCKLEY

Date: 9/17/09

Sampler: Katherine  
 C. Myers Gaumble

Source		Reason	Type
1) Surface/ Spring	4) Reservoir	A) Routine	C) Total Coliform
2) Well Head	5) Distribution	B) Repeat	F) Fecal Coliform
3) Well Distribution	6) Treatment Plant	C) Special	H) Heterotrophic Plate Count
			E) E. coli

Collection Data							Five Portions							Presence/Absence			NTU		
Lab ID Bottle ID	Time	Location	CL2	Source	Reason	Type	Vol ml	# Positive Tubes						Coliform					
								Prsmp		Confirmed				P/A or MPN					
								24	48	24	24	48	48	#	Total	Fecal		E.coli	
R 926	11:19 am	NFT	/	ICE	E		10.0 1.0 0.1	5 1 0	- 2 0	5 1 -	- 2 -			5 3 0	80	30	30	0.32	
S 032	11:39 am	ALG	/	ICE	E		10.0 1.0 0.1	5 1 0	- 2 0	5 1 -	- 2 -			5 3 0	80	30	30	0.30	
T 909	13:45	RC	/	ICE	E		10.0 1.0 0.1	5 5 2	- - 0	5 5 2				5 5 2	500	500	300	1.3	

Notification/Comments:

Set-Up: Date/Time/By: 9-17 1630 ASL  
 Completed: Date/By: 9-20-09 CAB