

D R A F T

STATE OF CALIFORNIA
STATE WATER RESOURCES CONTROL BOARD
ORDER WQ 20XX-XXX-UST

**In the Matter of Underground Storage Tank (UST) Case Closure
Pursuant to Health and Safety Code Section 25296.40 and the
Low-Threat Underground Storage Tank Case Closure Policy**

BY THE CHIEF DEPUTY DIRECTOR:¹

By this order, the Chief Deputy Director directs closure of the UST case at the site listed below, pursuant to section 25296.10 of the Health and Safety Code.² The name of the Petitioner, the site name, the site address, the Underground Storage Tank Cleanup Fund (Fund) claim number if applicable, current and former lead agencies, and case numbers are as follows:

AMERCO Real Estate Company (Petitioner)

U-Haul/Lynwood Moving Center

11716 Long Beach Boulevard, Lynwood, Los Angeles County

Los Angeles Regional Water Quality Control Board, Case No. R-12239

State Water Resources Control Board (State Water Board) Petition

No. DWQP-0264

¹ State Water Board Resolution No. 2012-0061 delegates to the Executive Director the authority to close or require the closure of any UST case if the case meets the criteria found in the State Water Board's Low-Threat Underground Storage Tank Case Closure Policy adopted by State Water Board Resolution No. 2012-0016. Pursuant to Resolution No. 2012-0061, the Executive Director has delegated this authority to the Chief Deputy Director.

² Unless otherwise noted, all references are to the California Health and Safety Code.

DRAFT

I. STATUTORY AND PROCEDURAL BACKGROUND

Health and Safety Code Section 25296.40 allows for an owner or operator, or responsible party, who has a UST case, who believes that the corrective plan has been satisfactorily implemented, and where closure has not been granted, to petition the State Water Board for review of their case. Upon review of the case, the State Water Board may close or require the closure of any UST case if it is determined that corrective action has been completed in compliance with all of the requirements of subdivisions (a) and (b) of section 25296.10. The State Water Board, or in certain cases the State Water Board Executive Director or Chief Deputy Director, may close a case or require the closure of a UST case. Closure of a UST case is appropriate where the corrective action ensures the protection of human health, safety, and the environment and where the corrective action is consistent with: 1) chapter 6.7 of division 20 of the Health and Safety Code and implementing regulations; 2) any applicable waste discharge requirements or other orders issued pursuant to division 7 of the Water Code; 3) all applicable state policies for water quality control; and 4) all applicable water quality control plans.

State Water Board staff has completed a review of the UST case identified above, and recommends that this case be closed. The recommendation is based upon the facts and circumstances of this particular UST case. The attached UST Case Closure Summary has been prepared for the case identified above and is incorporated by reference. The UST case record that is the basis for determining compliance with the Water Quality Control Policy for Low-Threat Underground Storage Tank Case Closures (Low-Threat Closure Policy or Policy) is available on the State Water Board's GeoTracker database.

[GeoTracker Case Record](http://geotracker.waterboards.ca.gov/?gid=T0603792883): <http://geotracker.waterboards.ca.gov/?gid=T0603792883>

Low-Threat Closure Policy

The Policy became effective on August 17, 2012. The Policy establishes consistent statewide case closure criteria for certain low threat petroleum UST sites. In the absence of unique attributes or site-specific conditions that demonstrably increase

DRAFT

the risk associated with residual petroleum constituents, cases that meet the general and media-specific criteria in the Low-Threat Closure Policy pose a low threat to human health, safety, the environment, and are appropriate for closure under Health and Safety Code section 25296.10. The Policy provides that if a regulatory agency determines that a case meets the general and media-specific criteria of the Policy, then the regulatory agency shall notify responsible parties and other specified interested persons that the case is eligible for case closure. Unless the regulatory agency revises its determination based on comments received on the proposed case closure, the Policy provides that the agency shall issue a uniform closure letter as specified in Health and Safety Code section 25296.10. The uniform closure letter may only be issued after the expiration of the 60-day comment period, proper destruction or maintenance of monitoring wells or borings, and removal of waste associated with investigation and remediation of the site.

Health and Safety Code section 25299.57. subdivision (I)(1) provides that claims for reimbursement of corrective action costs that are received by the Fund more than 365 days after the date of a uniform closure letter or letter of commitment, whichever occurs later, shall not be reimbursed unless specified conditions are satisfied.

Relief from Responsibility at Commingled Release Sites

In 2013, the State Water Board adopted State Water Board Order WQ 2013-0109 (*In the Matter of the Petition of James Salvatore*, hereafter *Salvatore*), which provides a test for relieving a party from responsibility where the party's unauthorized release has commingled with a release from another party. The *Salvatore* test acknowledges the relative contributions of the responsible parties and provides relief to the party whose release is not significant enough on its own to require corrective action. (*Salvatore*, p. 13.) Under this test, a party may be relieved from responsibility for a release if the party demonstrates that its release, considered separately from other commingled releases, meets case closure criteria and the site should be closed. (*Ibid.*) The party seeking removal of the responsible party status must demonstrate that the separate release for which the party is responsible has been adequately investigated and characterized, and that there are sufficient data to determine that the case based

DRAFT

on the individual release meets case closure criteria. (*Id.*, pp. 13-14.) In addition, as a condition of closure, the party seeking relief must provide reasonable access to the responsible party performing corrective action at the relieved party's site. (*Id.*, p. 14.) Finally, the State Water Board stated that this test is not applicable in circumstances where a financially responsible party has not been identified and removal of a party may result in the creation of an orphan site. (*Id.*, p. 19.)

II. FINDINGS

Pursuant to the test established by State Water Board Order WQ 2013-0109, a party may be removed as a responsible party for a UST cleanup case where the responsible party's unauthorized release has commingled with a release from another party if the responsible party's unauthorized release has been adequately investigated and characterized and there are sufficient data to determine that the responsible party's release, when considered separately from other releases that have commingled with the responsible party's release, meets State Water Board closure policies and the case should be closed. There are sufficient data for the State Water Board to determine that this case should be closed, as summarized in the attached UST Case Closure Summary. As a condition of closure, the responsible party(ies) in this case must provide reasonable access, as needed, to the responsible party(ies) performing corrective action associated with the case with which this one is or was commingled. Based on the State Water Board's review, closure of the case will not create an orphan site.

Based upon the facts in the UST record and the hydrogeologic conditions at the site, as summarized in the attached UST Case Closure Summary, the State Water Board finds that corrective action taken to address the unauthorized release of petroleum at the UST release site identified as:

AMERCO Real Estate Company (Petitioner)

U-Haul/Lynwood Moving Center

11716 Long Beach Boulevard, Lynwood, Los Angeles County

DRAFT

**Los Angeles Regional Water Quality Control Board, Case No. R-12239
State Water Resources Control Board (State Water Board) Petition
No. DWQP-0264**

ensures protection of human health, safety, and the environment and is consistent with chapter 6.7 of division 20 of the Health and Safety Code and implementing regulations, the Low-Threat Closure Policy and with other applicable water quality control policies and plans.

The unauthorized release from the UST consisted only of petroleum. This order directs closure for the petroleum UST case at the site. This order does not address non-petroleum contamination at the site, if non-petroleum contamination is present.

Pursuant to the Low-Threat Closure Policy, notification has been provided to all entities that are required to receive notice of the proposed case closure, a 60-day comment period has been provided to notified parties, and any comments received have been considered by the State Water Board in determining that the case should be closed.

Pursuant to section 21080.5 of the Public Resources Code, environmental impacts associated with the adoption of this order were analyzed in the substitute environmental document (SED) the State Water Board approved on May 1, 2012. The SED concludes that all environmental effects of adopting and implementing the Low-Threat Closure Policy are less than significant, and environmental impacts as a result of adopting this order in compliance with the Policy are no different from the impacts that are reasonably foreseen as a result of the Policy itself. A Notice of Decision was filed August 17, 2012. No new environmental impacts or any additional reasonably foreseeable impacts beyond those that were addressed in the SED will result from adopting this order.

The UST case identified above may be the subject of orders issued by the Regional Water Quality Control Board (Regional Water Board) pursuant to division 7 of the Water Code. Any orders that have been issued by the Regional Water Board pursuant to division 7 of the Water Code, or directives issued by a Local Oversight

DRAFT

Program (LOP) agency for this case should be rescinded to the extent they are inconsistent with this order.

III. ORDER

IT IS THEREFORE ORDERED that:

- A. The UST case identified in Section II of this order, meeting the general and media-specific criteria established in the Low-Threat Closure Policy, be closed in accordance with the following conditions and after the following actions are complete. The Petitioner is ordered to provide reasonable access, as needed, to the responsible party(ies) performing corrective action associated with the case with which this one is or was commingled. Prior to the issuance of a uniform closure letter, the Petitioner is ordered to:
1. Properly destroy any and all monitoring wells and borings unless the owner of real property on which the well or boring is located certifies that the wells or borings will be maintained in accordance with local or state requirements;
 2. Properly remove from the site and manage any and all waste piles, drums, debris, and other investigation and remediation derived materials in accordance with local or state requirements; and
 3. Within six months of the date of this order, submit documentation to the regulatory agency overseeing the UST case identified in Section II of this order that the tasks in subparagraphs (1) and (2) have been completed.
- B. The tasks in subparagraphs (1) and (2) of Paragraph (A) are ordered pursuant to Health and Safety Code section 25296.10, and failure to comply with these requirements may result in the imposition of civil penalties pursuant to Health and Safety Code section 25299, subdivision (d)(1). Penalties may be imposed administratively by the State Water Board or Regional Water Board.

DRAFT

- C. Within 30 days of receipt of proper documentation from the responsible party(ies) that requirements in subparagraphs (1) and (2) of Paragraph (A) are complete, the regulatory agency that is responsible for oversight of the UST case identified in Section II of this order shall notify the State Water Board that the tasks have been satisfactorily completed.

- D. Within 30 days of notification from the regulatory agency that the tasks are complete pursuant to Paragraph (C), the Deputy Director of the Division of Water Quality shall issue a uniform closure letter consistent with Health and Safety Code section 25296.10, subdivision (g) and upload the uniform closure letter to GeoTracker.

- E. Pursuant to section 25299.57, subdivision (l)(1), and except in specified circumstances, all claims for reimbursement of corrective action costs must be received by the Fund within 365 days of issuance of the uniform closure letter in order for the costs to be considered.

- F. Any Regional Water Board or LOP agency directive or order that directs corrective action or other action inconsistent with case closure for the UST case identified in Section II is rescinded, but only to the extent the Regional Water Board order or LOP agency directive is inconsistent with this order.

SIGNATURE

Chief Deputy Director

Date

[Instructions: To replace the signature above, right-click on the picture that reads "signature" and select "change picture." Navigate to the desired signature and select. If the signature changes the location of the signature line, just adjust the picture size, so its at the same level as the date line.]