



EDMUND G. BROWN JR.
GOVERNOR



MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board
Division of Drinking Water

October 17, 2014

Mr. Calvin Yarbrough, Water Master
Big Creek CSD
P.O. Box 169
Big Creek, CA 93605

RE: Big Creek CSD – System No. 1000005
Compliance Order No. 03-23-14R-015

Dear Mr. Yarbrough:

The State Water Resources Control Board (Water Board), Division of Drinking Water is issuing the Big Creek CSD a Compliance Order for violation of Section 116555 of the California Health and Safety Code. Section 116555 requires each public water system to have a reliable supply of water to serve its customers. Because of drought conditions and senior water right demands, the Water Board's Division of Water Rights determined that water was not available for the Big Creek CSD water system's San Joaquin River source and notified the Big Creek CSD of the need to curtail its diversions. For this reason, the Division of Drinking Water has made the determination that the Big Creek CSD is not able to meet the requirements of Section 116555. The Compliance Order contains seven directives with deadlines for completion of actions specified.

This Order does not require you to cease using the source that has been curtailed to provide for the basic health and safety needs of your customers, but does require that you take specific steps in the interim to prevent new service connections and to secure a reliable long-term supply of water. Successful implementation of the directives contained in the order will ensure compliance with California Safe Drinking Water Act as well as the State's water rights system.

Please read the order carefully and contact me at (559) 447-3300 if you have any questions

Sincerely,

A handwritten signature in black ink that reads "Betsy S. Lichti".

Betsy S. Lichti, P.E.
Senior Sanitary Engineer, Fresno District
SOUTHERN CALIFORNIA BRANCH
DRINKING WATER FIELD OPERATIONS

BSL/sp

Enclosure: Compliance Order No. 03-23-14R-015

cc: David Pomaville, Director
Fresno County Department of Public Health
1221 Fulton Mall
P O Box 11867, Fresno CA 93775-1867

Alan Weaver, Director
Fresno County Department of Public Works and Planning
2220 Tulare Street, 6th Floor
Fresno, CA 93721

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

**STATE OF CALIFORNIA
STATE WATER RESOURCES CONTROL BOARD
DIVISION OF DRINKING WATER**

IN RE: **BIG CREEK CSD**
 WATER SYSTEM NO. 1000005

TO: MR. CALVIN YARBROUGH
 BIG CREEK CSD
 P.O. BOX 169
 BIG CREEK, CA 93605

COMPLIANCE ORDER NO. 03-23-14R-015

**FOR VIOLATION OF CALIFORNIA HEALTH AND SAFETY CODE
SECTION 116555(a)(3)**

Issued on October 17, 2014

Section 116655 of the California Health and Safety Code (hereinafter "CHSC") authorizes the issuance of a compliance order to a public water system for violation or threatened violations of the California Safe Drinking Water Act (CSHC, Division 104, Part 12, Chapter 4, commencing with Section 116270) (hereinafter "California SDWA"), or any permit, regulation or standard issued or adopted thereunder.

The State Water Resources Control Board (hereinafter "Board"), acting by and through its Division of Drinking Water (hereinafter "Division") and the Deputy Director for the Division (hereinafter "Deputy Director"), hereby issues a compliance order to Big Creek CSD for failure to comply with CHSC Section 116555 (a)(3)

1
2 A copy of the applicable statutes and regulations is included in Appendix 1, which is
3 attached hereto and incorporated herein by this reference.
4

5 **STATEMENT OF FACTS**
6

7
8 Big Creek CSD water system (hereinafter “Water System”) is a community public water
9 system serving a population of approximately 124 through 67 service connections. The
10 Water System is located in the town of Big Creek in Fresno County and supplies water for
11 domestic purposes. The Water System operates under a Domestic Water Supply Permit No.
12 03-23-09P-046, issued by the Division on August 13, 2009.
13

14
15 On May 27 and 29, 2014, the Board issued curtailment notices to certain junior water right
16 holders in the Sacramento River and San Joaquin River watersheds. By means of the
17 curtailment notice, the Water System was notified “of the need to immediately stop
18 diverting under its post-1914 water rights....”
19

20
21 Big Creek CSD Water System obtains water supply from San Joaquin River watershed via
22 Southern California Edison Big Creek Powerhouse # 1 water system (hereinafter “SCE
23 Water System”). The SCE Water System intake is on the Huntington Penstock. SCE treats
24 the water using a direct filtration surface water treatment plant which is delivered to SCE
25 Water System and Big Creek CSD Water System. Big Creek CSD Water System has
26 submitted a “2014 Curtailed Water Rights Human Health and Safety Claims Form” to the
27

1 Board, claiming that the System's curtailed water right is "the sole source of water for
2 human health and safety uses."

3
4 In response to extreme drought conditions in California, the Board adopted CCR, Title 23,
5 Sections 863, 864, and 865 as an emergency regulation (hereinafter "Conservation
6 Regulation"). The Conservation Regulation is intended to ensure that water agencies, their
7 customers, and state residents increase water conservation, primarily through reduction of
8 outdoor urban water use.
9

10
11 **DETERMINATIONS**
12

13
14 The Division has determined that the Water System does not provide a reliable and
15 adequate supply of pure, wholesome, healthful, and potable water, in that the Water System
16 does not have legal access to sufficient water to support its customers' basic human health
17 and safety needs. The System therefore has violated, and continues to violate, CHSC
18 Section 116555 (a)(3).
19

20
21 **DIRECTIVES**
22

23 **The System is hereby directed to take the following actions:**
24

- 25
26 1. Effective immediately upon its receipt of this Order, the Water System shall not make
27 any additional service connections to its water system, including any such service
connections for which a "will serve" letter was issued at any time by the Water System,

1 but for which a building permit was not issued prior to the date of this Order. As used in
2 this Order, "will serve" letter means any form of notice, representation or agreement
3 that the Water System will supply water to a property, parcel or structure.
4

5 2. By **October 31, 2014**, the Water System shall identify any and all properties for which
6 "will serve" letters have been issued, but a service connection has not been made.
7

8 3. By **November 30, 2014**, the Water System shall advise the owner(s) of those properties
9 and all appropriate local planning agencies that the "will serve" letter issued for such
10 property is null and void and may not be relied upon for any purpose.
11

12 4. By **November 30, 2014**, the Water System shall provide to the Division the following
13 documents:
14

15 a) copies of all "will serve" letters issued by the Water System at any time for which a
16 service connection has not been made, including the address or parcel number of the
17 respective property;
18

19 b) a list of the property owners and applicable planning agencies it notified that its
20 "will serve" letters are null and void along with a certification that the required
21 notification was completed by the Water System; and
22

23 c) a current list of all service connections, including the address of each.
24
25
26
27

1 5. By **November 30, 2014**, the Water System shall provide to the Division, for its review
2 and approval, a plan for complying with the Conservation Regulation – in particular, the
3 *Mandatory Actions for Water Suppliers* specified in Title 23, CCR, Section 865 –
4 including a schedule for implementation of said plan. The System shall comply with
5 the schedule in the approved plan. A copy of the applicable regulation section is
6 included in Appendix 1.

7
8 6. By **April 30, 2015**, the Water System shall provide to the Division, for its review and
9 approval, a Source Capacity Planning Study pursuant to Title 22, CCR, Section 64558.
10 The Study shall be prepared by a Civil Engineer, registered in the State of California, or
11 another qualified person approved by the Division. The Study shall include a plan for
12 meeting the *projected system demand* identified in the approved Source Capacity
13 Planning Study, including a schedule for implementation of said plan. The Water
14 System shall comply with the schedule in the approved plan.

15
16
17 7. By the last day of March, June, September, and December of each calendar year
18 following the Division's approval of the plan for meeting the *projected system demand*,
19 the Water System shall provide progress reports to the Division regarding compliance
20 with said plan. The Water System shall continue submitting these reports until the plan
21 for meeting the *projected system demand* is fully implemented, or until the Division
22 issues written approval to cease submitting them.
23

24
25 The Division reserves the right to make such modifications to this Order as it may deem
26 necessary to protect public health and safety. Such modifications may be issued as
27 amendments to this Order and shall be deemed effective upon issuance.

1 Nothing in this Order relieves the System of its obligation to meet the requirements of the
2 California SDWA, or any regulation, permit, standard or order issued or adopted
3 thereunder.

4 All submittals required by this Order shall be submitted to the Division at the following
5 address:
6

7 All submittals required by this Order shall be addressed to:

8 Betsy S. Lichti, P.E.
9 Fresno District Engineer
10 State Water Resources Control Board
11 Division of Drinking Water
12 265 W. Bullard Avenue, Suite 101
13 Fresno, CA 93704

14 **PARTIES BOUND**

15
16 This Order shall apply to and be binding upon Big Creek CSD, its owners, shareholders,
17 officers, directors, agents, employees, contractors, successors, and assignees.
18


19 **SEVERABILITY**

20
21 The directives of this Compliance Order are severable, and Big Creek CSD shall comply
22 with each and every provision thereof notwithstanding the effectiveness of any provision.
23
24
25
26
27

1
2 **FURTHER ENFORCEMENT ACTION**

3
4 The California SDWA authorizes the Division to issue citations and compliance orders with
5 assessment of administrative penalties to a public water system for violation or continued
6 violation of the requirements of the California SDWA or any permit, regulation, permit or
7 order issued or adopted thereunder including, but not limited to, failure to correct a violation
8 identified in a citation or compliance order. The California SDWA also authorizes the
9 Division to take action to suspend or revoke a permit that has been issued to a public water
10 system if the system has violated applicable law or regulations or has failed to comply with
11 an order of the Division; and to petition the superior court to take various enforcement
12 measures against a public water system that has failed to comply with an order of the
13 Division. The Division does not waive any further enforcement action by issuance of this
14 compliance order.
15
16
17
18

19 10-17-2014
20 Date


21 Carl L. Carlucci, P.E.
22 Supervising Sanitary Engineer
23 Central California Section
24 SOUTHERN CALIFORNIA BRANCH
25 DRINKING WATER FIELD OPERATIONS

26 CLC/BSL/SP

27 **Attachments:**
Attachment 1: Applicable Authorities

**APPENDIX 1. APPLICABLE STATUTES AND REGULATIONS FOR
COMPLIANCE ORDER NO. 03-23-14R-015**

NOTE: The following language is provided for the convenience of the recipient, and cannot be relied upon as the State of California's representation of the law. The published codes are the only official representation of the law. Regulations related to drinking water are in Titles 22 and 17 of the California Code of Regulations. Statutes related to drinking water are in the Health & Safety Code, the Water Code, and other codes.

Section 116275(s) of the Health and Safety Code states in relevant part:

(s) "Service connection" means the point of connection between the customer's piping or constructed conveyance, and the water system's meter, service pipe, or constructed conveyance.

Section 116555 of the Health and Safety Code states in relevant part:

(a) Any person who owns a public water system shall ensure that the system does all of the following:

- (1) Complies with primary and secondary drinking water standards.
- (2) Will not be subject to backflow under normal operating conditions.
- (3) Provides a reliable and adequate supply of pure, wholesome, healthful, and potable water.

Section 116655 of the Health and Safety Code states in relevant part:

(a) Whenever the department determines that any person has violated or is violating this chapter, or any permit, regulation, or standard issued or adopted pursuant to this chapter, the director may issue an order doing any of the following:

- (1) Directing compliance forthwith.
- (2) Directing compliance in accordance with a time schedule set by the department.
- (3) Directing that appropriate preventive action be taken in the case of a threatened violation.

(b) An order issued pursuant to this section may include, but shall not be limited to, any or all of the following requirements:

- (1) That the existing plant, works, or system be repaired, altered, or added to.

- (2) That purification or treatment works be installed.
- (3) That the source of the water supply be changed.
- (4) That no additional service connection be made to the system.
- (5) That the water supply, the plant, or the system be monitored.
- (6) That a report on the condition and operation of the plant, works, system, or water supply be submitted to the department.

Title 22, CCR, Section 64558 states in relevant part:

(a) If directed by the Department to do so based on its determination that there is an existing or potential problem with the system's source capacity or a proposed expansion pursuant to section 64556(a)(5), a water system shall submit a Source Capacity Planning Study (Study) containing the following information:

- (1) The anticipated growth of the water system over a projected period of at least ten years in terms of the population and number and type of residential, commercial, and industrial service connections to be served by the water system.
- (2) Estimates of the amount of water needed to meet the total annual demand and the MDD over the projected ten-year growth period (projected system demand). Methods, assumptions, and calculations used to estimate the projected system demand shall be included.
- (3) A map and description of the entire existing and proposed service area, showing:
 - (A) The location of each water source, including wells that are abandoned, out-of-service, destroyed, standby, or inactive;
 1. Any valid water rights owned by the system for surface water sources, including information on any limitations or restrictions of those rights;
 2. For a groundwater aquifer, the groundwater levels and drawdown patterns;
 3. Permits or approvals for groundwater extraction if pumping from an adjudicated groundwater basin;
 4. Existing and planned source pumping capability and distribution storage capacity for the system as a whole and for each pressure zone;
 5. The calculated sustained well yields of existing wells if groundwater sources are used;
 6. Permits, if required, for any waters proposed for use to offset potable water demand; and

7. A Source Water Assessment for each potable water source.

- (B) Distribution system piping, pressure zones, hydropneumatic tanks, and reservoirs;
- (C) Valves, sample taps, flow meters, unmetered service connections, and other system appurtenances;
- (D) Conveyance facilities;
- (E) Any flood plains in the projected service area; and
- (F) The 100 year flood or highest recorded flood level, whichever is higher.

(b) If directed by the Department to do so based on its determination that a study is out of date, a water system shall update and submit the Study to the Department.

(c) Water systems that have submitted an Urban Water Management Plan to the Department of Water Resources pursuant to Water Code Part 2.6 commencing with section 10610, may submit a copy of that report in lieu of some or all of the requirements of subsection (a) to the extent such information is included in the plan.

Title 23, CCR, Section 865 states in relevant part:

Mandatory Actions by Water Suppliers.

(a) The term “urban water supplier,” when used in this section, refers to a supplier that meets the definition set forth in Water Code section 10617, except it does not refer to suppliers when they are functioning solely in a wholesale capacity, but does apply to suppliers when they are functioning in a retail capacity.

(b)(1) To promote water conservation, each urban water supplier shall implement all requirements and actions of the stage of its water shortage contingency plan that imposes mandatory restrictions on outdoor irrigation of ornamental landscapes or turf with potable water.

(2) As an alternative to subdivision (b)(1), an urban water supplier may submit a request to the Executive Director for approval of an alternate plan that includes allocation-based rate structures that satisfies the requirements of chapter 3.4 (commencing with section 370) of division 1 of the Water Code, and the Executive Director may approve such an alternate plan upon determining that the rate structure, in conjunction with other measures, achieves a level of conservation that would be superior to that achieved by implementing limitations on outdoor irrigation of ornamental landscapes or turf with potable water by the persons it serves to no more than two days per week.

(c) To promote water conservation, each urban water supplier that does not have a water shortage contingency plan or has been notified by the Department of Water Resources that its water shortage contingency plan does not meet the requirements of Water Code section 10632 shall, within thirty (30) days, limit outdoor irrigation of ornamental landscapes or turf with potable water by the persons it serves

to no more than two days per week or shall implement another mandatory conservation measure or measures intended to achieve a comparable reduction in water consumption by the persons it serves relative to the amount consumed in 2013.

(d) In furtherance of the promotion of water conservation each urban water supplier shall prepare and submit to the State Water Resources Control Board by the 15th of each month a monitoring report on forms provided by the Board. The monitoring report shall include the amount of potable water the urban water supplier produced, including water provided by a wholesaler, in the preceding calendar month and shall compare that amount to the amount produced in the same calendar month in 2013. Beginning October 15, 2014, the monitoring report shall also estimate the gallons of water per person per day used by the residential customers it serves. In its initial monitoring report, each urban water supplier shall state the number of persons it serves.

(e) To promote water conservation, each distributor of a public water supply, as defined in Water Code section 350, that is not an urban water supplier shall, within thirty (30) days, take one or more of the following actions:

- (1) Limit outdoor irrigation of ornamental landscapes or turf with potable water by the persons it serves to no more than two days per week; or
- (2) Implement another mandatory conservation measure or measures intended to achieve a comparable reduction in water consumption by the persons it serves relative to the amount consumed in 2013.

**APPENDIX 1. APPLICABLE STATUTES AND REGULATIONS FOR
COMPLIANCE ORDER NO. 03-23-14R-015**

NOTE: The following language is provided for the convenience of the recipient, and cannot be relied upon as the State of California's representation of the law. The published codes are the only official representation of the law. Regulations related to drinking water are in Titles 22 and 17 of the California Code of Regulations. Statutes related to drinking water are in the Health & Safety Code, the Water Code, and other codes.

Section 116275(s) of the Health and Safety Code states in relevant part:

(s) "Service connection" means the point of connection between the customer's piping or constructed conveyance, and the water system's meter, service pipe, or constructed conveyance.

Section 116555 of the Health and Safety Code states in relevant part:

(a) Any person who owns a public water system shall ensure that the system does all of the following:

- (1) Complies with primary and secondary drinking water standards.
- (2) Will not be subject to backflow under normal operating conditions.
- (3) Provides a reliable and adequate supply of pure, wholesome, healthful, and potable water.

Section 116655 of the Health and Safety Code states in relevant part:

(a) Whenever the department determines that any person has violated or is violating this chapter, or any permit, regulation, or standard issued or adopted pursuant to this chapter, the director may issue an order doing any of the following:

- (1) Directing compliance forthwith.
- (2) Directing compliance in accordance with a time schedule set by the department.
- (3) Directing that appropriate preventive action be taken in the case of a threatened violation.

(b) An order issued pursuant to this section may include, but shall not be limited to, any or all of the following requirements:

- (1) That the existing plant, works, or system be repaired, altered, or added to.

- (2) That purification or treatment works be installed.
- (3) That the source of the water supply be changed.
- (4) That no additional service connection be made to the system.
- (5) That the water supply, the plant, or the system be monitored.
- (6) That a report on the condition and operation of the plant, works, system, or water supply be submitted to the department.

Title 22, CCR, Section 64558 states in relevant part:

(a) If directed by the Department to do so based on its determination that there is an existing or potential problem with the system's source capacity or a proposed expansion pursuant to section 64556(a)(5), a water system shall submit a Source Capacity Planning Study (Study) containing the following information:

- (1) The anticipated growth of the water system over a projected period of at least ten years in terms of the population and number and type of residential, commercial, and industrial service connections to be served by the water system.
- (2) Estimates of the amount of water needed to meet the total annual demand and the MDD over the projected ten-year growth period (projected system demand). Methods, assumptions, and calculations used to estimate the projected system demand shall be included.
- (3) A map and description of the entire existing and proposed service area, showing:
 - (A) The location of each water source, including wells that are abandoned, out-of-service, destroyed, standby, or inactive;
 1. Any valid water rights owned by the system for surface water sources, including information on any limitations or restrictions of those rights;
 2. For a groundwater aquifer, the groundwater levels and drawdown patterns;
 3. Permits or approvals for groundwater extraction if pumping from an adjudicated groundwater basin;
 4. Existing and planned source pumping capability and distribution storage capacity for the system as a whole and for each pressure zone;
 5. The calculated sustained well yields of existing wells if groundwater sources are used;
 6. Permits, if required, for any waters proposed for use to offset potable water demand; and

7. A Source Water Assessment for each potable water source.

- (B) Distribution system piping, pressure zones, hydropneumatic tanks, and reservoirs;
- (C) Valves, sample taps, flow meters, unmetered service connections, and other system appurtenances;
- (D) Conveyance facilities;
- (E) Any flood plains in the projected service area; and
- (F) The 100 year flood or highest recorded flood level, whichever is higher.

(b) If directed by the Department to do so based on its determination that a study is out of date, a water system shall update and submit the Study to the Department.

(c) Water systems that have submitted an Urban Water Management Plan to the Department of Water Resources pursuant to Water Code Part 2.6 commencing with section 10610, may submit a copy of that report in lieu of some or all of the requirements of subsection (a) to the extent such information is included in the plan.

Title 23, CCR, Section 865 states in relevant part:

Mandatory Actions by Water Suppliers.

(a) The term “urban water supplier,” when used in this section, refers to a supplier that meets the definition set forth in Water Code section 10617, except it does not refer to suppliers when they are functioning solely in a wholesale capacity, but does apply to suppliers when they are functioning in a retail capacity.

(b)(1) To promote water conservation, each urban water supplier shall implement all requirements and actions of the stage of its water shortage contingency plan that imposes mandatory restrictions on outdoor irrigation of ornamental landscapes or turf with potable water.

(2) As an alternative to subdivision (b)(1), an urban water supplier may submit a request to the Executive Director for approval of an alternate plan that includes allocation-based rate structures that satisfies the requirements of chapter 3.4 (commencing with section 370) of division 1 of the Water Code, and the Executive Director may approve such an alternate plan upon determining that the rate structure, in conjunction with other measures, achieves a level of conservation that would be superior to that achieved by implementing limitations on outdoor irrigation of ornamental landscapes or turf with potable water by the persons it serves to no more than two days per week.

(c) To promote water conservation, each urban water supplier that does not have a water shortage contingency plan or has been notified by the Department of Water Resources that its water shortage contingency plan does not meet the requirements of Water Code section 10632 shall, within thirty (30) days, limit outdoor irrigation of ornamental landscapes or turf with potable water by the persons it serves

to no more than two days per week or shall implement another mandatory conservation measure or measures intended to achieve a comparable reduction in water consumption by the persons it serves relative to the amount consumed in 2013.

(d) In furtherance of the promotion of water conservation each urban water supplier shall prepare and submit to the State Water Resources Control Board by the 15th of each month a monitoring report on forms provided by the Board. The monitoring report shall include the amount of potable water the urban water supplier produced, including water provided by a wholesaler, in the preceding calendar month and shall compare that amount to the amount produced in the same calendar month in 2013. Beginning October 15, 2014, the monitoring report shall also estimate the gallons of water per person per day used by the residential customers it serves. In its initial monitoring report, each urban water supplier shall state the number of persons it serves.

(e) To promote water conservation, each distributor of a public water supply, as defined in Water Code section 350, that is not an urban water supplier shall, within thirty (30) days, take one or more of the following actions:

(1) Limit outdoor irrigation of ornamental landscapes or turf with potable water by the persons it serves to no more than two days per week; or

(2) Implement another mandatory conservation measure or measures intended to achieve a comparable reduction in water consumption by the persons it serves relative to the amount consumed in 2013.

